



ASSESSMENT OF ERROR DUE TO ORIFICE DIAMETER MIS-MEASUREMENT AT BLACKROD

A Report for

**National Grid
Brick Kiln Street
HINCKLEY
Leicestershire
LE10 0NA**

REPORT NO: 2010/32 (Rev. 2)

PROJECT NO: NGR009

DATE: 1 JUNE 2010



This report is issued as part of the contract under which the work has been carried out for the client.

NOTES

- 1 This report may be published in full by the client unless it includes information supplied in confidence by TUV NEL Ltd or any third party. Such information, if included within the report, shall be identified as confidential by TUV NEL Ltd.
- 2a The prior written consent of TUV NEL Ltd shall be obtained by the client before publication by them of any extract from, or abridgement of, this report.
- 2b The prior written consent of TUV NEL Ltd shall be obtained by the client before publication:
 - Where such publication is made in connection with any public enquiry, legal proceedings or arbitration.
 - Where such publication is made in connection with any company prospectus or similar document.
 - Where the client has notice that TUV NEL Ltd is seeking or intends to seek patent or like protection for any intellectual property produced in the course of rendering the services.

TUV NEL Ltd
East Kilbride
GLASGOW G75 0QF
UK
Tel: +44 (0)1355 220222
Fax: +44 (0)1355 272999
www.tuvnel.com

Assessment of Error Due to Orifice Diameter Mis-Measurement at Blackrod

A Report for

**National Grid
Brick Kiln Street
HINCKLEY
Leicestershire
LE10 0NA**

Prepared by:

Dr M J Reader-Harris

Date: 1 June 2010

Approved by:

J M McNaught

Date: 1 June 2010

for M Valente
Managing Director

CONTENTS

	Page No
1 INTRODUCTION	3
2 ORIFICE DIAMETERS	3
3 CORRECTING THE FLOWRATE	5
4 CORRECTIONS ON A DAILY BASIS	7
5 CONCLUSIONS	7
APPENDIX A ORIFICE PLATE CALIBRATION CERTIFICATES	8
APPENDIX B CONFIGURATION DATA REPORTS	22
APPENDIX C CORRECTED DAILY VOLUME FLOWS	182

1 INTRODUCTION

Owing to a mis-measurement of orifice diameters flows have been mis-measured at affected offtakes connected to the National Transmission System. This project has been undertaken to resolve these errors. This report covers the flows through Blackrod in the period of the error. The Joint Office Error Codes are NW001 and NW002 for meter tubes MTA and MTB.

2 ORIFICE DIAMETERS

The calibrations of the orifice plates in question gave the measured diameters shown in Table 1. The diameters at 20 °C have been calculated. The effective bores include the effect of a drain hole to BS ISO/TR 15377:1998.


TABLE 1

ORIFICE DIAMETERS

Calibration Reference	Plate serial no	Declared certificate date	Measured values			Values at 20 °C	
			Orifice bore (mm)	Effective bore (mm)	Temperature	Orifice bore (mm)	Effective bore (mm)
3112	226	27/07/03	366.5015		21	366.4956	
3113	225	27/07/03	366.843		21	366.8371	
4124	225	05/08/04	366.8525	367.0033	21	366.8466	366.9975
4125	226	05/08/04	364.5075	364.6598	21	364.5017	364.654
4185	225-1	04/01/05	366.4775		21	366.4716	
50164	225-1	27/07/05	366.4845		21	366.4786	
50165	226-1	27/07/05	366.578		21	366.5721	
50199	226	29/06/06	366.499	366.6505	21	366.4931	366.6447
50200	225	10/07/06	366.846	366.9971	21	366.8401	366.9913
60147	226-1	07/12/06	366.25		21	366.2441	
60148	225-1	06/12/06	366.156		21	366.1501	
70077	225	16/07/07	366.524	366.6744	20	366.524	366.6744
70096	226	27/09/07	366.1955	366.3466	20	366.1955	366.3466
80017	225-2	14/05/08	366.488	366.6384	19	366.4939	366.6442
80075	225	31/10/08	366.8515	367.0034	20.2	366.8503	367.0023
80076	225-1	07/11/08	366.4895		20.3	366.4877	

Figure 1 shows the data from Table 1 for the orifice bores at 20°C (omitting 4125, which is outside the period under consideration and is an error for which a correction has previously been made). This figure shows that there is a reduction in measured diameter followed by a recovery. The deduction from this graph is that for a period of time in late 2006 and 2007 the plates were mis-measured.

The calibration certificates for the orifice plates are given as Appendix A. The Flow Computer configurations are given as Appendix B.

**Figure 1 Orifice Diameters at 20 °C**

The plates actually used in each of the two meter tubes MTA and MTB can be determined from Table 2 in conjunction with Table 1.

TABLE 2
PLATES USED IN EACH LINE AS CONFIGURED BY FLOW COMPUTER

MTA	Before 16/07/2007	16/07/2007	18/07/2007	15/07/2008	02/07/2009
Orifice plate bore diameter (mm)	366.846	366.156	366.156	366.3466	367.0034
Expansion coefficient of the plate (/ $^{\circ}$ C)	0.000016	0.000016	0.000016	0.000016	0.000016
Orifice plate calibration temperature	21	21	21	20	20.2
Meter tube diameter (mm)	730.1738	730.1738	730.1738	730.1738	730.1738
Expansion coefficient of the meter tube (/ $^{\circ}$ C)	0.000011	0.000011	0.000011	0.000011	0.000011
Meter tube calibration temperature	20	20	20	20	20
Isentropic Exponent	1.3256	1.3256	1.3257	1.328646	1.328626
Dynamic Viscosity (Pa.s)	0.0000118	0.0000118	0.0000119	0.0000117	0.0000117
Orifice plate certificate number	OP50200	OP60148	OP60148	OP70096	OP80075
Orifice plate serial number	225	225-1	225-1	226	225
Error in orifice diameter?	No	Yes	Yes	Yes	No
MTB					
Orifice plate bore diameter (mm)	366.499	366.499	366.6744	366.6384	366.4895
Expansion coefficient of the plate (/ $^{\circ}$ C)	0.000016	0.000016	0.000016	0.000016	0.000016
Orifice plate calibration temperature	21	21	20	19	20.3
Meter tube diameter (mm)	730.2849	730.2849	730.2849	730.2849	730.2849
Expansion coefficient of the meter tube (/ $^{\circ}$ C)	0.000011	0.000011	0.000011	0.000011	0.000011
Meter tube calibration temperature	20	20	20	20	20
Isentropic Exponent	1.3256	1.3256	1.3257	1.328646	1.328626
Dynamic Viscosity (Pa.s)	0.0000118	0.0000118	0.0000119	0.0000117	0.0000117
Orifice plate certificate number	OP50199	OP50199	OP70077	OP80017	OP80076
Orifice plate serial number	226	226	225	225-2	225-1
Error in orifice diameter?	No	No	Yes	No	No

On MTA before 16/07/2007 and on MTB both before 16/07/2007 and on 16/07/2007 the orifice diameters in the flow computer did not include the effect of the drain hole; however, the effect on the error due to mis-measurement of the orifice diameters (as distinct from failure to include the effect of the drain hole in the flow computer) is negligible (of the order of 0.00001%).

3 CORRECTING THE FLOWRATE

To correct the measured flowrate by replacing an incorrect diameter with the correct diameter might appear to be fairly straightforward. However, the data supplied only give time to the nearest minute and at four-minute intervals. This is inadequate for very accurate calculation. It is possible to calculate the flow over each time interval and to add the values over a day; this method can be used to check that the calculations are being done correctly, but the differences between the summed figures and the ones already given in the spreadsheet are too large to enable the correction to be calculated in this way. An alternative method has therefore been used.

The mass flowrate q_m is given by

$$q_m = \frac{\pi d^2 C \varepsilon \sqrt{2 \rho \Delta p}}{4\sqrt{1 - \beta^4}}$$

where d is the orifice diameter, C is the discharge coefficient, ε is the expansibility, ρ is the density, Δp is the differential pressure, and β is the diameter ratio.

If the corrected and original data are described with subscripts c and o , then the following correction factor is obtained:

$$\frac{q_{m,c}}{q_{m,o}} = \left(\frac{d_c}{d_o} \right)^2 \frac{C_c \varepsilon_c}{C_o \varepsilon_o} \sqrt{\frac{1 - \beta_o^4}{1 - \beta_c^4}}$$

The correct effective diameter is taken as the average of the measurements shown in Table 1 for that plate excluding the erroneous measurement. 3112, 3113 and 4125 are excluded because in the case of 3112 and 3113 the effective bore is different from later values since no drain hole is included and 4125, as stated earlier, is in error. It is then necessary to calculate C and ε in each case, and they were determined from the equations in ISO 5167-1:1991. A change of 0.2% in Reynolds number causes such a small change in C that iteration is not required. Neglecting iteration causes a change of less than 0.000001% in C . C is a function of β and Re_D ; so there is a change in C due to β , but the change varies with Reynolds number. A differential pressure of 10 mbar gives a pipe Reynolds number of around 3×10^6 in each tube; a differential pressure of 500 mbar gives a pipe Reynolds number of around 2×10^7 . Throughout the calculations the upstream pressure p_1 is taken as 53 bar a; the change in $q_{m,c}/q_{m,o}$ due to changing the static pressure by 10 bar is around 0.00001% at maximum.

Over the period from 16/07/2007 to 15/07/2008 the correction on MTA can be calculated as in Table 3. Throughout this calculation the meter tube diameter D is 730.1738 mm and the isentropic exponent κ is 1.3257.

TABLE 3**THE CORRECTION ON MTA FROM 16/07/2007 TO 15/07/2008**

	d mm	β	ε	$\left(\frac{d_c}{d_o}\right)^2 \frac{\varepsilon_c}{\varepsilon_o} \sqrt{\frac{1-\beta_o^4}{1-\beta_c^4}}$	Re_D	C	$\frac{q_{m,c}}{q_{m,o}}$
Original: $\Delta p=10$ mbar	366.1501	0.501456	0.999938		3.000×10^6	0.602777	
Corrected $\Delta p=10$ mbar	366.4793	0.501907	0.999938	1.00192075	3.006×10^6	0.602786	1.0019359
Original $\Delta p=500$ mbar	366.1501	0.501456	0.996925		2.000×10^7	0.602605	
Corrected $\Delta p=500$ mbar	366.4793	0.501907	0.996924	1.00192019	2.004×10^7	0.602614	1.0019351

So $q_{m,c}/q_{m,o}$ is 1.001936.

Over the period from 18/07/2007 to 15/07/2008 the correction on MTB can be calculated as in Table 4; throughout this calculation $D = 730.2849$ mm and $\kappa = 1.3257$.

TABLE 4**THE CORRECTION ON MTB FROM 18/07/2007 TO 15/07/2008**

	d mm	β	ε	$\left(\frac{d_c}{d_o}\right)^2 \frac{\varepsilon_c}{\varepsilon_o} \sqrt{\frac{1-\beta_o^4}{1-\beta_c^4}}$	Re_D	C	$\frac{q_{m,c}}{q_{m,o}}$
Original: $\Delta p=10$ mbar	366.6744	0.502098	0.999938		3.000×10^6	0.602790	
Corrected $\Delta p=10$ mbar	366.997	0.502539	0.999938	1.00188017	3.006×10^6	0.602799	1.0018950
Original $\Delta p=500$ mbar	366.6744	0.502098	0.996924		2.000×10^7	0.602618	
Corrected $\Delta p=500$ mbar	366.997	0.502539	0.996923	1.00187962	2.004×10^7	0.602626	1.0018942

So $q_{m,c}/q_{m,o}$ is 1.001895.

Over the period from 15/07/2008 to 02/07/2009 the correction on MTA can be calculated as in Table 5; throughout this calculation $D = 730.1738$ mm and $\kappa = 1.328646$.

TABLE 5**THE CORRECTION ON MTA FROM 15/07/2008 TO 02/07/2009**

	d mm	β	ε	$\left(\frac{d_c}{d_o}\right)^2 \frac{\varepsilon_c}{\varepsilon_o} \sqrt{\frac{1-\beta_o^4}{1-\beta_c^4}}$	Re_D	C	$\frac{q_{m,c}}{q_{m,o}}$
Original: $\Delta p=10$ mbar	366.3466	0.501725	0.999939		3.000×10^6	0.602782	
Corrected $\Delta p=10$ mbar	366.6447	0.502133	0.999939	1.00173851	3.005×10^6	0.602790	1.0017522
Original $\Delta p=500$ mbar	366.3466	0.501725	0.996931		2.000×10^7	0.602610	
Corrected $\Delta p=500$ mbar	366.6447	0.502133	0.996931	1.001738	2.003×10^7	0.602618	1.0017515

So $q_{m,c}/q_{m,o}$ is 1.001752.

4 CORRECTIONS ON A DAILY BASIS

Each (approximately four-minute) interval was considered and the flow (here and throughout this paragraph flow refers to standard volume flow) was calculated in each tube; the flowrate during the interval was taken as the average of that at the beginning and that at the end of the interval. The interval is only known to the nearest minute; so the flow in MTA during the interval was calculated by taking the product of the total flow (supplied by National Grid) during that interval and the ratio of the calculated flow in MTA to the sum of the calculated flows in the tubes. Intervals in which the calculated flow in both MTA and MTB is zero have been disregarded. Then on taking account of the effects at the beginning and end of each day the sum of the daily flow in MTA (obtained by summing the flows in each interval) and that in MTB (obtained the same way) should be equal to the total flow in that day. To ensure that the sum of the daily flows is exactly equal to the total daily flow the individual totals were scaled. Then the increase in daily flow was calculated for each of the two daily flows by using the percentage increase for each tube given above. Finally the total increase in the daily flow is the sum of the increases for the two tubes. The results are given in Table C.1 of Appendix C. The data for one day (20th October 2008, chosen because it has flows in both tubes but one of the tubes does not run throughout the day) have been supplied separately on a spreadsheet for checking purposes.

5 CONCLUSIONS

Correction factors should be applied as shown in Table 6.

TABLE 6
CORRECTION FACTORS

Meter tube	Date	Correction factor $q_{m,c}/q_{m,o}$
MTA	16/07/2007 to 15/07/2008	1.001936
MTB	18/07/2007 to 15/07/2008	1.001895
MTA	15/07/2008 to 02/07/2009	1.001752

These correction factors apply to both measured volume and measured energy.

On applying these corrections the corrected volumes are as shown in Appendix C.

APPENDIX A ORIFICE PLATE CALIBRATION CERTIFICATES

TRANSICO ORIFICE PLATE CALIBRATION

DATE: 05-08-04

REF NO: OP4124

TEMPERATURE: 21 degsC

MEASURED ORIFICE BORE: 366.8525mm

PLATE DETAILS

PLATE SERIAL.	225	PLATE O.D.	774.722mm	SITE:	BLACKROD
MANUFACTURER:		PIPE I.D.:	730.275mm	FLOW:	
MATERIAL CERT.No.		DESIGN BORE:	366.496mm	1.359 x 10E7 M^3/day	

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE - ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 3858 NEXT CAL DUE:- 17/10/04

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
------------	---	---	---	---	---	---	---	---

FLATNESS %	0.025	0.019	0.020	0.012	0.023	0.018	0.028	0.021
------------	-------	-------	-------	-------	-------	-------	-------	-------

'E' mm	12.470	12.527	12.552	12.546	12.504	12.457	12.452	12.455
--------	--------	--------	--------	--------	--------	--------	--------	--------

'e' mm	
--------	--

EDGE SHARPNESS mm	0.0125	0.0125	0.0125	0.0125	0.0125	0.0125	0.0125	0.0125
-------------------	--------	--------	--------	--------	--------	--------	--------	--------

CONCENTRICITY	0.110mm
---------------	---------

SURFACE FINISH (Ra)	5 microns
---------------------	-----------

DOWNTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS: 0.018mm TAPER: 0 degs

BEVEL ANGLE: DEGS

DRAIN HOLE BORE	10.030mm	CENTRE DISTANCE	479.886mm
-----------------	----------	-----------------	-----------

COMMENTS:

INSPECTED BY G. WARDLE

TRANSICO ORIFICE PLATE CALIBRATION**DATE:** 05-08-04**REF NO:** OP4125**TEMPERATURE:** 21 degsC**MEASURED ORIFICE BORE:** 364.5075mm**PLATE DETAILS**

PLATE SERIAL.	226	PLATE O.D.	774.787mm	SITE:	BLACKROD
MANUFACTURER:		PIPE I.D.:	730.326mm	FLOW:	
MATERIAL CERT.NO.		DESIGN BORE:	366.572mm		

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 3858 NEXT CAL DUE:- 17/10/04

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.124	0.048	0.136	0.151	0.102	0.110	0.165	0.118
'E' mm	12.664	12.671	12.654	12.636	12.659	12.661	12.645	12.641
'e' mm								
EDGE SHARPNESS mm	0.025	0.025	0.025	0.025	0.025	0.025	0.025	0.025
CONECTRICITY	0.068mm							
SURFACE FINISH (Ra)	2.5 microns							

DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS: 0.015mm TAPER: .73 degs

BEVEL ANGLE: DEGS

DRAIN HOLE BORE 10.047mm CENTRE DISTANCE 512.789mm

COMMENTS:

INSPECTED BY G.WARDLE

TRANSCO ORIFICE PLATE CALIBRATION

DATE: 4-01-05
REF NO: OP4185
TEMPERATURE: 21 degsC
MEASURED ORIFICE BORE: 366.4775mm

PLATE DETAILS

PLATE SERIAL.	225-1	PLATE O.D.	774.749mm
MANUFACTURER:		PIPE I.D.:	730.275mm
MATERIAL CERT.NO.		DESIGN BORE:	366.496mm
			FLOW:

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 15/10/05

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.165	0.150	0.159	0.167	0.189	0.174	0.191	0.158
'E' mm	12.797	12.819	12.824	12.798	12.802	12.760	12.761	12.770
'e' mm								
EDGE SHARPNESS mm	0.025	0.025	0.025	0.025	0.025	0.025	0.025	0.025
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.070mm							
SURFACE FINISH (Ra)	2 microns							
DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS								
ROUNDNESS :	0.016mm	TAPER:	0 degs					

COMMENTS:


INSPECTED BY..... G.WARDLE
VERIFIED BY..... P.KENNERSON

TRANSCO ORIFICE PLATE CALIBRATION

DATE: 27-07-05
REF NO: OP50164
TEMPERATURE: 21 degsC
MEASURED ORIFICE BORE: 366.4845mm

=====

PLATE DETAILS

PLATE SERIAL.	225-1	PLATE O.D	774.759mm
MANUFACTURER:		PIPE I.D:	730.326mm
MATERIAL CERT.NO.		DESIGN BORE:	366.572mm
			FLOW:

=====

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE - ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 15/10/05

=====

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.169	0.167	0.163	0.171	0.167	0.155	0.169	0.166
'E' mm	12.784	12.805	12.819	12.799	12.790	12.783	12.756	12.757
'e' mm								
EDGE SHARPNESS mm	0.025	0.025	0.025	0.025	0.025	0.025	0.025	0.025
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.079mm							
SURFACE FINISH (Ra)	0.4 microns							

DOWNTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS : 0.011mm TAPER: 0 degs

COMMENTS:

INSPECTED BY..... *G.WARDLE* G.WARDLE

VERIFIED BY..... *P.KENNERSON* P.KENNERSON

TRANSKO ORIFICE PLATE CALIBRATION

DATE: 27-07-05
REF NO: OP50165
TEMPERATURE: 21 degsC
MEASURED ORIFICE BORE: 366.578mm

PLATE DETAILS

PLATE SERIAL.	226-1	PLATE O.D.	774.831mm
MANUFACTURER:		PIPE I.D.	730.275mm
MATERIAL CERT.NO.		DESIGN BORE:	366.496mm
			FLOW:


TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE - ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 15/10/05

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.167	0.172	0.160	0.148	0.150	0.159	0.187	0.160
'E' mm	12.774	12.784	12.795	12.798	12.789	12.792	12.772	12.755
'e' mm								
EDGE SHARPNESS mm	0.025	0.0375	0.0375	0.0375	0.025	0.05	0.025	0.025
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.095mm							
SURFACE FINISH (Ra)	1.4 microns							
DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS								
ROUNDNESS :	0.006mm	TAPER:	0 degs					

COMMENTS:

INSPECTED BY.....  G. WARDLEVERIFIED BY.....  P. KENNERTSON

NATIONAL GRID ORIFICE PLATE CALIBRATION

DATE: 29-06-06
REF NO: OP50199
TEMPERATURE: 21 degsC
MEASURED ORIFICE BORE: 366.499mm

PLATE DETAILS

PLATE SERIAL.	226	PLATE O.D.	774.764mm
MANUFACTURER:		PIPE I.D.	730.326mm
MATERIAL CERT.NO.		DESIGN BORE:	366.572mm
			FLOW:

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 14/10/06

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)


STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.107	0.035	0.121	0.129	0.111	0.069	0.140	0.091
'E' mm	12.671	12.685	12.660	12.643	12.649	12.663	12.648	12.653
'e' mm								
EDGE SHARPNESS mm	0.0125	0.0125	0.025	0.0125	0.0125	0.025	0.0125	0.0125
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.053mm							
SURFACE FINISH (Ra)	1.5 microns							

DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS : 0.013mm TAPER: 0 degs

DRAIN HOLE BORE 10.049mm CENTRE DISTANCE 506.492mm

COMMENTS :

INSPECTED BY...  P.KENNERISON 

NATIONAL GRID ORIFICE PLATE CALIBRATION

DATE: 10-07-06

REF NO: OP50200

TEMPERATURE: 21 degsC

MEASURED ORIFICE BORE: 366.846mm

PLATE DETAILS

PLATE SERIAL.	225	PLATE O.D	774.725mm
MANUFACTURER:		PIPE I.D:	730.275mm
MATERIAL CERT.NO.		DESIGN BORE:	366.496mm
			FLOW:

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 14/10/06

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.013	0.018	0.017	0.012	0.023	0.019	0.019	0.017
'E' mm	12.479	12.511	12.545	12.552	12.521	12.475	12.457	12.455
'e' mm								
EDGE SHARPNESS mm	0.0125	0.0125	0.0125	0.0125	0.0125	0.0125	0.0125	0.0125
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.092mm							
SURFACE FINISH (Ra)	4.6 microns							

DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS : 0.006mm TAPER: 0 degs

DRAIN HOLE BORE 10.040mm CENTRE DISTANCE 510.360mm

COMMENTS:

INSPECTED BY.....  P. KENNISON /S. CHAUVIN.

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:** 07-12-06**REF NO:** OP60147**TEMPERATURE:** 21 degsC**MEASURED ORIFICE BORE:** 366.25mm**PLATE DETAILS**

PLATE SERIAL.	226-1	PLATE O.D.	774.160mm
MANUFACTURER:		PIPE I.D.	730.275mm
MATERIAL CERT.NO.		DESIGN BORE:	366.496mm
			FLOW:

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 13/10/07

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.158	0.171	0.148	0.139	0.135	0.151	0.176	0.143
'E' mm	12.847	12.863	12.792	12.796	12.835	12.835	12.781	12.759
'e' mm								
EDGE SHARPNESS mm	0.025	0.0375	0.025	0.025	0.0125	0.0375	0.025	0.025
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.156mm							
SURFACE FINISH (Ra)	1.9 microns							

DOWNTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS : 0.368mm TAPER: 0 degs

COMMENTS:

INSPECTED BY  P. KENNERTON

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:** 06-12-06**REF NO:** OP60148**TEMPERATURE:** 21 degsC**MEASURED ORIFICE BORE:** 366.156mm**PLATE DETAILS**

PLATE SERIAL.	225-1	PLATE O.D	774.126mm	SITE:	BLACKROD
MANUFACTURER:		PIPE I.D:	730.326mm	FLOW:	
MATERIAL CERT.NO.		DESIGN BORE:	366.522mm		

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 13/10/07

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.169	0.167	0.172	0.159	0.162	0.162	0.151	0.162
'E' mm	12.871	12.889	12.786	12.785	12.830	12.811	12.740	12.744
'e' mm								
EDGE SHARPNESS mm	0.025	0.025	0.025	0.025	0.0375	0.025	0.025	0.025
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.042mm							
SURFACE FINISH (Ra)	1.1 microns							
DOWNSTREAM FACE/EDGE VISUAL INSPECTION :-	PASS							
ROUNDNESS :	0.363mm	TAPER:	0 degs					

COMMENTS:

INSPECTED BY..... P. KENNISON

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:** 16-JULY-2007**REF NO:** OP70077**TEMPERATURE:** 20 degsC**MEASURED ORIFICE BORE:** 366.524mm**PLATE DETAILS**

PLATE SERIAL.	225	PLATE O.D	773.880mm
MANUFACTURER:	HEECO	PIPE I.D:	730.2849mm
MATERIAL CERT.NO.		DESIGN BORE:	366.496mmmm
			FLOW:

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 13/10/07

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.023	0.020	0.018	0.009	0.019	0.034	0.015	0.031
'E' mm	12.562	12.591	12.545	12.509	12.531	12.502	12.432	12.444
'e' mm								
EDGE SHARPNESS mm	0.0125	SQUARE	0.025	SQUARE	SQUARE	0.0125	0.0125	0.0125
BEVEL ANGLE:		DEGS						
CONCENTRICITY	0.063mm							
SURFACE FINISH (Ra)	3.6 microns							

DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS : 0.323mm TAPER: 0 degs

DRAIN HOLE BORE 10.012mm CENTRE DISTANCE 394.487mm

COMMENTS:

INSPECTED BY  M. Livingstone

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:****27-SEPT-2007****REF NO:****OP70096****TEMPERATURE:****20 degsC****MEASURED ORIFICE BORE:** **366.1955mm****PLATE DETAILS**

PLATE SERIAL.	226	PLATE O.D.	774.187mm
MANUFACTURER:		PIPE I.D:	mm
MATERIAL CERT.No.		DESIGN BORE:	mm
			FLOW:

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 4820 NEXT CAL DUE:- 13/10/07

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.119	0.068	0.124	0.122	0.096	0.077	0.160	0.101
'E' mm	12.701	12.726	12.643	12.636	12.701	12.706	12.638	12.639
'e' mm								
EDGE SHARPNESS mm	SQUARE	0.025	0.025	0.0125	SQUARE	0.025	SQUARE	SQUARE
BEVEL ANGLE:		DEGS						
CONCENTRICITY		0.192mm						
SURFACE FINISH (Ra)		0.5 microns						
DOWNSTREAM FACE/EDGE VISUAL INSPECTION :-	PASS							
ROUNDNESS :	0.313mm	TAPER:	0 degs					

DRAIN HOLE BORE 10.030mm CENTRE DISTANCE 499.142mm

COMMENTS:

INSPECTED BY..... M LIVINGSTONE

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:** 14-MAY-2008**REF NO:** OP80017**TEMPERATURE:** 19 degsC**MEASURED ORIFICE BORE:** 366.488mm**PLATE DETAILS**

PLATE SERIAL.	225-2	PLATE O.D	774.931mm	SITE:	BLACKROD
MANUFACTURER:	ANT	PIPE I.D:	730.1738mm	FLOW:	M ³ /DAY
MATERIAL CERT.NO.	ANT21286	DESIGN BORE:	mm		

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, CERT:- 6292 NEXT CAL DUE:- 05-OCTOBER-2008

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.081	0.135	0.035	0.055	0.055	0.108	0.055	0.041
'E' mm	12.573	12.552	12.587	12.577	12.550	12.576	12.568	12.571
'e' mm								
EDGE SHARPNESS mm	0.0375	0.0375	0.0375	0.0375	0.0375	0.0375	0.0375	0.0375
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.024mm							
SURFACE FINISH (Ra)	1 microns							
DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS								
ROUNDNESS :	0.006mm	TAPER:	0 degs					

DRAIN HOLE BORE 10.010mm CENTRE DISTANCE 439.594mm

COMMENTS:

INSPECTED BY M Livingstone.

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:** 31-OCT-2008**REF NO:** OP80075**TEMPERATURE:** 20.2 degsC**MEASURED ORIFICE BORE:** 366.8515mm**PLATE DETAILS**

PLATE SERIAL.	225	PLATE O.D.	774.739mm	SITE:	BLACKROD
MANUFACTURER:		PIPE I.D:	730.1738mm	FLOW:	
MATERIAL CERT.No.		DESIGN BORE:	366.496mm		

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, UKAS CERT:- 6822. NEXT CAL DUE:- 03-OCTOBER-2009


UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.015	0.007	0.015	0.002	0.017	0.015	0.012	0.009
'E' mm	12.455	12.475	12.547	12.556	12.509	12.463	12.455	12.456
'e' mm								
EDGE SHARPNESS mm	0.0125	0.0125	0.0125	0.025	0.0125	0.0125	0.0125	0.0125
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.084mm							
SURFACE FINISH (Ra)	4.5 microns							
DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS								
ROUNDNESS :	0.008mm	TAPER:	0 degs					

DRAIN HOLE BORE 10.067mm CENTRE DISTANCE 510.627mm

DRAINHOLE PRESENT ? (YES/NO): Yes

COMMENTS: SOME GREASE TO UPSTREAM FACE RIM

INSPECTED BY  M Livingstone.

NATIONAL GRID ORIFICE PLATE CALIBRATION**DATE:****7-NOV-2008****REF NO:****OP80076****TEMPERATURE:****20.3 degsC****MEASURED ORIFICE BORE:****366.4895mm****PLATE DETAILS**

PLATE SERIAL.	225-1	PLATE O.D	774.741mm	SITE:	BLACKROD
MANUFACTURER:		PIPE I.D:	730.1738mm	FLOW:	M ³ /DAY
MATERIAL CERT.NO.		DESIGN BORE:	366.522mm		

TEST EQUIPMENT

MANUFACTURER & TYPE: KEMCO 700 MANUAL 3-DIMENSIONAL MEASURING MACHINE -ASSET NO OP-A02
CALIBRATED BY: QUALITY CONTROL TECHNOLOGY, UKAS CERT:- 6822. NEXT CAL DUE:- 03-OCTOBER-2009

UPSTREAM FACE INSPECTION RESULTS (ISO 5167)

STATIONS:-	1	2	3	4	5	6	7	8
FLATNESS %	0.165	0.165	0.162	0.153	0.163	0.168	0.150	0.147
'E' mm	12.807	12.813	12.805	12.787	12.789	12.772	12.761	12.772
'e' mm								
EDGE SHARPNESS mm	0.025	0.025	0.0125	0.025	0.025	0.025	0.025	0.025
BEVEL ANGLE:	DEGS							
CONCENTRICITY	0.095mm							
SURFACE FINISH (Ra)	1.0 microns							

DOWNSTREAM FACE/EDGE VISUAL INSPECTION :- PASS

ROUNDNESS : 0.008mm TAPER: 0 degs

DRAINHOLE PRESENT ? (YES/NO): No

COMMENTS :

INSPECTED BY..... M Livingstone.

APPENDIX B CONFIGURATION DATA REPORTS**TABLE B.1 CONFIGURATION DATA REPORT 25/07/2006**

```
=====
CONFIGURATION DATA REPORT : [ BLAL0725.OMI ]

COMPANY NAME : TRANSCO part of Lattice Group plc
LOCATION : Sunny Blackrod
COMPUTER ID : 62823

CURRENT DATE : 3-31-2010 TIME : 11:50a
CONFIGURATION FILE : LAST MODIFIED
=====

----- CHECK I/O MODULE CONFIG
OMNI Flow Computer Model Number..... OMNI 6000
Number of TYPE A Modules Installed..... 3
Number of TYPE B Modules Installed..... 0
Number of TYPE C Modules Installed..... 0
Number of TYPE E Modules Installed..... 0
Number of TYPE E/D Modules Installed..... 0
Number of TYPE H Modules Installed..... 0
Number of DIGITAL Modules Installed..... 1
Number of SERIAL Modules Installed..... 2

----- FLOW COMPUTER TIME & DATE
OMNI Time..... 12:07:12
OMNI Date..... 25/07/06
Select Date Type..... dd/mm/yy

----- CONFIG STATION DATA
Station Totals and Flows Defined As:..... 1+2
Reference Gravity.I/O Pnt#..... 0
    Tag.....  
Type..... 4-20 mA
Nitrogen % I/O Pnt#..... 0
    Tag.....  
Type..... 4-20 mA
Carbon Dioxide I/O Pnt#..... 0
    Tag.....  
Type..... 4-20 mA
Heating Value I/O Pnt#..... 0
    Tag.....  
Type..... 4-20 mA
Auxiliary Input #1 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #2 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #3 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #4 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd

----- CONFIG METER RUNS
Meter #1 Select Turbine Y/N..... NO
    DP Low Range I/O Pnt#..... 3
    Tag..... DPLR-1
```

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 02
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 4
Tag..... DPHR-1
Temp I/O Pnt#..... 1
Tag..... FT-1
Type..... DIN Rtd
Pres I/O Pnt#..... 2
Tag..... FP-1
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #2 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 7
Tag..... DPRL-2
DP High Range I/O Pnt#..... 8
Tag..... DPHR-2
Temp I/O Pnt#..... 5
Tag..... FT-2
Type..... DIN Rtd
Pres I/O Pnt#..... 6
Tag..... FP-2
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #3 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 11
Tag..... DPST-1
DP High Range I/O Pnt#..... 12
Tag..... DPST-2
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #4 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 0
Tag.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 03
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 0
Tag.....
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....

----- CONFIG PID LOOPS
Loop #1 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #2 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #3 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #4 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 04
=====

----- CONFIG PID LOOPS (Cont'd)
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....

----- CONFIG D/A OUT
D/A Output #01 Assign..... 7802
Remarks..... Station scm/hr
@ 4 ma..... 0
@ 20 ma..... 1109405
D/A Output #02 Assign..... 7044
Remarks..... Odorant scm/hr
@ 4 ma..... 0
@ 20 ma..... 1109405
D/A Output #03 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0
D/A Output #04 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0
D/A Output #05 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0
D/A Output #06 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0

----- CONFIG FRONT PANEL COUNTERS
Front Panel Counter A Assign..... 1802
Remark..... Stream 1 st vol
Pulses/Unit..... .001
Front Panel Counter B Assign..... 1804
Remark..... Stream 1 ene flo
Pulses/Unit..... .01
Front Panel Counter C Assign..... 0
Remark.....
Pulses/Unit..... 0

----- CONFIGURE BOOLEAN STATEMENTS
Boolean #1025 =..... 1811
Remarks..... Hi flow alrm
Boolean #1026 =..... /1829+1837
Remarks..... Power/EPROM fail
Boolean #1027 =..... 7054+7055
Remarks..... RD alarm
Boolean #1028 =..... 1125+1126
Remarks..... 1. L/H T alrm

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 05
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1029 =..... 1129+1130
 Remarks..... 1. L/H P alrm
Boolean #1030 =..... 1141+1142
 Remarks..... 1. L/H DP alarm
Boolean #1031 =..... 1341+1342
 Remarks..... 1. L/H STBY alrm
Boolean #1032 =..... 7035&1152
 Remarks..... 1. LDP OutOfTol
Boolean #1033 =..... 7036&1153
 Remarks..... 1. HDP OutOfTol
Boolean #1034 =..... 7048+7049
 Remarks..... 1. Density alrm
Boolean #1035 =.....
 Remarks.....
Boolean #1036 =..... 1225+1226
 Remarks..... 2. L/H T alrm
Boolean #1037 =..... 1229+1230
 Remarks..... 2. L/H P alrm
Boolean #1038 =..... 1241+1242
 Remarks..... 2. L/H DP alrm
Boolean #1039 =..... 1341+1342
 Remarks..... 2. L/H STDP alrm
Boolean #1040 =..... 7041&1252
 Remarks..... 2. LDP OutOfTol
Boolean #1041 =..... 7042&1253
 Remarks..... 2. HDP OutOfTol
Boolean #1042 =..... 7051+7052
 Remarks..... 2. Density
Boolean #1043 =.....
 Remarks.....
Boolean #1044 =..... 1025+1026+1027
 Remarks..... General
Boolean #1045 =..... 1028+1029+1030
 Remarks..... 1.
Boolean #1046 =..... 1031+1032+1033
 Remarks..... 1.
Boolean #1047 =..... 1034
 Remarks..... 1.
Boolean #1048 =..... 1036+1037+1038
 Remarks..... 2.
Boolean #1049 =..... 1039+1040+1041
 Remarks..... 2.
Boolean #1050 =..... 1042
 Remarks..... 2.
Boolean #1051 =..... 1045+1046+1047
 Remarks..... 1. Combined
Boolean #1052 =..... 1048+1049+1050
 Remarks..... 2. Combined
Boolean #1053 =..... 1051&1105
 Remarks..... 1. in use?
Boolean #1054 =..... 1052&1205
 Remarks..... 2. in use?
Boolean #1055 =..... 1044+1053+1054
 Remarks..... Meter Suspect

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 06
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)

Boolean #1056 =.....	Remarks.....
Boolean #1057 =.....	1088=1070 Remarks..... Maintenance
Boolean #1058 =.....	1087=1055 Remarks..... Meter Suspect
Boolean #1059 =.....	1086=1027 Remarks..... RD error
Boolean #1060 =.....	1085=1034 Remarks..... 1. Density error
Boolean #1061 =.....	1084=1032 Remarks..... 1. Low DP error
Boolean #1062 =.....	1083=1033 Remarks..... 1. High DP error
Boolean #1063 =.....	1082=1042 Remarks..... 2. Density error
Boolean #1064 =.....	1081=1040 Remarks..... 2. Low DP error
Boolean #1065 =.....	1080=1041 Remarks..... 2. High DP error
Boolean #1066 =.....	Remarks.....
Boolean #1067 =.....	Remarks.....
Boolean #1068 =.....	Remarks.....
Boolean #1069 =.....	/1105&/1205 Remarks..... No flow if = 1
Boolean #1070 =.....	7025 Remarks..... Maintenance mode
Boolean #1071 =.....	1027 Remarks..... Spare
Boolean #1072 =.....	/1055 Remarks..... Invert met susp
Boolean #1073 =.....	1736=/1105 Remarks..... 1. Disable flow
Boolean #1074 =.....	1737=/1205 Remarks..... 2. Disable flow
Boolean #1075 =.....	Remarks..... Den #3 alarm
Boolean #1076 =.....	Remarks..... Den #4 alarm
Boolean #1077 =.....	Remarks.....
Boolean #1078 =.....	Remarks.....
Boolean #1079 =.....	Remarks.....
Boolean #1080 =.....	M2 HDP OutOfTol Remarks.....
Boolean #1081 =.....	M2 LDP OutOfTol Remarks.....
Boolean #1082 =.....	M2 Den OutOfTol Remarks.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 07
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1083 =..... M1 HDP OutOfTol
Remarks.....
Boolean #1084 =..... M1 LDP OutOfTol
Remarks.....
Boolean #1085 =..... M1 Den OutOfTol
Remarks.....
Boolean #1086 =..... RD OutOfTol
Remarks.....
Boolean #1087 =..... Meter Suspect
Remarks.....
Boolean #1088 =..... Maintenance
Remarks.....

----- CONFIGURE VARIABLE STATEMENTS
Statement #7025 =..... Main:-1=Off,1=On
Remarks.....
Statement #7026 =..... LGT Fix Output %
Remarks.....
Statement #7027 =..... LGT lo flo inj %
Remarks.....
Statement #7028 =..... #5.0
Remarks..... Enter DP tol
Statement #7029 =..... #5.0-7028
Remarks..... DP tol >5.0?
Statement #7030 =..... 7029)7028=#5.0
Remarks..... Set min DPtol
Statement #7031 =..... 8596+8795
Remarks..... 1.Sum hi cells
Statement #7032 =..... 7031/#2
Remarks..... 1.Average hi
Statement #7033 =..... 7032-8595
Remarks..... 1.Diff av H + L
Statement #7034 =..... 8596-8795
Remarks..... 1.Diff H + STBY
Statement #7035 =..... \$7033-7028
Remarks..... 1.LDP OutOfTol
Statement #7036 =..... \$7034-7028
Remarks..... 1.HDP OutOfTol
Statement #7037 =..... 8696+8796
Remarks..... 2.Sum hi cells
Statement #7038 =..... 7037/#2
Remarks..... 2.Average hi
Statement #7039 =..... 7038-8695
Remarks..... 2.Diff av H + L
Statement #7040 =..... 8696-8796
Remarks..... 2.Diff H + STBY
Statement #7041 =..... \$7039-7028
Remarks..... 2.LDP OutOfTol
Statement #7042 =..... \$7040-7028
Remarks..... 2.HDP OutOfTol
Statement #7043 =.....
Remarks.....
Statement #7044 =..... 7802

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 08
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Set odour flow
Statement #7045 =..... 1069)7044=7085
Remarks..... LGT-low flow
Statement #7046 =..... 1055)7044=7086
Remarks..... LGT-Met Susp
Statement #7047 =..... 7025)7044=7087
Remarks..... LGT-fix flow
Statement #7048 =..... 7107-#80
Remarks..... 1. Hi den?
Statement #7049 =..... #24-7107
Remarks..... 1. Low den?
Statement #7050 =.....
Remarks.....
Statement #7051 =..... 7207-#80
Remarks..... 2. Hi den?
Statement #7052 =..... #24-7207
Remarks..... 2. Low den?
Statement #7053 =.....
Remarks.....
Statement #7054 =..... 7141-#0.7
Remarks..... RD hi?
Statement #7055 =..... #0.5-7141
Remarks..... RD low?
Statement #7056 =.....
Remarks.....
Statement #7057 =.....
Remarks.....
Statement #7058 =..... 7854=7138*17002
Remarks..... St mass fl limit
Statement #7059 =..... 7854=7854/#1000
Remarks..... Convert to ton/h
Statement #7060 =..... 7162=7854/#2
Remarks..... 1. Mass flow lim
Statement #7061 =..... 7262=7854/#2
Remarks..... 2. Mass flow lim
Statement #7062 =..... 7151=#.0009*7158
Remarks..... 1. Set DP cutoff
Statement #7063 =..... 7251=#.0009*7258
Remarks..... 2. Set DP cutoff
Statement #7064 =.....
Remarks.....
Statement #7065 =.....
Remarks.....
Statement #7066 =.....
Remarks.....
Statement #7067 =..... 7802*#0.000024
Remarks..... St vol MSCM/D
Statement #7068 =..... 7804*#0.024
Remarks..... St. energy MMJ/D
Statement #7069 =..... 7802/17002*#100
Remarks..... %Max flow
Statement #7070 =..... 17002*#0.000024
Remarks..... Max vol MSCM/D
Statement #7071 =..... 7070*#44

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 09
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Max energy MMJ/D
Statement #7072 =..... 7068/7071*#100
Remarks..... %Energy for tele
Statement #7073 =..... 7044/17004*#100
Remarks..... %Odour
Statement #7074 =.....
Remarks.....
Statement #7075 =.....
Remarks.....
Statement #7076 =..... 17049=17025
Remarks..... Set counter A
Statement #7077 =..... 17050=#10*17049
Remarks..... Set counter B
Statement #7078 =..... 7152=7158/#-200
Remarks..... 1. DP low limit
Statement #7079 =..... 7153=7158+\$7152
Remarks..... 1. DP hi limit
Statement #7080 =..... 7252=7258/#-200
Remarks..... 2. DP low limit
Statement #7081 =..... 7253=7258+\$7252
Remarks..... 2. DP hi limit
Statement #7082 =..... 7352=7358/#-200
Remarks..... 3. DP low limit
Statement #7083 =..... 7353=7358+\$7352
Remarks..... 3. DP hi limit
Statement #7084 =.....
Remarks.....
Statement #7085 =..... 7027/#100*17004
Remarks..... LGT low flow inj
Statement #7086 =..... /1055)7086=7044
Remarks..... Store LGT output
Statement #7087 =..... 7026/#100*17004
Remarks..... LGT fix flow
Statement #7088 =.....
Remarks.....

----- CONFIG USER DISPLAYS
User Display Number 1 Key Press..... F
1st Variable Tag..... MSCM/D
Point #..... 7067
Dec. Places..... 6
2nd Variable Tag..... MMJ/D
Point #..... 7068
Dec. Places..... 6
3rd Variable Tag..... %Max flw
Point #..... 7069
Dec. Places..... 2
4th Variable Tag..... %Odour
Point #..... 7073
Dec. Places..... 2
User Display Number 2 Key Press..... IO
1st Variable Tag..... RD
Point #..... 7141

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 10
=====

----- CONFIG USER DISPLAYS
(Cont'd)
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7138
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7107
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7142
Dec. Places..... 7
User Display Number 3 Key Press..... IP
1st Variable Tag..... RD
Point #..... 7241
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7238
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7207
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7242
Dec. Places..... 7
User Display Number 4 Key Press..... VER
1st Variable Tag..... 02_71_V2
Point #..... 0
Dec. Places..... 0
2nd Variable Tag..... LGTcutoff
Point #..... 7027
Dec. Places..... 2
3rd Variable Tag..... 25/08/98
Point #..... 0
Dec. Places..... 0
4th Variable Tag..... 0
Dec. Places..... 0
User Display Number 5 Key Press..... FO
1st Variable Tag..... acmh
Point #..... 7101
Dec. Places..... 3
2nd Variable Tag..... scmh
Point #..... 7102
Dec. Places..... 3
3rd Variable Tag..... tons/hr
Point #..... 7103
Dec. Places..... 7
4th Variable Tag..... GJ/hr
Point #..... 7104
Dec. Places..... 3
User Display Number 6 Key Press..... FP
1st Variable Tag..... acmh
Point #..... 7201
Dec. Places..... 3
2nd Variable Tag..... scmh

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 11
=====

----- CONFIG USER DISPLAYS (Cont'd)

	Point #.....	7202
	Dec. Places.....	3
3rd Variable	Tag.....	tons/hr
	Point #.....	7203
	Dec. Places.....	7
4th Variable	Tag.....	GJ/hr
	Point #.....	7204
	Dec. Places.....	3
User Display Number 7	Key Press.....	DPO
1st Variable	Tag.....	Low DP
	Point #.....	8595
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8596
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8795
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7032
	Dec. Places.....	4
User Display Number 8	Key Press.....	DPP
1st Variable	Tag.....	Low DP
	Point #.....	8695
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8696
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8796
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7038
	Dec. Places.....	4

----- CONFIG DIGITAL I/O

Digital Point #1	Assign.....	1802
	Remarks.....	Integ St Vol.
	Pulse Width.....	20
	Pulses/Unit.....	.001
Digital Point #2	Assign.....	1072
	Remarks.....	Meter Suspect
	Delay On.....	10
	Delay Off.....	10
Digital Point #3	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #4	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #5	Assign.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 12
=====

----- CONFIG DIGITAL I/O (Cont'd)

	Remarks.....
Digital Point #6	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #7	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #8	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #9	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #10	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #11	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #12	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0

----- CONFIG SERIAL I/O

Serial I/O #1	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Port Type.....	Printer
Serial I/O #2	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Protocol Type.....	Modbus RTU(Modem)
	Modbus ID.....	1
	Modicon Compatible.....	NO
	CRC Enabled.....	YES
Serial I/O #3	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 13
=====

----- CONFIG SERIAL I/O (Cont'd)

Protocol Type.....	Modbus ASCII
Modbus ID.....	1
Modicon Compatible.....	YES
CRC Enabled.....	YES
Serial I/O #4 Baud Rate.....	9600
Stop Bits.....	1 Bit
Data Bits.....	8
Parity.....	None
Xmit Key Delay.....	0ms
Protocol Type.....	Modbus RTU
Modbus ID.....	0
Modicon Compatible.....	YES
CRC Enabled.....	YES

----- MODBUS PEER/PEER COMMUNICATIONS

Activate Redundancy Mode.....	NO
Next Master in Sequence.....	0
Last Master in Sequence.....	0
Retry Timer (50 mS Ticks).....	0
Transaction #1 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #2 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #3 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #4 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #5 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #6 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #7 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 14
=====

----- MODBUS PEER/PEER COMMUNICATIONS (Cont'd)

Dest. Point #.....	0
Transaction #8 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #9 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #10 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #11 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #12 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #13 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #14 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #15 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #16 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0

----- CUSTOM MODBUS PACKET(ADDR:001)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 15
=====

----- CUSTOM MODBUS PACKET(ADDR:001) (Cont'd)

Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0
Packet #09	Pnt.#.....	0
	# of Points.....	0
Packet #10	Pnt.#.....	0
	# of Points.....	0
Packet #11	Pnt.#.....	0
	# of Points.....	0
Packet #12	Pnt.#.....	0
	# of Points.....	0
Packet #13	Pnt.#.....	0
	# of Points.....	0
Packet #14	Pnt.#.....	0
	# of Points.....	0
Packet #15	Pnt.#.....	0
	# of Points.....	0
Packet #16	Pnt.#.....	0
	# of Points.....	0
Packet #17	Pnt.#.....	0
	# of Points.....	0
Packet #18	Pnt.#.....	0
	# of Points.....	0
Packet #19	Pnt.#.....	0
	# of Points.....	0
Packet #20	Pnt.#.....	0
	# of Points.....	0

----- CUSTOM MODBUS PACKET(ADDR:201)

Packet #01	Pnt.#.....	0
	# of Points.....	0
Packet #02	Pnt.#.....	0
	# of Points.....	0
Packet #03	Pnt.#.....	0
	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 16
=====

----- CUSTOM MODBUS PACKET(ADDR:401)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Packet #17 Pnt.#.....	0
# of Points.....	0
Packet #18 Pnt.#.....	0
# of Points.....	0
Packet #19 Pnt.#.....	0
# of Points.....	0
Packet #20 Pnt.#.....	0
# of Points.....	0

----- ARCHIVE 701 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 17
=====

----- ARCHIVE 701 - RECORD DEFINITION (Cont'd)

Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 702 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 18
=====

----- ARCHIVE 702 - RECORD DEFINITION (Cont'd)
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 703 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 704 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 19
=====

----- ARCHIVE 704 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 705 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 20
=====

----- ARCHIVE 705 - RECORD DEFINITION (Cont'd)

Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 706 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 707 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 21
=====

----- ARCHIVE 707 - RECORD DEFINITION (Cont'd)

Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 708 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 22
=====

----- ARCHIVE 708 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 709 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 23
=====

----- ARCHIVE 710 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- CONFIG AB PLC BLOCK#1 READ

Start Address of Data Block #1.....	9
Item #1 Source Point #.....	8
# of Points.....	10
Item #2 Source Point #.....	11
# of Points.....	2
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	3
Item #6 Source Point #.....	4
# of Points.....	6
Item #7 Source Point #.....	7
# of Points.....	1
Item #8 Source Point #.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 24
=====

----- CONFIG AB PLC BLOCK#1 READ
of Points..... 0
Item #9 Source Point #..... 0
of Points..... 0
Item #10 Source Point #..... 0
of Points..... 0
Item #11 Source Point #..... 17
of Points..... 18
Item #12 Source Point #..... 0
of Points..... 0
Item #13 Source Point #..... 0
of Points..... 0
Item #14 Source Point #..... 0
of Points..... 0
Item #15 Source Point #..... 0
of Points..... 0
Item #16 Source Point #..... 0
of Points..... 0

(Cont'd)

----- CONFIG AB PLC BLOCK#2 READ
Start Address of Data Block #2..... 0
Item #1 Source Point #..... 0
of Points..... 0
Item #2 Source Point #..... 0
of Points..... 0
Item #3 Source Point #..... 0
of Points..... 0
Item #4 Source Point #..... 0
of Points..... 0
Item #5 Source Point #..... 0
of Points..... 0
Item #6 Source Point #..... 0
of Points..... 0
Item #7 Source Point #..... 0
of Points..... 0
Item #8 Source Point #..... 0
of Points..... 0
Item #9 Source Point #..... 0
of Points..... 0
Item #10 Source Point #..... 0
of Points..... 0
Item #11 Source Point #..... 0
of Points..... 0
Item #12 Source Point #..... 0
of Points..... 0
Item #13 Source Point #..... 0
of Points..... 0
Item #14 Source Point #..... 0
of Points..... 0
Item #15 Source Point #..... 0
of Points..... 0
Item #16 Source Point #..... 0
of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 25
=====

----- CONFIG AB PLC BLOCK#3 READ

Start Address of Data Block #3.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC COMMAND BLOCK

Start Address of Command Block	0
Item #1 Dest. Point #.....	0
# of Points.....	0
Item #2 Dest. Point #.....	0
# of Points.....	0
Item #3 Dest. Point #.....	0
# of Points.....	0
Item #4 Dest. Point #.....	0
# of Points.....	0
Item #5 Dest. Point #.....	0
# of Points.....	0
Item #6 Dest. Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 26
=====

----- CONFIG AB PLC SETPOINT BLOCK
Start Address of Command Block..... 0
 Item #1 Dest. Point #..... 0
 # of Points..... 0
 Item #2 Dest. Point #..... 0
 # of Points..... 0
 Item #3 Dest. Point #..... 0
 # of Points..... 0
 Item #4 Dest. Point #..... 0
 # of Points..... 0
 Item #5 Dest. Point #..... 0
 # of Points..... 0
 Item #6 Dest. Point #..... 0
 # of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 27
=====

----- PRINTER SETUP

Computer ID.....	62823
Print Interval in Minutes.....	0
Print Interval Start Time.....	18:00:00
Daily Report Time.....	06:00:00
Disable Daily Report.....	YES
Day Light Savings Start.....	00/00/00
Day Light Savings End.....	00/00/00
Clear Daily Totals at Batch End.....	YES
Auto Hourly Batch Select.....	NO
Auto Weekly Batch Select.....	No Batch End
Auto Monthly Batch Select.....	0
Print Priority.....	0
Number of Nulls.....	0
Use Default Report Template.....	NO
Printer Condensed Mode String.....	
Printer Normal Mode String.....	
Company Name	TRANSCO part of Lattice Group plc
Location	Sunny Blackrod

----- ANALYSER SETUP

Analyser ID Number.....	1
Analyser Type.....	DANALYZER
Results Interval (Minutes).....	4
Listen Only Mode (Y or N).....	NO
GC Fail Code.....	Always use
GC Comp. # for Methane (CH4).....	0
GC Comp. # for Nitrogen (N2).....	0
GC Comp. # for Carbon Dioxide (CO2).....	0
GC Comp. # for Ethane (C2H6).....	0
GC Comp. # for Propane (C3H8).....	0
GC Comp. # for Water (H2O).....	0
GC Comp. # for Hydrogen Sulfide (H2S).....	0
GC Comp. # for Hydrogen (H2).....	0
GC Comp. # for Carbon Monoxide (CO).....	0
GC Comp. # for Oxygen (O2).....	0
GC Comp. # for i-Butane (iC4H10).....	0
GC Comp. # for n-Butane (nC4H10).....	0
GC Comp. # for i-Pentane (iC5H12).....	0
GC Comp. # for n-Pentane (nC5H12).....	0
GC Comp. # for n-Hexane (C6H14).....	0
GC Comp. # for n-Heptane (C7H16).....	0
GC Comp. # for n-Octane (C8H16).....	0
GC Comp. # for n-Nonane.....	0
GC Comp. # for n-Decane.....	0
GC Comp. # for Helium (He).....	0
GC Comp. # for Argon (Ar).....	0
GC Comp. # for Heating Value.....	0
GC Comp. # for Specific Gravity.....	0

```
=====
CONFIGURATION DATA REPORT      COMPUTER ID : 62823      PAGE : 28
=====

----- PID CONTROL SETUP
Loop #1 Secondary Setpoint Value..... 0
    Primary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Secondary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Deadband %..... 0
    Startup Ramp %..... 0
    Shutdown Ramp %..... 0
    Minimum Ramp To %..... 0
    Primary Setpoint Low Limit..... 0
        High Limit..... 0
        Zero Value..... 0
        Full Scale Value..... 0
    Secondary Var Zero Value..... 0
        Full Scale Value..... 0
Loop #2 Secondary Setpoint Value..... 0
    Primary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Secondary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Deadband %..... 0
    Startup Ramp %..... 0
    Shutdown Ramp %..... 0
    Minimum Ramp To %..... 0
    Primary Setpoint Low Limit..... 0
        High Limit..... 0
        Zero Value..... 0
        Full Scale Value..... 0
    Secondary Var Zero Value..... 0
        Full Scale Value..... 0
Loop #3 Secondary Setpoint Value..... 0
    Primary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Secondary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Deadband %..... 0
    Startup Ramp %..... 0
    Shutdown Ramp %..... 0
    Minimum Ramp To %..... 0
    Primary Setpoint Low Limit..... 0
        High Limit..... 0
        Zero Value..... 0
        Full Scale Value..... 0
    Secondary Var Zero Value..... 0
        Full Scale Value..... 0
Loop #4 Secondary Setpoint Value..... 0
    Primary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Secondary Gain Factor..... 0.00
        Rpts/Min..... 0.00
    Deadband %..... 0
    Startup Ramp %..... 0
    Shutdown Ramp %..... 0
```

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 29
=====

----- PID CONTROL SETUP (Cont'd)

Minimum Ramp To %.....	0
Primary Setpoint Low Limit.....	0
High Limit.....	0
Zero Value.....	0
Full Scale Value.....	0
Secondary Var Zero Value.....	0
Full Scale Value.....	0

----- GRAV/DENSITY SETUP

----- TEMP/PRESS SETUP

Temp #1 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Temp #2 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Press #1 Low Alarm Limit.....	35
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds
Press #2 Low Alarm Limit.....	30
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds

----- DIFF. PRESSURE SETUP

Diff Pressure #1 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail
Low DP at 4mA.....	0
Low DP at 20mA.....	50
Damping Code.....	0.0 Seconds
High DP at 4mA.....	0
High DP at 20mA.....	500
Damping Code.....	0.0 Seconds
High DP Select %.....	95
Low DP Select %.....	9
Diff Pressure #2 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 30
=====

----- DIFF. PRESSURE SETUP (Cont'd)
Low DP at 4mA..... 0
Low DP at 20mA..... 50
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 95
Low DP Select %..... 9
Diff Pressure #3 Low Alarm Limit..... -2.5
Hi Alarm Limit..... 502.5
Override Value..... 0
Override Code..... Avg on fail
Low DP at 4mA..... 0
Low DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 0
Low DP Select %..... 0

----- STATION SG/N2 ETC SETUP
Station ID..... Blackrod
Flow Low Limit (Tons/Hr)..... 0
Flow High Limit (Tons/Hr)..... 871.4241
Gross Flowrate Full Scale..... 0
Mass Flowrate Full Scale..... 0
Run Switch Mode..... Manual
Run Switch Time..... 0
Run Switch Threshold Low %DP..... 0
Run Switch Threshold High %DP..... 0

----- METER RUN SETUP
Meter #1 Meter ID..... 9741/MTA
Analysis Selected..... Product #1
Analyzer Stream Number..... 3
Flow Low Limit..... 0
Flow High Limit..... 435.712
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.846
Orifice Reference Temp..... 21
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.1738
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO
Meter #2 Meter ID..... 8171/MTB

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 31
=====

----- METER RUN SETUP (Cont'd)
Analysis Selected..... Product #1
Analyzer Stream Number..... 1
Flow Low Limit..... 0
Flow High Limit..... 435.712
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.499
Orifice Reference Temp..... 21
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.2849
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

Meter #3 Meter ID.....
Analysis Selected..... Product #1
Analyzer Stream Number..... 0
Flow Low Limit..... 0
Flow High Limit..... 0
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... 0
Orifice Measured Dia..... 0
Orifice Reference Temp..... 0
Orifice Expansion Coef..... 0.000000E+000
Pipe Measured Dia..... 0
Pipe Reference Temp..... 0
Pipe Expansion Coef..... 0.000000E+000
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... YES
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

----- FACTOR SETUP & SYS CONSTANTS
Atmospheric Pressure (absolute)..... 1.01325
Base Pressure (absolute)..... 1.01325
Base Temperature..... 15
Density of Air..... 1.225410
Flow Average Factor..... 0
Alarm Deadband %..... 2.00
Roll All Totalizers..... 9 Digits
Gross Totalizer Decimal Places..... 0
Net Totalizer Decimal Places..... 0
Mass Totalizer Decimal Places..... 0
Energy Totalizer Decimal Places..... 0
Select Averaging Method..... Flow Weighted
Select Pressure Units..... Bar
Select DP Units..... Milli Bar

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 32
=====

----- FLUID DATA & ANALYSIS

Prod #1 Fluid Name.....
 Fluid Type Select (F1=Help)..... Natural Gas
 Viscosity in pa.s..... .0000116
 Isentropic Exponent..... 1.3215
 AGA-8 Method (F1=Help)..... 94 Detailed
 Heating Value Method (F1=Help)..... ISO 6976
 Heating Value MJ/NM3..... 39.92
 Specific Gravity..... 0.6410
 1994-01 % Methane (CH4)..... 87.9129
 1994-02 % Nitrogen (N2)..... 0.9419
 1994-03 % Carbon Dioxide (CO2)..... 2.4474
 1994-04 % Ethane (C2H6)..... 6.1555
 1994-05 % Propane (C3H8)..... 1.9367
 1994-06 % Water (H2O)..... 0.0000
 1994-07 % Hydrogen Sulfide (H2S)..... 0.0000
 1994-08 % Hydrogen (H2)..... 0.0000
 1994-09 % Carbon Monoxide (CO)..... 0.0000
 1994-10 % Oxygen (O2)..... 0.0000
 1994-11 % i-Butane (iC4H10)..... 0.1755
 1994-12 % n-Butane (nC4H10)..... 0.3017
 1994-13 % i-Pentane (iC5H12)..... 0.0464
 1994-14 % n-Pentane (nC5H12)..... 0.0480
 1994-15 % n-Hexane (C6H14)..... 0.0339
 1994-16 % n-Heptane (C7H16)..... 0.0000
 1994-17 % n-Octane (C8H16)..... 0.0000
 1994-18 % n-Nonane..... 0.0000
 1994-19 % n-Decane..... 0.0000
 1994-20 % Helium (He)..... 0.0000
 1994-21 % Argon (Ar)..... 0.0000

Prod #2 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 39.92

Prod #3 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 0

Prod #4 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density Lb/Ft3..... 0
 Viscosity in Centipoise..... 0
 Isentropic Exponent..... 0
 Heating Value Btu/Scf..... 0

TABLE B.2 CONFIGURATION DATA REPORT 16/07/2007

```
=====
CONFIGURATION DATA REPORT : [ BLAL0802.OMI ]  
  
COMPANY NAME : TRANSCO part of Lattice Group plc  
LOCATION : Sunny Blackrod  
COMPUTER ID : 62823  
  
CURRENT DATE : 3-31-2010 TIME : 11:42a  
CONFIGURATION FILE : LAST MODIFIED  
=====  
  
----- CHECK I/O MODULE CONFIG  
OMNI Flow Computer Model Number..... OMNI 6000  
Number of TYPE A Modules Installed..... 3  
Number of TYPE B Modules Installed..... 0  
Number of TYPE C Modules Installed..... 0  
Number of TYPE E Modules Installed..... 0  
Number of TYPE E/D Modules Installed..... 0  
Number of TYPE H Modules Installed..... 0  
Number of DIGITAL Modules Installed..... 1  
Number of SERIAL Modules Installed..... 2  
  
----- FLOW COMPUTER TIME & DATE  
OMNI Time..... 11:11:01  
OMNI Date..... 16/07/07  
Select Date Type..... dd/mm/yy  
  
----- CONFIG STATION DATA  
Station Totals and Flows Defined As:..... 1+2  
Reference Gravity.I/O Pnt#..... 0  
    Tag.....  
    Type..... 4-20 mA  
Nitrogen % I/O Pnt#..... 0  
    Tag.....  
Carbon Dioxide I/O Pnt#..... 0  
    Tag.....  
Heating Value I/O Pnt#..... 0  
    Tag.....  
Auxiliary Input #1 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #2 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #3 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #4 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
  
----- CONFIG METER RUNS  
Meter #1 Select Turbine Y/N..... NO  
    DP Low Range I/O Pnt#..... 3  
        Tag..... DPLR-1
```

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 02
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 4
Tag..... DPHR-1
Temp I/O Pnt#..... 1
Tag..... FT-1
Type..... DIN Rtd
Pres I/O Pnt#..... 2
Tag..... FP-1
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #2 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 7
Tag..... DPRL-2
DP High Range I/O Pnt#..... 8
Tag..... DPHR-2
Temp I/O Pnt#..... 5
Tag..... FT-2
Type..... DIN Rtd
Pres I/O Pnt#..... 6
Tag..... FP-2
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #3 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 11
Tag..... DPST-1
DP High Range I/O Pnt#..... 12
Tag..... DPST-2
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #4 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 0
Tag.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 03
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 0
Tag.....
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....

----- CONFIG PID LOOPS
Loop #1 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #2 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #3 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #4 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 04
=====

----- CONFIG PID LOOPS (Cont'd)

Action (F/R).....	Forward
Error Select (Low/High).....	Low
Startup Mode (Last/Manual).....	Last State
Control Output Tag.....	

----- CONFIG D/A OUT

D/A Output #01 Assign.....	7802
Remarks.....	Station scm/hr
@ 4 ma.....	0
@ 20 ma.....	1109405
D/A Output #02 Assign.....	7044
Remarks.....	Odorant scm/hr
@ 4 ma.....	0
@ 20 ma.....	1109405
D/A Output #03 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #04 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #05 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #06 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0

----- CONFIG FRONT PANEL COUNTERS

Front Panel Counter A Assign.....	1802
Remark.....	Stream 1 st vol
Pulses/Unit.....	.001
Front Panel Counter B Assign.....	1804
Remark.....	Stream 1 ene flo
Pulses/Unit.....	.01
Front Panel Counter C Assign.....	0
Remark.....	
Pulses/Unit.....	0

----- CONFIGURE BOOLEAN STATEMENTS

Boolean #1025 =.....	1811
Remarks.....	Hi flow alrm
Boolean #1026 =.....	/1829+1837
Remarks.....	Power/EPROM fail
Boolean #1027 =.....	7054+7055
Remarks.....	RD alarm
Boolean #1028 =.....	1125+1126
Remarks.....	1. L/H T alrm

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 05
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1029 =..... 1129+1130
 Remarks..... 1. L/H P alrm
Boolean #1030 =..... 1141+1142
 Remarks..... 1. L/H DP alarm
Boolean #1031 =..... 1341+1342
 Remarks..... 1. L/H STBY alrm
Boolean #1032 =..... 7035&1152
 Remarks..... 1. LDP OutOfTol
Boolean #1033 =..... 7036&1153
 Remarks..... 1. HDP OutOfTol
Boolean #1034 =..... 7048+7049
 Remarks..... 1. Density alrm
Boolean #1035 =.....
 Remarks.....
Boolean #1036 =..... 1225+1226
 Remarks..... 2. L/H T alrm
Boolean #1037 =..... 1229+1230
 Remarks..... 2. L/H P alrm
Boolean #1038 =..... 1241+1242
 Remarks..... 2. L/H DP alrm
Boolean #1039 =..... 1341+1342
 Remarks..... 2. L/H STDP alrm
Boolean #1040 =..... 7041&1252
 Remarks..... 2. LDP OutOfTol
Boolean #1041 =..... 7042&1253
 Remarks..... 2. HDP OutOfTol
Boolean #1042 =..... 7051+7052
 Remarks..... 2. Density
Boolean #1043 =.....
 Remarks.....
Boolean #1044 =..... 1025+1026+1027
 Remarks..... General
Boolean #1045 =..... 1028+1029+1030
 Remarks..... 1.
Boolean #1046 =..... 1031+1032+1033
 Remarks..... 1.
Boolean #1047 =..... 1034
 Remarks..... 1.
Boolean #1048 =..... 1036+1037+1038
 Remarks..... 2.
Boolean #1049 =..... 1039+1040+1041
 Remarks..... 2.
Boolean #1050 =..... 1042
 Remarks..... 2.
Boolean #1051 =..... 1045+1046+1047
 Remarks..... 1. Combined
Boolean #1052 =..... 1048+1049+1050
 Remarks..... 2. Combined
Boolean #1053 =..... 1051&1105
 Remarks..... 1. in use?
Boolean #1054 =..... 1052&1205
 Remarks..... 2. in use?
Boolean #1055 =..... 1044+1053+1054
 Remarks..... Meter Suspect

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 06
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1056 =.....
 Remarks.....
Boolean #1057 =..... 1088=1070
 Remarks..... Maintenance
Boolean #1058 =..... 1087=1055
 Remarks..... Meter Suspect
Boolean #1059 =..... 1086=1027
 Remarks..... RD error
Boolean #1060 =..... 1085=1034
 Remarks..... 1. Density error
Boolean #1061 =..... 1084=1032
 Remarks..... 1. Low DP error
Boolean #1062 =..... 1083=1033
 Remarks..... 1. High DP error
Boolean #1063 =..... 1082=1042
 Remarks..... 2. Density error
Boolean #1064 =..... 1081=1040
 Remarks..... 2. Low DP error
Boolean #1065 =..... 1080=1041
 Remarks..... 2. High DP error
Boolean #1066 =.....
 Remarks.....
Boolean #1067 =.....
 Remarks.....
Boolean #1068 =.....
 Remarks.....
Boolean #1069 =..... /1105&/1205
 Remarks..... No flow if = 1
Boolean #1070 =..... 7025
 Remarks..... Maintenance mode
Boolean #1071 =..... 1027
 Remarks..... Spare
Boolean #1072 =..... /1055
 Remarks..... Invert met susp
Boolean #1073 =..... 1736=/1105
 Remarks..... 1. Disable flow
Boolean #1074 =..... 1737=/1205
 Remarks..... 2. Disable flow
Boolean #1075 =.....
 Remarks..... Den #3 alarm
Boolean #1076 =.....
 Remarks..... Den #4 alarm
Boolean #1077 =.....
 Remarks.....
Boolean #1078 =.....
 Remarks.....
Boolean #1079 =.....
 Remarks.....
Boolean #1080 =..... M2 HDP OutOfTol
 Remarks.....
Boolean #1081 =..... M2 LDP OutOfTol
 Remarks.....
Boolean #1082 =..... M2 Den OutOfTol
 Remarks.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 07
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1083 =..... M1 HDP OutOfTol
Remarks.....
Boolean #1084 =..... M1 LDP OutOfTol
Remarks.....
Boolean #1085 =..... M1 Den OutOfTol
Remarks.....
Boolean #1086 =..... RD OutOfTol
Remarks.....
Boolean #1087 =..... Meter Suspect
Remarks.....
Boolean #1088 =..... Maintenance
Remarks.....

----- CONFIGURE VARIABLE STATEMENTS
Statement #7025 =..... Main:-1=Off,1=On
Remarks.....
Statement #7026 =..... LGT Fix Output %
Remarks.....
Statement #7027 =..... LGT lo flo inj %
Remarks.....
Statement #7028 =..... #5.0
Remarks..... Enter DP tol
Statement #7029 =..... #5.0-7028
Remarks..... DP tol >5.0?
Statement #7030 =..... 7029)7028=#5.0
Remarks..... Set min DPtol
Statement #7031 =..... 8596+8795
Remarks..... 1.Sum hi cells
Statement #7032 =..... 7031/#2
Remarks..... 1.Average hi
Statement #7033 =..... 7032-8595
Remarks..... 1.Diff av H + L
Statement #7034 =..... 8596-8795
Remarks..... 1.Diff H + STBY
Statement #7035 =..... \$7033-7028
Remarks..... 1.LDP OutOfTol
Statement #7036 =..... \$7034-7028
Remarks..... 1.HDP OutOfTol
Statement #7037 =..... 8696+8796
Remarks..... 2.Sum hi cells
Statement #7038 =..... 7037/#2
Remarks..... 2.Average hi
Statement #7039 =..... 7038-8695
Remarks..... 2.Diff av H + L
Statement #7040 =..... 8696-8796
Remarks..... 2.Diff H + STBY
Statement #7041 =..... \$7039-7028
Remarks..... 2.LDP OutOfTol
Statement #7042 =..... \$7040-7028
Remarks..... 2.HDP OutOfTol
Statement #7043 =.....
Remarks.....
Statement #7044 =..... 7802

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 08
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Set odour flow
Statement #7045 =..... 1069)7044=7085
Remarks..... LGT-low flow
Statement #7046 =..... 1055)7044=7086
Remarks..... LGT-Met Susp
Statement #7047 =..... 7025)7044=7087
Remarks..... LGT-fix flow
Statement #7048 =..... 7107-#80
Remarks..... 1. Hi den?
Statement #7049 =..... #24-7107
Remarks..... 1. Low den?
Statement #7050 =.....
Remarks.....
Statement #7051 =..... 7207-#80
Remarks..... 2. Hi den?
Statement #7052 =..... #24-7207
Remarks..... 2. Low den?
Statement #7053 =.....
Remarks.....
Statement #7054 =..... 7141-#0.7
Remarks..... RD hi?
Statement #7055 =..... #0.5-7141
Remarks..... RD low?
Statement #7056 =.....
Remarks.....
Statement #7057 =.....
Remarks.....
Statement #7058 =..... 7854=7138*17002
Remarks..... St mass fl limit
Statement #7059 =..... 7854=7854/#1000
Remarks..... Convert to ton/h
Statement #7060 =..... 7162=7854/#2
Remarks..... 1. Mass flow lim
Statement #7061 =..... 7262=7854/#2
Remarks..... 2. Mass flow lim
Statement #7062 =..... 7151=#.0009*7158
Remarks..... 1. Set DP cutoff
Statement #7063 =..... 7251=#.0009*7258
Remarks..... 2. Set DP cutoff
Statement #7064 =.....
Remarks.....
Statement #7065 =.....
Remarks.....
Statement #7066 =.....
Remarks.....
Statement #7067 =..... 7802*#0.000024
Remarks..... St vol MSCM/D
Statement #7068 =..... 7804*#0.024
Remarks..... St. energy MMJ/D
Statement #7069 =..... 7802/17002*#100
Remarks..... %Max flow
Statement #7070 =..... 17002*#0.000024
Remarks..... Max vol MSCM/D
Statement #7071 =..... 7070*#44

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 09
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Max energy MMJ/D
Statement #7072 =..... 7068/7071*#100
Remarks..... %Energy for tele
Statement #7073 =..... 7044/17004*#100
Remarks..... %Odour
Statement #7074 =.....
Remarks.....
Statement #7075 =.....
Remarks.....
Statement #7076 =..... 17049=17025
Remarks..... Set counter A
Statement #7077 =..... 17050=#10*17049
Remarks..... Set counter B
Statement #7078 =..... 7152=7158/#-200
Remarks..... 1. DP low limit
Statement #7079 =..... 7153=7158+\$7152
Remarks..... 1. DP hi limit
Statement #7080 =..... 7252=7258/#-200
Remarks..... 2. DP low limit
Statement #7081 =..... 7253=7258+\$7252
Remarks..... 2. DP hi limit
Statement #7082 =..... 7352=7358/#-200
Remarks..... 3. DP low limit
Statement #7083 =..... 7353=7358+\$7352
Remarks..... 3. DP hi limit
Statement #7084 =.....
Remarks.....
Statement #7085 =..... 7027/#100*17004
Remarks..... LGT low flow inj
Statement #7086 =..... /1055)7086=7044
Remarks..... Store LGT output
Statement #7087 =..... 7026/#100*17004
Remarks..... LGT fix flow
Statement #7088 =.....
Remarks.....

----- CONFIG USER DISPLAYS
User Display Number 1 Key Press..... F
1st Variable Tag..... MSCM/D
Point #..... 7067
Dec. Places..... 6
2nd Variable Tag..... MMJ/D
Point #..... 7068
Dec. Places..... 6
3rd Variable Tag..... %Max flw
Point #..... 7069
Dec. Places..... 2
4th Variable Tag..... %Odour
Point #..... 7073
Dec. Places..... 2
User Display Number 2 Key Press..... IO
1st Variable Tag..... RD
Point #..... 7141

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 10
=====

----- CONFIG USER DISPLAYS
(Cont'd)
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7138
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7107
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7142
Dec. Places..... 7
User Display Number 3 Key Press..... IP
1st Variable Tag..... RD
Point #..... 7241
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7238
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7207
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7242
Dec. Places..... 7
User Display Number 4 Key Press..... VER
1st Variable Tag..... 02_71_V2
Point #..... 0
Dec. Places..... 0
2nd Variable Tag..... LGTcutoff
Point #..... 7027
Dec. Places..... 2
3rd Variable Tag..... 25/08/98
Point #..... 0
Dec. Places..... 0
4th Variable Tag..... 0
Dec. Places..... 0
User Display Number 5 Key Press..... FO
1st Variable Tag..... acmh
Point #..... 7101
Dec. Places..... 3
2nd Variable Tag..... scmh
Point #..... 7102
Dec. Places..... 3
3rd Variable Tag..... tons/hr
Point #..... 7103
Dec. Places..... 7
4th Variable Tag..... GJ/hr
Point #..... 7104
Dec. Places..... 3
User Display Number 6 Key Press..... FP
1st Variable Tag..... acmh
Point #..... 7201
Dec. Places..... 3
2nd Variable Tag..... scmh

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 11
=====

----- CONFIG USER DISPLAYS (Cont'd)

	Point #.....	7202
	Dec. Places.....	3
3rd Variable	Tag.....	tons/hr
	Point #.....	7203
	Dec. Places.....	7
4th Variable	Tag.....	GJ/hr
	Point #.....	7204
	Dec. Places.....	3
User Display Number 7	Key Press.....	DPO
1st Variable	Tag.....	Low DP
	Point #.....	8595
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8596
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8795
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7032
	Dec. Places.....	4
User Display Number 8	Key Press.....	DPP
1st Variable	Tag.....	Low DP
	Point #.....	8695
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8696
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8796
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7038
	Dec. Places.....	4

----- CONFIG DIGITAL I/O

Digital Point #1	Assign.....	1802
	Remarks.....	Integ St Vol.
	Pulse Width.....	20
	Pulses/Unit.....	.001
Digital Point #2	Assign.....	1072
	Remarks.....	Meter Suspect
	Delay On.....	10
	Delay Off.....	10
Digital Point #3	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #4	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #5	Assign.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 12
=====

----- CONFIG DIGITAL I/O (Cont'd)

Digital Point #6	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #7	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #8	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #9	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #10	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #11	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #12	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	

----- CONFIG SERIAL I/O

Serial I/O #1	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Port Type.....	Printer
Serial I/O #2	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Protocol Type.....	Modbus RTU(Modem)
	Modbus ID.....	1
	Modicon Compatible.....	NO
	CRC Enabled.....	YES
Serial I/O #3	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 13
=====

----- CONFIG SERIAL I/O (Cont'd)

Protocol Type.....	Modbus ASCII
Modbus ID.....	1
Modicon Compatible.....	YES
CRC Enabled.....	YES
Serial I/O #4 Baud Rate.....	9600
Stop Bits.....	1 Bit
Data Bits.....	8
Parity.....	None
Xmit Key Delay.....	0ms
Protocol Type.....	Modbus RTU
Modbus ID.....	0
Modicon Compatible.....	YES
CRC Enabled.....	YES

----- MODBUS PEER/PEER COMMUNICATIONS

Activate Redundancy Mode.....	NO
Next Master in Sequence.....	0
Last Master in Sequence.....	0
Retry Timer (50 mS Ticks).....	0
Transaction #1 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #2 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #3 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #4 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #5 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #6 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #7 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 14
=====

----- MODBUS PEER/PEER COMMUNICATIONS (Cont'd)

Dest. Point #.....	0
Transaction #8 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #9 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #10 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #11 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #12 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #13 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #14 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #15 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #16 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0

----- CUSTOM MODBUS PACKET(ADDR:001)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 15
=====

----- CUSTOM MODBUS PACKET(ADDR:001) (Cont'd)

	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0
Packet #09	Pnt.#.....	0
	# of Points.....	0
Packet #10	Pnt.#.....	0
	# of Points.....	0
Packet #11	Pnt.#.....	0
	# of Points.....	0
Packet #12	Pnt.#.....	0
	# of Points.....	0
Packet #13	Pnt.#.....	0
	# of Points.....	0
Packet #14	Pnt.#.....	0
	# of Points.....	0
Packet #15	Pnt.#.....	0
	# of Points.....	0
Packet #16	Pnt.#.....	0
	# of Points.....	0
Packet #17	Pnt.#.....	0
	# of Points.....	0
Packet #18	Pnt.#.....	0
	# of Points.....	0
Packet #19	Pnt.#.....	0
	# of Points.....	0
Packet #20	Pnt.#.....	0
	# of Points.....	0

----- CUSTOM MODBUS PACKET(ADDR:201)

Packet #01	Pnt.#.....	0
	# of Points.....	0
Packet #02	Pnt.#.....	0
	# of Points.....	0
Packet #03	Pnt.#.....	0
	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 16
=====

----- CUSTOM MODBUS PACKET(ADDR:401)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Packet #17 Pnt.#.....	0
# of Points.....	0
Packet #18 Pnt.#.....	0
# of Points.....	0
Packet #19 Pnt.#.....	0
# of Points.....	0
Packet #20 Pnt.#.....	0
# of Points.....	0

----- ARCHIVE 701 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 17
=====

----- ARCHIVE 701 - RECORD DEFINITION (Cont'd)

Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 702 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 18
=====

----- ARCHIVE 702 - RECORD DEFINITION (Cont'd)
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 703 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 704 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 19
=====

----- ARCHIVE 704 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 705 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 20
=====

----- ARCHIVE 705 - RECORD DEFINITION (Cont'd)
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 706 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 707 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 21
=====

----- ARCHIVE 707 - RECORD DEFINITION (Cont'd)

Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 708 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 22
=====

----- ARCHIVE 708 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 709 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 23
=====

----- ARCHIVE 710 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- CONFIG AB PLC BLOCK#1 READ

Start Address of Data Block #1.....	9
Item #1 Source Point #.....	8
# of Points.....	10
Item #2 Source Point #.....	11
# of Points.....	2
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	3
Item #6 Source Point #.....	4
# of Points.....	6
Item #7 Source Point #.....	7
# of Points.....	1
Item #8 Source Point #.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 24
=====

----- CONFIG AB PLC BLOCK#1 READ (Cont'd)

# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	17
# of Points.....	18
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC BLOCK#2 READ

Start Address of Data Block #2.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 25
=====

----- CONFIG AB PLC BLOCK#3 READ

Start Address of Data Block #3.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC COMMAND BLOCK

Start Address of Command Block	0
Item #1 Dest. Point #.....	0
# of Points.....	0
Item #2 Dest. Point #.....	0
# of Points.....	0
Item #3 Dest. Point #.....	0
# of Points.....	0
Item #4 Dest. Point #.....	0
# of Points.....	0
Item #5 Dest. Point #.....	0
# of Points.....	0
Item #6 Dest. Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 26
=====

----- CONFIG AB PLC SETPOINT BLOCK
Start Address of Command Block..... 0
 Item #1 Dest. Point #..... 0
 # of Points..... 0
 Item #2 Dest. Point #..... 0
 # of Points..... 0
 Item #3 Dest. Point #..... 0
 # of Points..... 0
 Item #4 Dest. Point #..... 0
 # of Points..... 0
 Item #5 Dest. Point #..... 0
 # of Points..... 0
 Item #6 Dest. Point #..... 0
 # of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 27
=====

----- PRINTER SETUP

Computer ID.....	62823
Print Interval in Minutes.....	0
Print Interval Start Time.....	18:00:00
Daily Report Time.....	06:00:00
Disable Daily Report.....	YES
Day Light Savings Start.....	00/00/00
Day Light Savings End.....	00/00/00
Clear Daily Totals at Batch End.....	YES
Auto Hourly Batch Select.....	NO
Auto Weekly Batch Select.....	No Batch End
Auto Monthly Batch Select.....	0
Print Priority.....	0
Number of Nulls.....	0
Use Default Report Template.....	NO
Printer Condensed Mode String.....	
Printer Normal Mode String.....	
Company Name	TRANSCO part of Lattice Group plc
Location	Sunny Blackrod

----- ANALYSER SETUP

Analyser ID Number.....	1
Analyser Type.....	DANALYZER
Results Interval (Minutes).....	4
Listen Only Mode (Y or N).....	NO
GC Fail Code.....	Always use
GC Comp. # for Methane (CH4).....	0
GC Comp. # for Nitrogen (N2).....	0
GC Comp. # for Carbon Dioxide (CO2).....	0
GC Comp. # for Ethane (C2H6).....	0
GC Comp. # for Propane (C3H8).....	0
GC Comp. # for Water (H2O).....	0
GC Comp. # for Hydrogen Sulfide (H2S).....	0
GC Comp. # for Hydrogen (H2).....	0
GC Comp. # for Carbon Monoxide (CO).....	0
GC Comp. # for Oxygen (O2).....	0
GC Comp. # for i-Butane (iC4H10).....	0
GC Comp. # for n-Butane (nC4H10).....	0
GC Comp. # for i-Pentane (iC5H12).....	0
GC Comp. # for n-Pentane (nC5H12).....	0
GC Comp. # for n-Hexane (C6H14).....	0
GC Comp. # for n-Heptane (C7H16).....	0
GC Comp. # for n-Octane (C8H16).....	0
GC Comp. # for n-Nonane.....	0
GC Comp. # for n-Decane.....	0
GC Comp. # for Helium (He).....	0
GC Comp. # for Argon (Ar).....	0
GC Comp. # for Heating Value.....	0
GC Comp. # for Specific Gravity.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 28
=====

----- PID CONTROL SETUP
Loop #1 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #2 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #3 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #4 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 29
=====

----- PID CONTROL SETUP (Cont'd)

Minimum Ramp To %.....	0
Primary Setpoint Low Limit.....	0
High Limit.....	0
Zero Value.....	0
Full Scale Value.....	0
Secondary Var Zero Value.....	0
Full Scale Value.....	0

----- GRAV/DENSITY SETUP

----- TEMP/PRESS SETUP

Temp #1 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Temp #2 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Press #1 Low Alarm Limit.....	35
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds
Press #2 Low Alarm Limit.....	30
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds

----- DIFF. PRESSURE SETUP

Diff Pressure #1 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail
Low DP at 4mA.....	0
Low DP at 20mA.....	50
Damping Code.....	0.0 Seconds
High DP at 4mA.....	0
High DP at 20mA.....	500
Damping Code.....	0.0 Seconds
High DP Select %.....	95
Low DP Select %.....	9
Diff Pressure #2 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 30
=====

----- DIFF. PRESSURE SETUP (Cont'd)
Low DP at 4mA..... 0
Low DP at 20mA..... 50
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 95
Low DP Select %..... 9
Diff Pressure #3 Low Alarm Limit..... -2.5
Hi Alarm Limit..... 502.5
Override Value..... 0
Override Code..... Avg on fail
Low DP at 4mA..... 0
Low DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 0
Low DP Select %..... 0

----- STATION SG/N2 ETC SETUP
Station ID..... Blackrod
Flow Low Limit (Tons/Hr)..... 0
Flow High Limit (Tons/Hr)..... 862.4516
Gross Flowrate Full Scale..... 0
Mass Flowrate Full Scale..... 0
Run Switch Mode..... Manual
Run Switch Time..... 0
Run Switch Threshold Low %DP..... 0
Run Switch Threshold High %DP..... 0

----- METER RUN SETUP
Meter #1 Meter ID..... 9741/MTA
Analysis Selected..... Product #1
Analyzer Stream Number..... 3
Flow Low Limit..... 0
Flow High Limit..... 431.2258
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.156
Orifice Reference Temp..... 21
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.1738
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO
Meter #2 Meter ID..... 8171/MTB

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 31
=====

----- METER RUN SETUP (Cont'd)
Analysis Selected..... Product #1
Analyzer Stream Number..... 1
Flow Low Limit..... 0
Flow High Limit..... 431.2258
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.499
Orifice Reference Temp..... 21
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.2849
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

Meter #3 Meter ID.....
Analysis Selected..... Product #1
Analyzer Stream Number..... 0
Flow Low Limit..... 0
Flow High Limit..... 0
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... 0
Orifice Measured Dia..... 0
Orifice Reference Temp..... 0
Orifice Expansion Coef..... 0.000000E+000
Pipe Measured Dia..... 0
Pipe Reference Temp..... 0
Pipe Expansion Coef..... 0.000000E+000
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... YES
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

----- FACTOR SETUP & SYS CONSTANTS
Atmospheric Pressure (absolute)..... 1.01325
Base Pressure (absolute)..... 1.01325
Base Temperature..... 15
Density of Air..... 1.225410
Flow Average Factor..... 0
Alarm Deadband %..... 2.00
Roll All Totalizers..... 9 Digits
Gross Totalizer Decimal Places..... 0
Net Totalizer Decimal Places..... 0
Mass Totalizer Decimal Places..... 0
Energy Totalizer Decimal Places..... 0
Select Averaging Method..... Flow Weighted
Select Pressure Units..... Bar
Select DP Units..... Milli Bar

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 32
=====

----- FLUID DATA & ANALYSIS

Prod #1 Fluid Name.....
 Fluid Type Select (F1=Help)..... Natural Gas
 Viscosity in pa.s..... .0000118
 Isentropic Exponent..... 1.3256
 AGA-8 Method (F1=Help)..... 94 Detailed
 Heating Value Method (F1=Help)..... ISO 6976
 Heating Value MJ/NM3..... 38.97
 Specific Gravity..... 0.6344
 1994-01 % Methane (CH4)..... 87.8198
 1994-02 % Nitrogen (N2)..... 3.0957
 1994-03 % Carbon Dioxide (CO2)..... 1.6276
 1994-04 % Ethane (C2H6)..... 5.3777
 1994-05 % Propane (C3H8)..... 1.4294
 1994-06 % Water (H2O)..... 0.0000
 1994-07 % Hydrogen Sulfide (H2S)..... 0.0000
 1994-08 % Hydrogen (H2)..... 0.0000
 1994-09 % Carbon Monoxide (CO)..... 0.0000
 1994-10 % Oxygen (O2)..... 0.0000
 1994-11 % i-Butane (iC4H10)..... 0.1687
 1994-12 % n-Butane (nC4H10)..... 0.2719
 1994-13 % i-Pentane (iC5H12)..... 0.0755
 1994-14 % n-Pentane (nC5H12)..... 0.0684
 1994-15 % n-Hexane (C6H14)..... 0.0654
 1994-16 % n-Heptane (C7H16)..... 0.0000
 1994-17 % n-Octane (C8H16)..... 0.0000
 1994-18 % n-Nonane..... 0.0000
 1994-19 % n-Decane..... 0.0000
 1994-20 % Helium (He)..... 0.0000
 1994-21 % Argon (Ar)..... 0.0000

Prod #2 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 38.97

Prod #3 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 0

Prod #4 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density Lb/Ft3..... 0
 Viscosity in Centipoise..... 0
 Isentropic Exponent..... 0
 Heating Value Btu/Scf..... 0

TABLE B.3 CONFIGURATION DATA REPORT 20/07/2007

```
=====
CONFIGURATION DATA REPORT : [ BLAM1607.OMI ]

COMPANY NAME : TRANSCO part of Lattice Group plc
LOCATION : Sunny Blackrod
COMPUTER ID : 62823

CURRENT DATE : 3-31-2010 TIME : 12:02a
CONFIGURATION FILE : LAST MODIFIED
=====

----- CHECK I/O MODULE CONFIG
OMNI Flow Computer Model Number..... OMNI 6000
Number of TYPE A Modules Installed..... 3
Number of TYPE B Modules Installed..... 0
Number of TYPE C Modules Installed..... 0
Number of TYPE E Modules Installed..... 0
Number of TYPE E/D Modules Installed..... 0
Number of TYPE H Modules Installed..... 0
Number of DIGITAL Modules Installed..... 1
Number of SERIAL Modules Installed..... 2

----- FLOW COMPUTER TIME & DATE
OMNI Time..... 11:43:40
OMNI Date..... 20/07/07
Select Date Type..... dd/mm/yy

----- CONFIG STATION DATA
Station Totals and Flows Defined As:..... 1+2
Reference Gravity.I/O Pnt#..... 0
    Tag.....  
Type..... 4-20 mA
Nitrogen % I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Carbon Dioxide I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Heating Value I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #1 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #2 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #3 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd
Auxiliary Input #4 I/O Pnt#..... 0
    Tag.....  
Type..... DIN Rtd

----- CONFIG METER RUNS
Meter #1 Select Turbine Y/N..... NO
    DP Low Range I/O Pnt#..... 3
        Tag..... DPLR-1
```

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 02
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 4
Tag..... DPHR-1
Temp I/O Pnt#..... 1
Tag..... FT-1
Type..... DIN Rtd
Pres I/O Pnt#..... 2
Tag..... FP-1
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #2 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 7
Tag..... DPRL-2
DP High Range I/O Pnt#..... 8
Tag..... DPHR-2
Temp I/O Pnt#..... 5
Tag..... FT-2
Type..... DIN Rtd
Pres I/O Pnt#..... 6
Tag..... FP-2
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #3 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 11
Tag..... DPST-1
DP High Range I/O Pnt#..... 12
Tag..... DPST-2
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #4 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 0
Tag.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 03
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 0
Tag.....
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....

----- CONFIG PID LOOPS
Loop #1 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #2 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #3 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #4 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 04
=====

----- CONFIG PID LOOPS (Cont'd)

Action (F/R).....	Forward
Error Select (Low/High).....	Low
Startup Mode (Last/Manual).....	Last State
Control Output Tag.....	

----- CONFIG D/A OUT

D/A Output #01 Assign.....	7802
Remarks.....	Station scm/hr
@ 4 ma.....	0
@ 20 ma.....	1109405
D/A Output #02 Assign.....	7044
Remarks.....	Odorant scm/hr
@ 4 ma.....	0
@ 20 ma.....	1109405
D/A Output #03 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #04 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #05 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #06 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0

----- CONFIG FRONT PANEL COUNTERS

Front Panel Counter A Assign.....	1802
Remark.....	Stream 1 st vol
Pulses/Unit.....	.001
Front Panel Counter B Assign.....	1804
Remark.....	Stream 1 ene flo
Pulses/Unit.....	.01
Front Panel Counter C Assign.....	0
Remark.....	
Pulses/Unit.....	0

----- CONFIGURE BOOLEAN STATEMENTS

Boolean #1025 =.....	1811
Remarks.....	Hi flow alrm
Boolean #1026 =.....	/1829+1837
Remarks.....	Power/EPROM fail
Boolean #1027 =.....	7054+7055
Remarks.....	RD alarm
Boolean #1028 =.....	1125+1126
Remarks.....	1. L/H T alrm

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 05
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1029 =..... 1129+1130
 Remarks..... 1. L/H P alrm
Boolean #1030 =..... 1141+1142
 Remarks..... 1. L/H DP alarm
Boolean #1031 =..... 1341+1342
 Remarks..... 1. L/H STBY alrm
Boolean #1032 =..... 7035&1152
 Remarks..... 1. LDP OutOfTol
Boolean #1033 =..... 7036&1153
 Remarks..... 1. HDP OutOfTol
Boolean #1034 =..... 7048+7049
 Remarks..... 1. Density alrm
Boolean #1035 =.....
 Remarks.....
Boolean #1036 =..... 1225+1226
 Remarks..... 2. L/H T alrm
Boolean #1037 =..... 1229+1230
 Remarks..... 2. L/H P alrm
Boolean #1038 =..... 1241+1242
 Remarks..... 2. L/H DP alrm
Boolean #1039 =..... 1341+1342
 Remarks..... 2. L/H STDP alrm
Boolean #1040 =..... 7041&1252
 Remarks..... 2. LDP OutOfTol
Boolean #1041 =..... 7042&1253
 Remarks..... 2. HDP OutOfTol
Boolean #1042 =..... 7051+7052
 Remarks..... 2. Density
Boolean #1043 =.....
 Remarks.....
Boolean #1044 =..... 1025+1026+1027
 Remarks..... General
Boolean #1045 =..... 1028+1029+1030
 Remarks..... 1.
Boolean #1046 =..... 1031+1032+1033
 Remarks..... 1.
Boolean #1047 =..... 1034
 Remarks..... 1.
Boolean #1048 =..... 1036+1037+1038
 Remarks..... 2.
Boolean #1049 =..... 1039+1040+1041
 Remarks..... 2.
Boolean #1050 =..... 1042
 Remarks..... 2.
Boolean #1051 =..... 1045+1046+1047
 Remarks..... 1. Combined
Boolean #1052 =..... 1048+1049+1050
 Remarks..... 2. Combined
Boolean #1053 =..... 1051&1105
 Remarks..... 1. in use?
Boolean #1054 =..... 1052&1205
 Remarks..... 2. in use?
Boolean #1055 =..... 1044+1053+1054
 Remarks..... Meter Suspect

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 06
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)

Boolean #1056 =.....	Remarks.....
Boolean #1057 =.....	1088=1070 Remarks..... Maintenance
Boolean #1058 =.....	1087=1055 Remarks..... Meter Suspect
Boolean #1059 =.....	1086=1027 Remarks..... RD error
Boolean #1060 =.....	1085=1034 Remarks..... 1. Density error
Boolean #1061 =.....	1084=1032 Remarks..... 1. Low DP error
Boolean #1062 =.....	1083=1033 Remarks..... 1. High DP error
Boolean #1063 =.....	1082=1042 Remarks..... 2. Density error
Boolean #1064 =.....	1081=1040 Remarks..... 2. Low DP error
Boolean #1065 =.....	1080=1041 Remarks..... 2. High DP error
Boolean #1066 =.....	Remarks.....
Boolean #1067 =.....	Remarks.....
Boolean #1068 =.....	Remarks.....
Boolean #1069 =.....	/1105&/1205 Remarks..... No flow if = 1
Boolean #1070 =.....	7025 Remarks..... Maintenance mode
Boolean #1071 =.....	1027 Remarks..... Spare
Boolean #1072 =.....	/1055 Remarks..... Invert met susp
Boolean #1073 =.....	1736=/1105 Remarks..... 1. Disable flow
Boolean #1074 =.....	1737=/1205 Remarks..... 2. Disable flow
Boolean #1075 =.....	Remarks..... Den #3 alarm
Boolean #1076 =.....	Remarks..... Den #4 alarm
Boolean #1077 =.....	Remarks.....
Boolean #1078 =.....	Remarks.....
Boolean #1079 =.....	Remarks.....
Boolean #1080 =.....	M2 HDP OutOfTol Remarks.....
Boolean #1081 =.....	M2 LDP OutOfTol Remarks.....
Boolean #1082 =.....	M2 Den OutOfTol Remarks.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 07
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1083 =..... M1 HDP OutOfTol
Remarks.....
Boolean #1084 =..... M1 LDP OutOfTol
Remarks.....
Boolean #1085 =..... M1 Den OutOfTol
Remarks.....
Boolean #1086 =..... RD OutOfTol
Remarks.....
Boolean #1087 =..... Meter Suspect
Remarks.....
Boolean #1088 =..... Maintenance
Remarks.....

----- CONFIGURE VARIABLE STATEMENTS
Statement #7025 =..... Main:-1=Off,1=On
Remarks.....
Statement #7026 =..... LGT Fix Output %
Remarks.....
Statement #7027 =..... LGT lo flo inj %
Remarks.....
Statement #7028 =..... #5.0
Remarks..... Enter DP tol
Statement #7029 =..... #5.0-7028
Remarks..... DP tol >5.0?
Statement #7030 =..... 7029)7028=#5.0
Remarks..... Set min DPtol
Statement #7031 =..... 8596+8795
Remarks..... 1.Sum hi cells
Statement #7032 =..... 7031/#2
Remarks..... 1.Average hi
Statement #7033 =..... 7032-8595
Remarks..... 1.Diff av H + L
Statement #7034 =..... 8596-8795
Remarks..... 1.Diff H + STBY
Statement #7035 =..... \$7033-7028
Remarks..... 1.LDP OutOfTol
Statement #7036 =..... \$7034-7028
Remarks..... 1.HDP OutOfTol
Statement #7037 =..... 8696+8796
Remarks..... 2.Sum hi cells
Statement #7038 =..... 7037/#2
Remarks..... 2.Average hi
Statement #7039 =..... 7038-8695
Remarks..... 2.Diff av H + L
Statement #7040 =..... 8696-8796
Remarks..... 2.Diff H + STBY
Statement #7041 =..... \$7039-7028
Remarks..... 2.LDP OutOfTol
Statement #7042 =..... \$7040-7028
Remarks..... 2.HDP OutOfTol
Statement #7043 =.....
Remarks.....
Statement #7044 =..... 7802

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 08
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Set odour flow
Statement #7045 =..... 1069)7044=7085
Remarks..... LGT-low flow
Statement #7046 =..... 1055)7044=7086
Remarks..... LGT-Met Susp
Statement #7047 =..... 7025)7044=7087
Remarks..... LGT-fix flow
Statement #7048 =..... 7107-#80
Remarks..... 1. Hi den?
Statement #7049 =..... #24-7107
Remarks..... 1. Low den?
Statement #7050 =.....
Remarks.....
Statement #7051 =..... 7207-#80
Remarks..... 2. Hi den?
Statement #7052 =..... #24-7207
Remarks..... 2. Low den?
Statement #7053 =.....
Remarks.....
Statement #7054 =..... 7141-#0.7
Remarks..... RD hi?
Statement #7055 =..... #0.5-7141
Remarks..... RD low?
Statement #7056 =.....
Remarks.....
Statement #7057 =.....
Remarks.....
Statement #7058 =..... 7854=7138*17002
Remarks..... St mass fl limit
Statement #7059 =..... 7854=7854/#1000
Remarks..... Convert to ton/h
Statement #7060 =..... 7162=7854/#2
Remarks..... 1. Mass flow lim
Statement #7061 =..... 7262=7854/#2
Remarks..... 2. Mass flow lim
Statement #7062 =..... 7151=#.0009*7158
Remarks..... 1. Set DP cutoff
Statement #7063 =..... 7251=#.0009*7258
Remarks..... 2. Set DP cutoff
Statement #7064 =.....
Remarks.....
Statement #7065 =.....
Remarks.....
Statement #7066 =.....
Remarks.....
Statement #7067 =..... 7802*#0.000024
Remarks..... St vol MSCM/D
Statement #7068 =..... 7804*#0.024
Remarks..... St. energy MMJ/D
Statement #7069 =..... 7802/17002*#100
Remarks..... %Max flow
Statement #7070 =..... 17002*#0.000024
Remarks..... Max vol MSCM/D
Statement #7071 =..... 7070*#44

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 09
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Max energy MMJ/D
Statement #7072 =..... 7068/7071*#100
Remarks..... %Energy for tele
Statement #7073 =..... 7044/17004*#100
Remarks..... %Odour
Statement #7074 =.....
Remarks.....
Statement #7075 =.....
Remarks.....
Statement #7076 =..... 17049=17025
Remarks..... Set counter A
Statement #7077 =..... 17050=#10*17049
Remarks..... Set counter B
Statement #7078 =..... 7152=7158/#-200
Remarks..... 1. DP low limit
Statement #7079 =..... 7153=7158+\$7152
Remarks..... 1. DP hi limit
Statement #7080 =..... 7252=7258/#-200
Remarks..... 2. DP low limit
Statement #7081 =..... 7253=7258+\$7252
Remarks..... 2. DP hi limit
Statement #7082 =..... 7352=7358/#-200
Remarks..... 3. DP low limit
Statement #7083 =..... 7353=7358+\$7352
Remarks..... 3. DP hi limit
Statement #7084 =.....
Remarks.....
Statement #7085 =..... 7027/#100*17004
Remarks..... LGT low flow inj
Statement #7086 =..... /1055)7086=7044
Remarks..... Store LGT output
Statement #7087 =..... 7026/#100*17004
Remarks..... LGT fix flow
Statement #7088 =.....
Remarks.....

----- CONFIG USER DISPLAYS
User Display Number 1 Key Press..... F
1st Variable Tag..... MSCM/D
Point #..... 7067
Dec. Places..... 6
2nd Variable Tag..... MMJ/D
Point #..... 7068
Dec. Places..... 6
3rd Variable Tag..... %Max flw
Point #..... 7069
Dec. Places..... 2
4th Variable Tag..... %Odour
Point #..... 7073
Dec. Places..... 2
User Display Number 2 Key Press..... IO
1st Variable Tag..... RD
Point #..... 7141

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 10
=====

----- CONFIG USER DISPLAYS
(Cont'd)
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7138
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7107
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7142
Dec. Places..... 7
User Display Number 3 Key Press..... IP
1st Variable Tag..... RD
Point #..... 7241
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7238
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7207
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7242
Dec. Places..... 7
User Display Number 4 Key Press..... VER
1st Variable Tag..... 02_71_V2
Point #..... 0
Dec. Places..... 0
2nd Variable Tag..... LGTcutoff
Point #..... 7027
Dec. Places..... 2
3rd Variable Tag..... 25/08/98
Point #..... 0
Dec. Places..... 0
4th Variable Tag..... 0
Dec. Places..... 0
User Display Number 5 Key Press..... FO
1st Variable Tag..... acmh
Point #..... 7101
Dec. Places..... 3
2nd Variable Tag..... scmh
Point #..... 7102
Dec. Places..... 3
3rd Variable Tag..... tons/hr
Point #..... 7103
Dec. Places..... 7
4th Variable Tag..... GJ/hr
Point #..... 7104
Dec. Places..... 3
User Display Number 6 Key Press..... FP
1st Variable Tag..... acmh
Point #..... 7201
Dec. Places..... 3
2nd Variable Tag..... scmh

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 11
=====

----- CONFIG USER DISPLAYS (Cont'd)

	Point #.....	7202
	Dec. Places.....	3
3rd Variable	Tag.....	tons/hr
	Point #.....	7203
	Dec. Places.....	7
4th Variable	Tag.....	GJ/hr
	Point #.....	7204
	Dec. Places.....	3
User Display Number 7	Key Press.....	DPO
1st Variable	Tag.....	Low DP
	Point #.....	8595
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8596
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8795
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7032
	Dec. Places.....	4
User Display Number 8	Key Press.....	DPP
1st Variable	Tag.....	Low DP
	Point #.....	8695
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8696
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8796
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7038
	Dec. Places.....	4

----- CONFIG DIGITAL I/O

Digital Point #1	Assign.....	1802
	Remarks.....	Integ St Vol.
	Pulse Width.....	20
	Pulses/Unit.....	.001
Digital Point #2	Assign.....	1072
	Remarks.....	Meter Suspect
	Delay On.....	10
	Delay Off.....	10
Digital Point #3	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #4	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #5	Assign.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 12
=====

----- CONFIG DIGITAL I/O (Cont'd)

Digital Point #6	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #7	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #8	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #9	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #10	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #11	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	
Digital Point #12	Assign.....	0
Remarks.....		
Delay On.....	0	
Delay Off.....	0	

----- CONFIG SERIAL I/O

Serial I/O #1	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Port Type.....	Printer
Serial I/O #2	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Protocol Type.....	Modbus RTU(Modem)
	Modbus ID.....	1
	Modicon Compatible.....	NO
	CRC Enabled.....	YES
Serial I/O #3	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 13
=====

----- CONFIG SERIAL I/O (Cont'd)

Protocol Type.....	Modbus ASCII
Modbus ID.....	1
Modicon Compatible.....	YES
CRC Enabled.....	YES
Serial I/O #4 Baud Rate.....	9600
Stop Bits.....	1 Bit
Data Bits.....	8
Parity.....	None
Xmit Key Delay.....	0ms
Protocol Type.....	Modbus RTU
Modbus ID.....	0
Modicon Compatible.....	YES
CRC Enabled.....	YES

----- MODBUS PEER/PEER COMMUNICATIONS

Activate Redundancy Mode.....	NO
Next Master in Sequence.....	0
Last Master in Sequence.....	0
Retry Timer (50 mS Ticks).....	0
Transaction #1 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #2 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #3 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #4 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #5 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #6 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #7 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 14
=====

----- MODBUS PEER/PEER COMMUNICATIONS (Cont'd)

Dest. Point #.....	0
Transaction #8 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #9 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #10 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #11 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #12 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #13 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #14 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #15 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #16 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0

----- CUSTOM MODBUS PACKET(ADDR:001)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 15
=====

----- CUSTOM MODBUS PACKET(ADDR:001) (Cont'd)

	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0
Packet #09	Pnt.#.....	0
	# of Points.....	0
Packet #10	Pnt.#.....	0
	# of Points.....	0
Packet #11	Pnt.#.....	0
	# of Points.....	0
Packet #12	Pnt.#.....	0
	# of Points.....	0
Packet #13	Pnt.#.....	0
	# of Points.....	0
Packet #14	Pnt.#.....	0
	# of Points.....	0
Packet #15	Pnt.#.....	0
	# of Points.....	0
Packet #16	Pnt.#.....	0
	# of Points.....	0
Packet #17	Pnt.#.....	0
	# of Points.....	0
Packet #18	Pnt.#.....	0
	# of Points.....	0
Packet #19	Pnt.#.....	0
	# of Points.....	0
Packet #20	Pnt.#.....	0
	# of Points.....	0

----- CUSTOM MODBUS PACKET(ADDR:201)

Packet #01	Pnt.#.....	0
	# of Points.....	0
Packet #02	Pnt.#.....	0
	# of Points.....	0
Packet #03	Pnt.#.....	0
	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 16
=====

----- CUSTOM MODBUS PACKET(ADDR:401)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Packet #17 Pnt.#.....	0
# of Points.....	0
Packet #18 Pnt.#.....	0
# of Points.....	0
Packet #19 Pnt.#.....	0
# of Points.....	0
Packet #20 Pnt.#.....	0
# of Points.....	0

----- ARCHIVE 701 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 17
=====

----- ARCHIVE 701 - RECORD DEFINITION (Cont'd)

Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 702 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 18
=====

----- ARCHIVE 702 - RECORD DEFINITION (Cont'd)
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 703 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 704 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 19
=====

----- ARCHIVE 704 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 705 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 20
=====

----- ARCHIVE 705 - RECORD DEFINITION (Cont'd)

Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 706 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 707 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 21
=====

----- ARCHIVE 707 - RECORD DEFINITION (Cont'd)

Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 708 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 22
=====

----- ARCHIVE 708 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 709 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 23
=====

----- ARCHIVE 710 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- CONFIG AB PLC BLOCK#1 READ

Start Address of Data Block #1.....	9
Item #1 Source Point #.....	8
# of Points.....	10
Item #2 Source Point #.....	11
# of Points.....	2
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	3
Item #6 Source Point #.....	4
# of Points.....	6
Item #7 Source Point #.....	7
# of Points.....	1
Item #8 Source Point #.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 24
=====

----- CONFIG AB PLC BLOCK#1 READ
of Points..... 0
Item #9 Source Point #..... 0
of Points..... 0
Item #10 Source Point #..... 0
of Points..... 0
Item #11 Source Point #..... 17
of Points..... 18
Item #12 Source Point #..... 0
of Points..... 0
Item #13 Source Point #..... 0
of Points..... 0
Item #14 Source Point #..... 0
of Points..... 0
Item #15 Source Point #..... 0
of Points..... 0
Item #16 Source Point #..... 0
of Points..... 0

(Cont'd)

----- CONFIG AB PLC BLOCK#2 READ
Start Address of Data Block #2..... 0
Item #1 Source Point #..... 0
of Points..... 0
Item #2 Source Point #..... 0
of Points..... 0
Item #3 Source Point #..... 0
of Points..... 0
Item #4 Source Point #..... 0
of Points..... 0
Item #5 Source Point #..... 0
of Points..... 0
Item #6 Source Point #..... 0
of Points..... 0
Item #7 Source Point #..... 0
of Points..... 0
Item #8 Source Point #..... 0
of Points..... 0
Item #9 Source Point #..... 0
of Points..... 0
Item #10 Source Point #..... 0
of Points..... 0
Item #11 Source Point #..... 0
of Points..... 0
Item #12 Source Point #..... 0
of Points..... 0
Item #13 Source Point #..... 0
of Points..... 0
Item #14 Source Point #..... 0
of Points..... 0
Item #15 Source Point #..... 0
of Points..... 0
Item #16 Source Point #..... 0
of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 25
=====

----- CONFIG AB PLC BLOCK#3 READ

Start Address of Data Block #3.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC COMMAND BLOCK

Start Address of Command Block	0
Item #1 Dest. Point #.....	0
# of Points.....	0
Item #2 Dest. Point #.....	0
# of Points.....	0
Item #3 Dest. Point #.....	0
# of Points.....	0
Item #4 Dest. Point #.....	0
# of Points.....	0
Item #5 Dest. Point #.....	0
# of Points.....	0
Item #6 Dest. Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 26
=====

----- CONFIG AB PLC SETPOINT BLOCK
Start Address of Command Block..... 0
 Item #1 Dest. Point #..... 0
 # of Points..... 0
 Item #2 Dest. Point #..... 0
 # of Points..... 0
 Item #3 Dest. Point #..... 0
 # of Points..... 0
 Item #4 Dest. Point #..... 0
 # of Points..... 0
 Item #5 Dest. Point #..... 0
 # of Points..... 0
 Item #6 Dest. Point #..... 0
 # of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 27
=====

----- PRINTER SETUP

Computer ID.....	62823
Print Interval in Minutes.....	0
Print Interval Start Time.....	18:00:00
Daily Report Time.....	06:00:00
Disable Daily Report.....	YES
Day Light Savings Start.....	00/00/00
Day Light Savings End.....	00/00/00
Clear Daily Totals at Batch End.....	YES
Auto Hourly Batch Select.....	NO
Auto Weekly Batch Select.....	No Batch End
Auto Monthly Batch Select.....	0
Print Priority.....	0
Number of Nulls.....	0
Use Default Report Template.....	NO
Printer Condensed Mode String.....	
Printer Normal Mode String.....	
Company Name	
TRANSCO part of Lattice Group plc	
Location	
Sunny Blackrod	

----- ANALYSER SETUP

Analyser ID Number.....	1
Analyser Type.....	DANALYZER
Results Interval (Minutes).....	4
Listen Only Mode (Y or N).....	NO
GC Fail Code.....	Always use
GC Comp. # for Methane (CH4).....	0
GC Comp. # for Nitrogen (N2).....	0
GC Comp. # for Carbon Dioxide (CO2).....	0
GC Comp. # for Ethane (C2H6).....	0
GC Comp. # for Propane (C3H8).....	0
GC Comp. # for Water (H2O).....	0
GC Comp. # for Hydrogen Sulfide (H2S).....	0
GC Comp. # for Hydrogen (H2).....	0
GC Comp. # for Carbon Monoxide (CO).....	0
GC Comp. # for Oxygen (O2).....	0
GC Comp. # for i-Butane (iC4H10).....	0
GC Comp. # for n-Butane (nC4H10).....	0
GC Comp. # for i-Pentane (iC5H12).....	0
GC Comp. # for n-Pentane (nC5H12).....	0
GC Comp. # for n-Hexane (C6H14).....	0
GC Comp. # for n-Heptane (C7H16).....	0
GC Comp. # for n-Octane (C8H16).....	0
GC Comp. # for n-Nonane.....	0
GC Comp. # for n-Decane.....	0
GC Comp. # for Helium (He).....	0
GC Comp. # for Argon (Ar).....	0
GC Comp. # for Heating Value.....	0
GC Comp. # for Specific Gravity.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 28
=====

----- PID CONTROL SETUP
Loop #1 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #2 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #3 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #4 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 29
=====

----- PID CONTROL SETUP (Cont'd)

Minimum Ramp To %.....	0
Primary Setpoint Low Limit.....	0
High Limit.....	0
Zero Value.....	0
Full Scale Value.....	0
Secondary Var Zero Value.....	0
Full Scale Value.....	0

----- GRAV/DENSITY SETUP

----- TEMP/PRESS SETUP

Temp #1 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Temp #2 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Press #1 Low Alarm Limit.....	35
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds
Press #2 Low Alarm Limit.....	30
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds

----- DIFF. PRESSURE SETUP

Diff Pressure #1 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail
Low DP at 4mA.....	0
Low DP at 20mA.....	50
Damping Code.....	0.0 Seconds
High DP at 4mA.....	0
High DP at 20mA.....	500
Damping Code.....	0.0 Seconds
High DP Select %.....	95
Low DP Select %.....	9
Diff Pressure #2 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 30
=====

----- DIFF. PRESSURE SETUP (Cont'd)
Low DP at 4mA..... 0
Low DP at 20mA..... 50
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 95
Low DP Select %..... 9
Diff Pressure #3 Low Alarm Limit..... -2.5
Hi Alarm Limit..... 502.5
Override Value..... 0
Override Code..... Avg on fail
Low DP at 4mA..... 0
Low DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 0
Low DP Select %..... 0

----- STATION SG/N2 ETC SETUP
Station ID..... Blackrod
Flow Low Limit (Tons/Hr)..... 0
Flow High Limit (Tons/Hr)..... 862.0438
Gross Flowrate Full Scale..... 0
Mass Flowrate Full Scale..... 0
Run Switch Mode..... Manual
Run Switch Time..... 0
Run Switch Threshold Low %DP..... 0
Run Switch Threshold High %DP..... 0

----- METER RUN SETUP
Meter #1 Meter ID..... 9741/MTA
Analysis Selected..... Product #1
Analyzer Stream Number..... 3
Flow Low Limit..... 0
Flow High Limit..... 431.0219
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.156
Orifice Reference Temp..... 21
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.1738
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO
Meter #2 Meter ID..... 8171/MTB

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 31
=====

----- METER RUN SETUP (Cont'd)
Analysis Selected..... Product #1
Analyzer Stream Number..... 1
Flow Low Limit..... 0
Flow High Limit..... 431.0219
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.6744
Orifice Reference Temp..... 20
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.2849
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

Meter #3 Meter ID.....
Analysis Selected..... Product #1
Analyzer Stream Number..... 0
Flow Low Limit..... 0
Flow High Limit..... 0
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... 0
Orifice Measured Dia..... 0
Orifice Reference Temp..... 0
Orifice Expansion Coef..... 0.000000E+000
Pipe Measured Dia..... 0
Pipe Reference Temp..... 0
Pipe Expansion Coef..... 0.000000E+000
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... YES
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

----- FACTOR SETUP & SYS CONSTANTS
Atmospheric Pressure (absolute)..... 1.01325
Base Pressure (absolute)..... 1.01325
Base Temperature..... 15
Density of Air..... 1.225410
Flow Average Factor..... 0
Alarm Deadband %..... 2.00
Roll All Totalizers..... 9 Digits
Gross Totalizer Decimal Places..... 0
Net Totalizer Decimal Places..... 0
Mass Totalizer Decimal Places..... 0
Energy Totalizer Decimal Places..... 0
Select Averaging Method..... Flow Weighted
Select Pressure Units..... Bar
Select DP Units..... Milli Bar

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 32
=====

----- FLUID DATA & ANALYSIS

Prod #1 Fluid Name.....
 Fluid Type Select (F1=Help)..... Natural Gas
 Viscosity in pa.s..... .0000119
 Isentropic Exponent..... 1.3257
 AGA-8 Method (F1=Help)..... 94 Detailed
 Heating Value Method (F1=Help)..... ISO 6976
 Heating Value MJ/NM3..... 38.883
 Specific Gravity..... 0.6341
 1994-01 % Methane (CH4)..... 87.9784
 1994-02 % Nitrogen (N2)..... 3.0080
 1994-03 % Carbon Dioxide (CO2)..... 1.7608
 1994-04 % Ethane (C2H6)..... 5.2067
 1994-05 % Propane (C3H8)..... 1.3992
 1994-06 % Water (H2O)..... 0.0000
 1994-07 % Hydrogen Sulfide (H2S)..... 0.0000
 1994-08 % Hydrogen (H2)..... 0.0000
 1994-09 % Carbon Monoxide (CO)..... 0.0000
 1994-10 % Oxygen (O2)..... 0.0000
 1994-11 % i-Butane (iC4H10)..... 0.1678
 1994-12 % n-Butane (nC4H10)..... 0.2721
 1994-13 % i-Pentane (iC5H12)..... 0.0757
 1994-14 % n-Pentane (nC5H12)..... 0.0676
 1994-15 % n-Hexane (C6H14)..... 0.0636
 1994-16 % n-Heptane (C7H16)..... 0.0000
 1994-17 % n-Octane (C8H16)..... 0.0000
 1994-18 % n-Nonane..... 0.0000
 1994-19 % n-Decane..... 0.0000
 1994-20 % Helium (He)..... 0.0000
 1994-21 % Argon (Ar)..... 0.0000

Prod #2 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 38.883

Prod #3 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 0

Prod #4 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density Lb/Ft3..... 0
 Viscosity in Centipoise..... 0
 Isentropic Exponent..... 0
 Heating Value Btu/Scf..... 0

TABLE B.4 CONFIGURATION DATA REPORT 15/07/2008

```
=====
CONFIGURATION DATA REPORT : [ BLAN0715.OMI ]  
  
COMPANY NAME : TRANSCO part of Lattice Group plc  
LOCATION : Sunny Blackrod  
COMPUTER ID : 62823  
  
CURRENT DATE : 3-31-2010 TIME : 12:15a  
CONFIGURATION FILE : LAST MODIFIED  
=====  
  
----- CHECK I/O MODULE CONFIG  
OMNI Flow Computer Model Number..... OMNI 6000  
Number of TYPE A Modules Installed..... 3  
Number of TYPE B Modules Installed..... 0  
Number of TYPE C Modules Installed..... 0  
Number of TYPE E Modules Installed..... 0  
Number of TYPE E/D Modules Installed..... 0  
Number of TYPE H Modules Installed..... 0  
Number of DIGITAL Modules Installed..... 1  
Number of SERIAL Modules Installed..... 2  
  
----- FLOW COMPUTER TIME & DATE  
OMNI Time..... 13:46:07  
OMNI Date..... 15/07/08  
Select Date Type..... dd/mm/yy  
  
----- CONFIG STATION DATA  
Station Totals and Flows Defined As:..... 1+2  
Reference Gravity.I/O Pnt#..... 0  
    Tag.....  
    Type..... 4-20 mA  
Nitrogen % I/O Pnt#..... 0  
    Tag.....  
Carbon Dioxide I/O Pnt#..... 0  
    Tag.....  
Heating Value I/O Pnt#..... 0  
    Tag.....  
Auxiliary Input #1 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #2 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #3 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #4 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
  
----- CONFIG METER RUNS  
Meter #1 Select Turbine Y/N..... NO  
    DP Low Range I/O Pnt#..... 3  
        Tag..... DPLR-1
```

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 02
=====

----- CONFIG METER RUNS
(Cont'd)
DP High Range I/O Pnt#..... 4
Tag..... DPHR-1
Temp I/O Pnt#..... 1
Tag..... FT-1
Type..... DIN Rtd
Pres I/O Pnt#..... 2
Tag..... FP-1
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #2 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 7
Tag..... DPRL-2
DP High Range I/O Pnt#..... 8
Tag..... DPHR-2
Temp I/O Pnt#..... 5
Tag..... FT-2
Type..... DIN Rtd
Pres I/O Pnt#..... 6
Tag..... FP-2
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #3 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 11
Tag..... DPST-1
DP High Range I/O Pnt#..... 12
Tag..... DPST-2
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #4 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 0
Tag.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 03
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 0
Tag.....
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....

----- CONFIG PID LOOPS
Loop #1 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #2 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #3 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #4 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 04
=====

----- CONFIG PID LOOPS (Cont'd)
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....

----- CONFIG D/A OUT
D/A Output #01 Assign..... 7802
Remarks..... Station scm/hr
@ 4 ma..... 0
@ 20 ma..... 1109405
D/A Output #02 Assign..... 7044
Remarks..... Odorant scm/hr
@ 4 ma..... 0
@ 20 ma..... 1109405
D/A Output #03 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0
D/A Output #04 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0
D/A Output #05 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0
D/A Output #06 Assign..... 0
Remarks.....
@ 4 ma..... 0
@ 20 ma..... 0

----- CONFIG FRONT PANEL COUNTERS
Front Panel Counter A Assign..... 1802
Remark..... Stream 1 st vol
Pulses/Unit..... .001
Front Panel Counter B Assign..... 1804
Remark..... Stream 1 ene flo
Pulses/Unit..... .01
Front Panel Counter C Assign..... 0
Remark.....
Pulses/Unit..... 0

----- CONFIGURE BOOLEAN STATEMENTS
Boolean #1025 =..... 1811
Remarks..... Hi flow alrm
Boolean #1026 =..... /1829+1837
Remarks..... Power/EPROM fail
Boolean #1027 =..... 7054+7055
Remarks..... RD alarm
Boolean #1028 =..... 1125+1126
Remarks..... 1. L/H T alrm

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 05
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)

Boolean #1029 =.....	1129+1130
Remarks.....	1. L/H P alrm
Boolean #1030 =.....	1141+1142
Remarks.....	1. L/H DP alarm
Boolean #1031 =.....	1341+1342
Remarks.....	1. L/H STBY alrm
Boolean #1032 =.....	7035&1152
Remarks.....	1. LDP OutOfTol
Boolean #1033 =.....	7036&1153
Remarks.....	1. HDP OutOfTol
Boolean #1034 =.....	7048+7049
Remarks.....	1. Density alrm
Boolean #1035 =.....	
Remarks.....	
Boolean #1036 =.....	1225+1226
Remarks.....	2. L/H T alrm
Boolean #1037 =.....	1229+1230
Remarks.....	2. L/H P alrm
Boolean #1038 =.....	1241+1242
Remarks.....	2. L/H DP alrm
Boolean #1039 =.....	1341+1342
Remarks.....	2. L/H STDP alrm
Boolean #1040 =.....	7041&1252
Remarks.....	2. LDP OutOfTol
Boolean #1041 =.....	7042&1253
Remarks.....	2. HDP OutOfTol
Boolean #1042 =.....	7051+7052
Remarks.....	2. Density
Boolean #1043 =.....	
Remarks.....	
Boolean #1044 =.....	1025+1026+1027
Remarks.....	General
Boolean #1045 =.....	1028+1029+1030
Remarks.....	1.
Boolean #1046 =.....	1031+1032+1033
Remarks.....	1.
Boolean #1047 =.....	1034
Remarks.....	1.
Boolean #1048 =.....	1036+1037+1038
Remarks.....	2.
Boolean #1049 =.....	1039+1040+1041
Remarks.....	2.
Boolean #1050 =.....	1042
Remarks.....	2.
Boolean #1051 =.....	1045+1046+1047
Remarks.....	1. Combined
Boolean #1052 =.....	1048+1049+1050
Remarks.....	2. Combined
Boolean #1053 =.....	1051&1105
Remarks.....	1. in use?
Boolean #1054 =.....	1052&1205
Remarks.....	2. in use?
Boolean #1055 =.....	1044+1053+1054
Remarks.....	Meter Suspect

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 06
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1056 =..... Remarks.....
Boolean #1057 =..... 1088=1070 Remarks..... Maintenance
Boolean #1058 =..... 1087=1055 Remarks..... Meter Suspect
Boolean #1059 =..... 1086=1027 Remarks..... RD error
Boolean #1060 =..... 1085=1034 Remarks..... 1. Density error
Boolean #1061 =..... 1084=1032 Remarks..... 1. Low DP error
Boolean #1062 =..... 1083=1033 Remarks..... 1. High DP error
Boolean #1063 =..... 1082=1042 Remarks..... 2. Density error
Boolean #1064 =..... 1081=1040 Remarks..... 2. Low DP error
Boolean #1065 =..... 1080=1041 Remarks..... 2. High DP error
Boolean #1066 =..... Remarks.....
Boolean #1067 =..... Remarks.....
Boolean #1068 =..... Remarks.....
Boolean #1069 =..... /1105&/1205 Remarks..... No flow if = 1
Boolean #1070 =..... 7025 Remarks..... Maintenance mode
Boolean #1071 =..... 1027 Remarks..... Spare
Boolean #1072 =..... /1055 Remarks..... Invert met susp
Boolean #1073 =..... 1736=/1105 Remarks..... 1. Disable flow
Boolean #1074 =..... 1737=/1205 Remarks..... 2. Disable flow
Boolean #1075 =..... Remarks..... Den #3 alarm
Boolean #1076 =..... Remarks..... Den #4 alarm
Boolean #1077 =..... Remarks.....
Boolean #1078 =..... Remarks.....
Boolean #1079 =..... Remarks.....
Boolean #1080 =..... M2 HDP OutOfTol Remarks.....
Boolean #1081 =..... M2 LDP OutOfTol Remarks.....
Boolean #1082 =..... M2 Den OutOfTol Remarks.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 07
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1083 =..... M1 HDP OutOfTol
Remarks.....
Boolean #1084 =..... M1 LDP OutOfTol
Remarks.....
Boolean #1085 =..... M1 Den OutOfTol
Remarks.....
Boolean #1086 =..... RD OutOfTol
Remarks.....
Boolean #1087 =..... Meter Suspect
Remarks.....
Boolean #1088 =..... Maintenance
Remarks.....

----- CONFIGURE VARIABLE STATEMENTS
Statement #7025 =..... Main:-1=Off,1=On
Remarks.....
Statement #7026 =..... LGT Fix Output %
Remarks.....
Statement #7027 =..... LGT lo flo inj %
Remarks.....
Statement #7028 =..... #5.0
Remarks..... Enter DP tol
Statement #7029 =..... #5.0-7028
Remarks..... DP tol >5.0?
Statement #7030 =..... 7029)7028=#5.0
Remarks..... Set min DPtol
Statement #7031 =..... 8596+8795
Remarks..... 1.Sum hi cells
Statement #7032 =..... 7031/#2
Remarks..... 1.Average hi
Statement #7033 =..... 7032-8595
Remarks..... 1.Diff av H + L
Statement #7034 =..... 8596-8795
Remarks..... 1.Diff H + STBY
Statement #7035 =..... \$7033-7028
Remarks..... 1.LDP OutOfTol
Statement #7036 =..... \$7034-7028
Remarks..... 1.HDP OutOfTol
Statement #7037 =..... 8696+8796
Remarks..... 2.Sum hi cells
Statement #7038 =..... 7037/#2
Remarks..... 2.Average hi
Statement #7039 =..... 7038-8695
Remarks..... 2.Diff av H + L
Statement #7040 =..... 8696-8796
Remarks..... 2.Diff H + STBY
Statement #7041 =..... \$7039-7028
Remarks..... 2.LDP OutOfTol
Statement #7042 =..... \$7040-7028
Remarks..... 2.HDP OutOfTol
Statement #7043 =.....
Remarks.....
Statement #7044 =..... 7802

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 08
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Set odour flow
Statement #7045 =..... 1069)7044=7085
Remarks..... LGT-low flow
Statement #7046 =..... 1055)7044=7086
Remarks..... LGT-Met Susp
Statement #7047 =..... 7025)7044=7087
Remarks..... LGT-fix flow
Statement #7048 =..... 7107-#80
Remarks..... 1. Hi den?
Statement #7049 =..... #24-7107
Remarks..... 1. Low den?
Statement #7050 =.....
Remarks.....
Statement #7051 =..... 7207-#80
Remarks..... 2. Hi den?
Statement #7052 =..... #24-7207
Remarks..... 2. Low den?
Statement #7053 =.....
Remarks.....
Statement #7054 =..... 7141-#0.7
Remarks..... RD hi?
Statement #7055 =..... #0.5-7141
Remarks..... RD low?
Statement #7056 =.....
Remarks.....
Statement #7057 =.....
Remarks.....
Statement #7058 =..... 7854=7138*17002
Remarks..... St mass fl limit
Statement #7059 =..... 7854=7854/#1000
Remarks..... Convert to ton/h
Statement #7060 =..... 7162=7854/#2
Remarks..... 1. Mass flow lim
Statement #7061 =..... 7262=7854/#2
Remarks..... 2. Mass flow lim
Statement #7062 =..... 7151=#.0009*7158
Remarks..... 1. Set DP cutoff
Statement #7063 =..... 7251=#.0009*7258
Remarks..... 2. Set DP cutoff
Statement #7064 =.....
Remarks.....
Statement #7065 =.....
Remarks.....
Statement #7066 =.....
Remarks.....
Statement #7067 =..... 7802*#0.000024
Remarks..... St vol MSCM/D
Statement #7068 =..... 7804*#0.024
Remarks..... St. energy MMJ/D
Statement #7069 =..... 7802/17002*#100
Remarks..... %Max flow
Statement #7070 =..... 17002*#0.000024
Remarks..... Max vol MSCM/D
Statement #7071 =..... 7070*#44

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 09
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Max energy MMJ/D
Statement #7072 =..... 7068/7071*#100
Remarks..... %Energy for tele
Statement #7073 =..... 7044/17004*#100
Remarks..... %Odour
Statement #7074 =.....
Remarks.....
Statement #7075 =.....
Remarks.....
Statement #7076 =..... 17049=17025
Remarks..... Set counter A
Statement #7077 =..... 17050=#10*17049
Remarks..... Set counter B
Statement #7078 =..... 7152=7158/#-200
Remarks..... 1. DP low limit
Statement #7079 =..... 7153=7158+\$7152
Remarks..... 1. DP hi limit
Statement #7080 =..... 7252=7258/#-200
Remarks..... 2. DP low limit
Statement #7081 =..... 7253=7258+\$7252
Remarks..... 2. DP hi limit
Statement #7082 =..... 7352=7358/#-200
Remarks..... 3. DP low limit
Statement #7083 =..... 7353=7358+\$7352
Remarks..... 3. DP hi limit
Statement #7084 =.....
Remarks.....
Statement #7085 =..... 7027/#100*17004
Remarks..... LGT low flow inj
Statement #7086 =..... /1055)7086=7044
Remarks..... Store LGT output
Statement #7087 =..... 7026/#100*17004
Remarks..... LGT fix flow
Statement #7088 =.....
Remarks.....

----- CONFIG USER DISPLAYS
User Display Number 1 Key Press..... F
1st Variable Tag..... MSCM/D
Point #..... 7067
Dec. Places..... 6
2nd Variable Tag..... MMJ/D
Point #..... 7068
Dec. Places..... 6
3rd Variable Tag..... %Max flw
Point #..... 7069
Dec. Places..... 2
4th Variable Tag..... %Odour
Point #..... 7073
Dec. Places..... 2
User Display Number 2 Key Press..... IO
1st Variable Tag..... RD
Point #..... 7141

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 10
=====

----- CONFIG USER DISPLAYS
(Cont'd)
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7138
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7107
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7142
Dec. Places..... 7
User Display Number 3 Key Press..... IP
1st Variable Tag..... RD
Point #..... 7241
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7238
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7207
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7242
Dec. Places..... 7
User Display Number 4 Key Press..... VER
1st Variable Tag..... 02_71_V2
Point #..... 0
Dec. Places..... 0
2nd Variable Tag..... LGTcutoff
Point #..... 7027
Dec. Places..... 2
3rd Variable Tag..... 25/08/98
Point #..... 0
Dec. Places..... 0
4th Variable Tag..... 0
Dec. Places..... 0
User Display Number 5 Key Press..... FO
1st Variable Tag..... acmh
Point #..... 7101
Dec. Places..... 3
2nd Variable Tag..... scmh
Point #..... 7102
Dec. Places..... 3
3rd Variable Tag..... tons/hr
Point #..... 7103
Dec. Places..... 7
4th Variable Tag..... GJ/hr
Point #..... 7104
Dec. Places..... 3
User Display Number 6 Key Press..... FP
1st Variable Tag..... acmh
Point #..... 7201
Dec. Places..... 3
2nd Variable Tag..... scmh

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 11
=====

----- CONFIG USER DISPLAYS (Cont'd)

	Point #.....	7202
	Dec. Places.....	3
3rd Variable	Tag.....	tons/hr
	Point #.....	7203
	Dec. Places.....	7
4th Variable	Tag.....	GJ/hr
	Point #.....	7204
	Dec. Places.....	3
User Display Number 7	Key Press.....	DPO
1st Variable	Tag.....	Low DP
	Point #.....	8595
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8596
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8795
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7032
	Dec. Places.....	4
User Display Number 8	Key Press.....	DPP
1st Variable	Tag.....	Low DP
	Point #.....	8695
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8696
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8796
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7038
	Dec. Places.....	4

----- CONFIG DIGITAL I/O

Digital Point #1	Assign.....	1802
	Remarks.....	Integ St Vol.
	Pulse Width.....	20
	Pulses/Unit.....	.001
Digital Point #2	Assign.....	1072
	Remarks.....	Meter Suspect
	Delay On.....	10
	Delay Off.....	10
Digital Point #3	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #4	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #5	Assign.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 12
=====

----- CONFIG DIGITAL I/O (Cont'd)

	Remarks.....
Digital Point #6	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #7	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #8	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #9	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #10	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #11	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0
Digital Point #12	Assign.....	0
	Remarks.....
	Delay On.....	0
	Delay Off.....	0

----- CONFIG SERIAL I/O

Serial I/O #1	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Port Type.....	Printer
Serial I/O #2	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Protocol Type.....	Modbus RTU(Modem)
	Modbus ID.....	1
	Modicon Compatible.....	NO
	CRC Enabled.....	YES
Serial I/O #3	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 13
=====

----- CONFIG SERIAL I/O (Cont'd)

Protocol Type.....	Modbus ASCII
Modbus ID.....	1
Modicon Compatible.....	YES
CRC Enabled.....	YES
Serial I/O #4 Baud Rate.....	9600
Stop Bits.....	1 Bit
Data Bits.....	8
Parity.....	None
Xmit Key Delay.....	0ms
Protocol Type.....	Modbus RTU
Modbus ID.....	0
Modicon Compatible.....	YES
CRC Enabled.....	YES

----- MODBUS PEER/PEER COMMUNICATIONS

Activate Redundancy Mode.....	NO
Next Master in Sequence.....	0
Last Master in Sequence.....	0
Retry Timer (50 mS Ticks).....	0
Transaction #1 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #2 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #3 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #4 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #5 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #6 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #7 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 14
=====

----- MODBUS PEER/PEER COMMUNICATIONS (Cont'd)

Dest. Point #.....	0
Transaction #8 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #9 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #10 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #11 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #12 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #13 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #14 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #15 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #16 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0

----- CUSTOM MODBUS PACKET(ADDR:001)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 15
=====

----- CUSTOM MODBUS PACKET(ADDR:001) (Cont'd)

	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0
Packet #09	Pnt.#.....	0
	# of Points.....	0
Packet #10	Pnt.#.....	0
	# of Points.....	0
Packet #11	Pnt.#.....	0
	# of Points.....	0
Packet #12	Pnt.#.....	0
	# of Points.....	0
Packet #13	Pnt.#.....	0
	# of Points.....	0
Packet #14	Pnt.#.....	0
	# of Points.....	0
Packet #15	Pnt.#.....	0
	# of Points.....	0
Packet #16	Pnt.#.....	0
	# of Points.....	0
Packet #17	Pnt.#.....	0
	# of Points.....	0
Packet #18	Pnt.#.....	0
	# of Points.....	0
Packet #19	Pnt.#.....	0
	# of Points.....	0
Packet #20	Pnt.#.....	0
	# of Points.....	0

----- CUSTOM MODBUS PACKET(ADDR:201)

Packet #01	Pnt.#.....	0
	# of Points.....	0
Packet #02	Pnt.#.....	0
	# of Points.....	0
Packet #03	Pnt.#.....	0
	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 16
=====

----- CUSTOM MODBUS PACKET(ADDR:401)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Packet #17 Pnt.#.....	0
# of Points.....	0
Packet #18 Pnt.#.....	0
# of Points.....	0
Packet #19 Pnt.#.....	0
# of Points.....	0
Packet #20 Pnt.#.....	0
# of Points.....	0

----- ARCHIVE 701 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 17
=====

----- ARCHIVE 701 - RECORD DEFINITION (Cont'd)

Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 702 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 18
=====

----- ARCHIVE 702 - RECORD DEFINITION (Cont'd)
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 703 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 704 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 19
=====

----- ARCHIVE 704 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 705 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 20
=====

----- ARCHIVE 705 - RECORD DEFINITION (Cont'd)

Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 706 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 707 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 21
=====

----- ARCHIVE 707 - RECORD DEFINITION (Cont'd)

Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 708 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 22
=====

----- ARCHIVE 708 - RECORD DEFINITION (Cont'd)
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 709 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 23
=====

----- ARCHIVE 710 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- CONFIG AB PLC BLOCK#1 READ

Start Address of Data Block #1.....	9
Item #1 Source Point #.....	8
# of Points.....	10
Item #2 Source Point #.....	11
# of Points.....	2
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	3
Item #6 Source Point #.....	4
# of Points.....	6
Item #7 Source Point #.....	7
# of Points.....	1
Item #8 Source Point #.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 24
=====

----- CONFIG AB PLC BLOCK#1 READ (Cont'd)

# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	17
# of Points.....	18
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC BLOCK#2 READ

Start Address of Data Block #2.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 25
=====

----- CONFIG AB PLC BLOCK#3 READ

Start Address of Data Block #3.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC COMMAND BLOCK

Start Address of Command Block	0
Item #1 Dest. Point #.....	0
# of Points.....	0
Item #2 Dest. Point #.....	0
# of Points.....	0
Item #3 Dest. Point #.....	0
# of Points.....	0
Item #4 Dest. Point #.....	0
# of Points.....	0
Item #5 Dest. Point #.....	0
# of Points.....	0
Item #6 Dest. Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 26
=====

----- CONFIG AB PLC SETPOINT BLOCK
Start Address of Command Block..... 0
 Item #1 Dest. Point #..... 0
 # of Points..... 0
 Item #2 Dest. Point #..... 0
 # of Points..... 0
 Item #3 Dest. Point #..... 0
 # of Points..... 0
 Item #4 Dest. Point #..... 0
 # of Points..... 0
 Item #5 Dest. Point #..... 0
 # of Points..... 0
 Item #6 Dest. Point #..... 0
 # of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 27
=====

----- PRINTER SETUP

Computer ID.....	62823
Print Interval in Minutes.....	0
Print Interval Start Time.....	18:00:00
Daily Report Time.....	06:00:00
Disable Daily Report.....	YES
Day Light Savings Start.....	00/00/00
Day Light Savings End.....	00/00/00
Clear Daily Totals at Batch End.....	YES
Auto Hourly Batch Select.....	NO
Auto Weekly Batch Select.....	No Batch End
Auto Monthly Batch Select.....	0
Print Priority.....	0
Number of Nulls.....	0
Use Default Report Template.....	NO
Printer Condensed Mode String.....	
Printer Normal Mode String.....	
Company Name	
TRANSCO part of Lattice Group plc	
Location	
Sunny Blackrod	

----- ANALYSER SETUP

Analyser ID Number.....	1
Analyser Type.....	DANALYZER
Results Interval (Minutes).....	4
Listen Only Mode (Y or N).....	NO
GC Fail Code.....	Always use
GC Comp. # for Methane (CH4).....	0
GC Comp. # for Nitrogen (N2).....	0
GC Comp. # for Carbon Dioxide (CO2).....	0
GC Comp. # for Ethane (C2H6).....	0
GC Comp. # for Propane (C3H8).....	0
GC Comp. # for Water (H2O).....	0
GC Comp. # for Hydrogen Sulfide (H2S).....	0
GC Comp. # for Hydrogen (H2).....	0
GC Comp. # for Carbon Monoxide (CO).....	0
GC Comp. # for Oxygen (O2).....	0
GC Comp. # for i-Butane (iC4H10).....	0
GC Comp. # for n-Butane (nC4H10).....	0
GC Comp. # for i-Pentane (iC5H12).....	0
GC Comp. # for n-Pentane (nC5H12).....	0
GC Comp. # for n-Hexane (C6H14).....	0
GC Comp. # for n-Heptane (C7H16).....	0
GC Comp. # for n-Octane (C8H16).....	0
GC Comp. # for n-Nonane.....	0
GC Comp. # for n-Decane.....	0
GC Comp. # for Helium (He).....	0
GC Comp. # for Argon (Ar).....	0
GC Comp. # for Heating Value.....	0
GC Comp. # for Specific Gravity.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 28
=====

----- PID CONTROL SETUP
Loop #1 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #2 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #3 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #4 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 29
=====

----- PID CONTROL SETUP (Cont'd)

Minimum Ramp To %.....	0
Primary Setpoint Low Limit.....	0
High Limit.....	0
Zero Value.....	0
Full Scale Value.....	0
Secondary Var Zero Value.....	0
Full Scale Value.....	0

----- GRAV/DENSITY SETUP

----- TEMP/PRESS SETUP

Temp #1 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Temp #2 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Press #1 Low Alarm Limit.....	35
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds
Press #2 Low Alarm Limit.....	30
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds

----- DIFF. PRESSURE SETUP

Diff Pressure #1 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail
Low DP at 4mA.....	0
Low DP at 20mA.....	50
Damping Code.....	0.0 Seconds
High DP at 4mA.....	0
High DP at 20mA.....	500
Damping Code.....	0.0 Seconds
High DP Select %.....	95
Low DP Select %.....	9
Diff Pressure #2 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 30
=====

----- DIFF. PRESSURE SETUP (Cont'd)
Low DP at 4mA..... 0
Low DP at 20mA..... 50
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 95
Low DP Select %..... 9
Diff Pressure #3 Low Alarm Limit..... -2.5
Hi Alarm Limit..... 502.5
Override Value..... 0
Override Code..... Avg on fail
Low DP at 4mA..... 0
Low DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 0
Low DP Select %..... 0

----- STATION SG/N2 ETC SETUP
Station ID..... Blackrod
Flow Low Limit (Tons/Hr)..... 0
Flow High Limit (Tons/Hr)..... 858.7809
Gross Flowrate Full Scale..... 0
Mass Flowrate Full Scale..... 0
Run Switch Mode..... Manual
Run Switch Time..... 0
Run Switch Threshold Low %DP..... 0
Run Switch Threshold High %DP..... 0

----- METER RUN SETUP
Meter #1 Meter ID..... 9741/MTA
Analysis Selected..... Product #1
Analyzer Stream Number..... 3
Flow Low Limit..... 0
Flow High Limit..... 429.3905
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.3466
Orifice Reference Temp..... 20
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.1738
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO
Meter #2 Meter ID..... 8171/MTB

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 31
=====

----- METER RUN SETUP (Cont'd)
Analysis Selected..... Product #1
Analyzer Stream Number..... 1
Flow Low Limit..... 0
Flow High Limit..... 429.3905
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.6384
Orifice Reference Temp..... 19
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.2849
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

Meter #3 Meter ID.....
Analysis Selected..... Product #1
Analyzer Stream Number..... 0
Flow Low Limit..... 0
Flow High Limit..... 0
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... 0
Orifice Measured Dia..... 0
Orifice Reference Temp..... 0
Orifice Expansion Coef..... 0.000000E+000
Pipe Measured Dia..... 0
Pipe Reference Temp..... 0
Pipe Expansion Coef..... 0.000000E+000
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... YES
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

----- FACTOR SETUP & SYS CONSTANTS
Atmospheric Pressure (absolute)..... 1.01325
Base Pressure (absolute)..... 1.01325
Base Temperature..... 15
Density of Air..... 1.225410
Flow Average Factor..... 0
Alarm Deadband %..... 2.00
Roll All Totalizers..... 9 Digits
Gross Totalizer Decimal Places..... 0
Net Totalizer Decimal Places..... 0
Mass Totalizer Decimal Places..... 0
Energy Totalizer Decimal Places..... 0
Select Averaging Method..... Flow Weighted
Select Pressure Units..... Bar
Select DP Units..... Milli Bar

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 32
=====

----- FLUID DATA & ANALYSIS

Prod #1 Fluid Name.....
Fluid Type Select (F1=Help)..... Natural Gas
Viscosity in pa.s..... .0000117
Isentropic Exponent..... 1.328646
AGA-8 Method (F1=Help)..... 94 Detailed
Heating Value Method (F1=Help)..... ISO 6976
Heating Value MJ/NM3..... 39.854
Specific Gravity..... 0.6317
1994-01 % Methane (CH4)..... 88.9096
1994-02 % Nitrogen (N2)..... 1.4097
1994-03 % Carbon Dioxide (CO2)..... 1.6309
1994-04 % Ethane (C2H6)..... 5.6258
1994-05 % Propane (C3H8)..... 1.7901
1994-06 % Water (H2O)..... 0.0000
1994-07 % Hydrogen Sulfide (H2S)..... 0.0000
1994-08 % Hydrogen (H2)..... 0.0000
1994-09 % Carbon Monoxide (CO)..... 0.0000
1994-10 % Oxygen (O2)..... 0.0000
1994-11 % i-Butane (iC4H10)..... 0.1640
1994-12 % n-Butane (nC4H10)..... 0.3014
1994-13 % i-Pentane (iC5H12)..... 0.0578
1994-14 % n-Pentane (nC5H12)..... 0.0607
1994-15 % n-Hexane (C6H14)..... 0.0498
1994-16 % n-Heptane (C7H16)..... 0.0000
1994-17 % n-Octane (C8H16)..... 0.0000
1994-18 % n-Nonane..... 0.0000
1994-19 % n-Decane..... 0.0000
1994-20 % Helium (He)..... 0.0000
1994-21 % Argon (Ar)..... 0.0000

Prod #2 Fluid Name.....
Fluid Type Select (F1=Help)..... None Selected
Reference Density KG/M3..... 0
Viscosity in pa.s..... 0
Isentropic Exponent..... 0
Heating Value MJ/NM3..... 39.854

Prod #3 Fluid Name.....
Fluid Type Select (F1=Help)..... None Selected
Reference Density KG/M3..... 0
Viscosity in pa.s..... 0
Isentropic Exponent..... 0
Heating Value MJ/NM3..... 0

Prod #4 Fluid Name.....
Fluid Type Select (F1=Help)..... None Selected
Reference Density Lb/Ft3..... 0
Viscosity in Centipoise..... 0
Isentropic Exponent..... 0
Heating Value Btu/Scf..... 0

TABLE B.5 CONFIGURATION DATA REPORT 02/07/2009

```
=====
CONFIGURATION DATA REPORT : [ BLAO0702.OMI ]  
  
COMPANY NAME : TRANSCO part of Lattice Group plc  
LOCATION : Sunny Blackrod  
COMPUTER ID : 62823  
  
CURRENT DATE : 3-31-2010 TIME : 12:20a  
CONFIGURATION FILE : LAST MODIFIED  
=====  
  
----- CHECK I/O MODULE CONFIG  
OMNI Flow Computer Model Number..... OMNI 6000  
Number of TYPE A Modules Installed..... 3  
Number of TYPE B Modules Installed..... 0  
Number of TYPE C Modules Installed..... 0  
Number of TYPE E Modules Installed..... 0  
Number of TYPE E/D Modules Installed..... 0  
Number of TYPE H Modules Installed..... 0  
Number of DIGITAL Modules Installed..... 1  
Number of SERIAL Modules Installed..... 2  
  
----- FLOW COMPUTER TIME & DATE  
OMNI Time..... 10:38:44  
OMNI Date..... 02/07/09  
Select Date Type..... dd/mm/yy  
  
----- CONFIG STATION DATA  
Station Totals and Flows Defined As:..... 1+2  
Reference Gravity.I/O Pnt#..... 0  
    Tag.....  
    Type..... 4-20 mA  
Nitrogen % I/O Pnt#..... 0  
    Tag.....  
Carbon Dioxide I/O Pnt#..... 0  
    Tag.....  
Heating Value I/O Pnt#..... 0  
    Tag.....  
Auxiliary Input #1 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #2 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #3 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
Auxiliary Input #4 I/O Pnt#..... 0  
    Tag.....  
    Type..... DIN Rtd  
  
----- CONFIG METER RUNS  
Meter #1 Select Turbine Y/N..... NO  
    DP Low Range I/O Pnt#..... 3  
        Tag..... DPLR-1
```

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 02
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 4
Tag..... DPHR-1
Temp I/O Pnt#..... 1
Tag..... FT-1
Type..... DIN Rtd
Pres I/O Pnt#..... 2
Tag..... FP-1
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #2 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 7
Tag..... DPRL-2
DP High Range I/O Pnt#..... 8
Tag..... DPHR-2
Temp I/O Pnt#..... 5
Tag..... FT-2
Type..... DIN Rtd
Pres I/O Pnt#..... 6
Tag..... FP-2
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #3 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 11
Tag..... DPST-1
DP High Range I/O Pnt#..... 12
Tag..... DPST-2
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....
Meter #4 Select Turbine Y/N..... NO
DP Low Range I/O Pnt#..... 0
Tag.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 03
=====

----- CONFIG METER RUNS (Cont'd)
DP High Range I/O Pnt#..... 0
Tag.....
Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Pres I/O Pnt#..... 0
Tag.....
Dens I/O Pnt#..... 0
Tag.....
Type..... 4-20 SG
Dens Temp I/O Pnt#..... 0
Tag.....
Type..... DIN Rtd
Dens Pres I/O Pnt#..... 0
Tag.....

----- CONFIG PID LOOPS
Loop #1 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #2 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #3 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Error Select (Low/High)..... Low
Startup Mode (Last/Manual)..... Last State
Control Output Tag.....
Loop #4 Primary Variable Assign..... 0
Remark.....
Action (F/R)..... Forward
Remote Set Pt I/O Pnt#..... 0
Secondary Variable Assign..... 0
Remark.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 04
=====

----- CONFIG PID LOOPS (Cont'd)

Action (F/R).....	Forward
Error Select (Low/High).....	Low
Startup Mode (Last/Manual).....	Last State
Control Output Tag.....	

----- CONFIG D/A OUT

D/A Output #01 Assign.....	7802
Remarks.....	Station scm/hr
@ 4 ma.....	0
@ 20 ma.....	1109405
D/A Output #02 Assign.....	7044
Remarks.....	Odorant scm/hr
@ 4 ma.....	0
@ 20 ma.....	1109405
D/A Output #03 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #04 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #05 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0
D/A Output #06 Assign.....	0
Remarks.....	
@ 4 ma.....	0
@ 20 ma.....	0

----- CONFIG FRONT PANEL COUNTERS

Front Panel Counter A Assign.....	1802
Remark.....	Stream 1 st vol
Pulses/Unit.....	.001
Front Panel Counter B Assign.....	1804
Remark.....	Stream 1 ene flo
Pulses/Unit.....	.01
Front Panel Counter C Assign.....	0
Remark.....	
Pulses/Unit.....	0

----- CONFIGURE BOOLEAN STATEMENTS

Boolean #1025 =.....	1811
Remarks.....	Hi flow alrm
Boolean #1026 =.....	/1829+1837
Remarks.....	Power/EPROM fail
Boolean #1027 =.....	7054+7055
Remarks.....	RD alarm
Boolean #1028 =.....	1125+1126
Remarks.....	1. L/H T alrm

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 05
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1029 =..... 1129+1130
 Remarks..... 1. L/H P alrm
Boolean #1030 =..... 1141+1142
 Remarks..... 1. L/H DP alarm
Boolean #1031 =..... 1341+1342
 Remarks..... 1. L/H STBY alrm
Boolean #1032 =..... 7035&1152
 Remarks..... 1. LDP OutOfTol
Boolean #1033 =..... 7036&1153
 Remarks..... 1. HDP OutOfTol
Boolean #1034 =..... 7048+7049
 Remarks..... 1. Density alrm
Boolean #1035 =.....
 Remarks.....
Boolean #1036 =..... 1225+1226
 Remarks..... 2. L/H T alrm
Boolean #1037 =..... 1229+1230
 Remarks..... 2. L/H P alrm
Boolean #1038 =..... 1241+1242
 Remarks..... 2. L/H DP alrm
Boolean #1039 =..... 1341+1342
 Remarks..... 2. L/H STDP alrm
Boolean #1040 =..... 7041&1252
 Remarks..... 2. LDP OutOfTol
Boolean #1041 =..... 7042&1253
 Remarks..... 2. HDP OutOfTol
Boolean #1042 =..... 7051+7052
 Remarks..... 2. Density
Boolean #1043 =.....
 Remarks.....
Boolean #1044 =..... 1025+1026+1027
 Remarks..... General
Boolean #1045 =..... 1028+1029+1030
 Remarks..... 1.
Boolean #1046 =..... 1031+1032+1033
 Remarks..... 1.
Boolean #1047 =..... 1034
 Remarks..... 1.
Boolean #1048 =..... 1036+1037+1038
 Remarks..... 2.
Boolean #1049 =..... 1039+1040+1041
 Remarks..... 2.
Boolean #1050 =..... 1042
 Remarks..... 2.
Boolean #1051 =..... 1045+1046+1047
 Remarks..... 1. Combined
Boolean #1052 =..... 1048+1049+1050
 Remarks..... 2. Combined
Boolean #1053 =..... 1051&1105
 Remarks..... 1. in use?
Boolean #1054 =..... 1052&1205
 Remarks..... 2. in use?
Boolean #1055 =..... 1044+1053+1054
 Remarks..... Meter Suspect

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 06
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)

Boolean #1056 =.....	Remarks.....
Boolean #1057 =.....	1088=1070 Remarks..... Maintenance
Boolean #1058 =.....	1087=1055 Remarks..... Meter Suspect
Boolean #1059 =.....	1086=1027 Remarks..... RD error
Boolean #1060 =.....	1085=1034 Remarks..... 1. Density error
Boolean #1061 =.....	1084=1032 Remarks..... 1. Low DP error
Boolean #1062 =.....	1083=1033 Remarks..... 1. High DP error
Boolean #1063 =.....	1082=1042 Remarks..... 2. Density error
Boolean #1064 =.....	1081=1040 Remarks..... 2. Low DP error
Boolean #1065 =.....	1080=1041 Remarks..... 2. High DP error
Boolean #1066 =.....	Remarks.....
Boolean #1067 =.....	Remarks.....
Boolean #1068 =.....	Remarks.....
Boolean #1069 =.....	/1105&/1205 Remarks..... No flow if = 1
Boolean #1070 =.....	7025 Remarks..... Maintenance mode
Boolean #1071 =.....	1027 Remarks..... Spare
Boolean #1072 =.....	/1055 Remarks..... Invert met susp
Boolean #1073 =.....	1736=/1105 Remarks..... 1. Disable flow
Boolean #1074 =.....	1737=/1205 Remarks..... 2. Disable flow
Boolean #1075 =.....	Remarks..... Den #3 alarm
Boolean #1076 =.....	Remarks..... Den #4 alarm
Boolean #1077 =.....	Remarks.....
Boolean #1078 =.....	Remarks.....
Boolean #1079 =.....	Remarks.....
Boolean #1080 =.....	M2 HDP OutOfTol Remarks.....
Boolean #1081 =.....	M2 LDP OutOfTol Remarks.....
Boolean #1082 =.....	M2 Den OutOfTol Remarks.....

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 07
=====

----- CONFIGURE BOOLEAN STATEMENTS (Cont'd)
Boolean #1083 =..... M1 HDP OutOfTol
Remarks.....
Boolean #1084 =..... M1 LDP OutOfTol
Remarks.....
Boolean #1085 =..... M1 Den OutOfTol
Remarks.....
Boolean #1086 =..... RD OutOfTol
Remarks.....
Boolean #1087 =..... Meter Suspect
Remarks.....
Boolean #1088 =..... Maintenance
Remarks.....

----- CONFIGURE VARIABLE STATEMENTS
Statement #7025 =..... Main:-1=Off,1=On
Remarks.....
Statement #7026 =..... LGT Fix Output %
Remarks.....
Statement #7027 =..... LGT lo flo inj %
Remarks.....
Statement #7028 =..... #5.0
Remarks..... Enter DP tol
Statement #7029 =..... #5.0-7028
Remarks..... DP tol >5.0?
Statement #7030 =..... 7029)7028=#5.0
Remarks..... Set min DPtol
Statement #7031 =..... 8596+8795
Remarks..... 1.Sum hi cells
Statement #7032 =..... 7031/#2
Remarks..... 1.Average hi
Statement #7033 =..... 7032-8595
Remarks..... 1.Diff av H + L
Statement #7034 =..... 8596-8795
Remarks..... 1.Diff H + STBY
Statement #7035 =..... \$7033-7028
Remarks..... 1.LDP OutOfTol
Statement #7036 =..... \$7034-7028
Remarks..... 1.HDP OutOfTol
Statement #7037 =..... 8696+8796
Remarks..... 2.Sum hi cells
Statement #7038 =..... 7037/#2
Remarks..... 2.Average hi
Statement #7039 =..... 7038-8695
Remarks..... 2.Diff av H + L
Statement #7040 =..... 8696-8796
Remarks..... 2.Diff H + STBY
Statement #7041 =..... \$7039-7028
Remarks..... 2.LDP OutOfTol
Statement #7042 =..... \$7040-7028
Remarks..... 2.HDP OutOfTol
Statement #7043 =.....
Remarks.....
Statement #7044 =..... 7802

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 08
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Set odour flow
Statement #7045 =..... 1069)7044=7085
Remarks..... LGT-low flow
Statement #7046 =..... 1055)7044=7086
Remarks..... LGT-Met Susp
Statement #7047 =..... 7025)7044=7087
Remarks..... LGT-fix flow
Statement #7048 =..... 7107-#80
Remarks..... 1. Hi den?
Statement #7049 =..... #24-7107
Remarks..... 1. Low den?
Statement #7050 =.....
Remarks.....
Statement #7051 =..... 7207-#80
Remarks..... 2. Hi den?
Statement #7052 =..... #24-7207
Remarks..... 2. Low den?
Statement #7053 =.....
Remarks.....
Statement #7054 =..... 7141-#0.7
Remarks..... RD hi?
Statement #7055 =..... #0.5-7141
Remarks..... RD low?
Statement #7056 =.....
Remarks.....
Statement #7057 =.....
Remarks.....
Statement #7058 =..... 7854=7138*17002
Remarks..... St mass fl limit
Statement #7059 =..... 7854=7854/#1000
Remarks..... Convert to ton/h
Statement #7060 =..... 7162=7854/#2
Remarks..... 1. Mass flow lim
Statement #7061 =..... 7262=7854/#2
Remarks..... 2. Mass flow lim
Statement #7062 =..... 7151=#.0009*7158
Remarks..... 1. Set DP cutoff
Statement #7063 =..... 7251=#.0009*7258
Remarks..... 2. Set DP cutoff
Statement #7064 =.....
Remarks.....
Statement #7065 =.....
Remarks.....
Statement #7066 =.....
Remarks.....
Statement #7067 =..... 7802*#0.000024
Remarks..... St vol MSCM/D
Statement #7068 =..... 7804*#0.024
Remarks..... St. energy MMJ/D
Statement #7069 =..... 7802/17002*#100
Remarks..... %Max flow
Statement #7070 =..... 17002*#0.000024
Remarks..... Max vol MSCM/D
Statement #7071 =..... 7070*#44

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 09
=====

----- CONFIGURE VARIABLE STATEMENTS (Cont'd)
Remarks..... Max energy MMJ/D
Statement #7072 =..... 7068/7071*#100
Remarks..... %Energy for tele
Statement #7073 =..... 7044/17004*#100
Remarks..... %Odour
Statement #7074 =.....
Remarks.....
Statement #7075 =.....
Remarks.....
Statement #7076 =..... 17049=17025
Remarks..... Set counter A
Statement #7077 =..... 17050=#10*17049
Remarks..... Set counter B
Statement #7078 =..... 7152=7158/#-200
Remarks..... 1. DP low limit
Statement #7079 =..... 7153=7158+\$7152
Remarks..... 1. DP hi limit
Statement #7080 =..... 7252=7258/#-200
Remarks..... 2. DP low limit
Statement #7081 =..... 7253=7258+\$7252
Remarks..... 2. DP hi limit
Statement #7082 =..... 7352=7358/#-200
Remarks..... 3. DP low limit
Statement #7083 =..... 7353=7358+\$7352
Remarks..... 3. DP hi limit
Statement #7084 =.....
Remarks.....
Statement #7085 =..... 7027/#100*17004
Remarks..... LGT low flow inj
Statement #7086 =..... /1055)7086=7044
Remarks..... Store LGT output
Statement #7087 =..... 7026/#100*17004
Remarks..... LGT fix flow
Statement #7088 =.....
Remarks.....

----- CONFIG USER DISPLAYS
User Display Number 1 Key Press..... F
1st Variable Tag..... MSCM/D
Point #..... 7067
Dec. Places..... 6
2nd Variable Tag..... MMJ/D
Point #..... 7068
Dec. Places..... 6
3rd Variable Tag..... %Max flw
Point #..... 7069
Dec. Places..... 2
4th Variable Tag..... %Odour
Point #..... 7073
Dec. Places..... 2
User Display Number 2 Key Press..... IO
1st Variable Tag..... RD
Point #..... 7141

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 10
=====

----- CONFIG USER DISPLAYS
(Cont'd)
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7138
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7107
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7142
Dec. Places..... 7
User Display Number 3 Key Press..... IP
1st Variable Tag..... RD
Point #..... 7241
Dec. Places..... 7
2nd Variable Tag..... Ref den
Point #..... 7238
Dec. Places..... 7
3rd Variable Tag..... Density
Point #..... 7207
Dec. Places..... 7
4th Variable Tag..... CV
Point #..... 7242
Dec. Places..... 7
User Display Number 4 Key Press..... VER
1st Variable Tag..... 02_71_V2
Point #..... 0
Dec. Places..... 0
2nd Variable Tag..... LGTcutoff
Point #..... 7027
Dec. Places..... 2
3rd Variable Tag..... 25/08/98
Point #..... 0
Dec. Places..... 0
4th Variable Tag..... 0
Dec. Places..... 0
User Display Number 5 Key Press..... FO
1st Variable Tag..... acmh
Point #..... 7101
Dec. Places..... 3
2nd Variable Tag..... scmh
Point #..... 7102
Dec. Places..... 3
3rd Variable Tag..... tons/hr
Point #..... 7103
Dec. Places..... 7
4th Variable Tag..... GJ/hr
Point #..... 7104
Dec. Places..... 3
User Display Number 6 Key Press..... FP
1st Variable Tag..... acmh
Point #..... 7201
Dec. Places..... 3
2nd Variable Tag..... scmh

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 11
=====

----- CONFIG USER DISPLAYS (Cont'd)

	Point #.....	7202
	Dec. Places.....	3
3rd Variable	Tag.....	tons/hr
	Point #.....	7203
	Dec. Places.....	7
4th Variable	Tag.....	GJ/hr
	Point #.....	7204
	Dec. Places.....	3
User Display Number 7	Key Press.....	DPO
1st Variable	Tag.....	Low DP
	Point #.....	8595
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8596
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8795
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7032
	Dec. Places.....	4
User Display Number 8	Key Press.....	DPP
1st Variable	Tag.....	Low DP
	Point #.....	8695
	Dec. Places.....	4
2nd Variable	Tag.....	High DP
	Point #.....	8696
	Dec. Places.....	4
3rd Variable	Tag.....	Standby
	Point #.....	8796
	Dec. Places.....	4
4th Variable	Tag.....	Average
	Point #.....	7038
	Dec. Places.....	4

----- CONFIG DIGITAL I/O

Digital Point #1	Assign.....	1802
	Remarks.....	Integ St Vol.
	Pulse Width.....	20
	Pulses/Unit.....	.001
Digital Point #2	Assign.....	1072
	Remarks.....	Meter Suspect
	Delay On.....	10
	Delay Off.....	10
Digital Point #3	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #4	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #5	Assign.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 12
=====

----- CONFIG DIGITAL I/O (Cont'd)

	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #6	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #7	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #8	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #9	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #10	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #11	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0
Digital Point #12	Assign.....	0
	Remarks.....	
	Delay On.....	0
	Delay Off.....	0

----- CONFIG SERIAL I/O

Serial I/O #1	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Port Type.....	Printer
Serial I/O #2	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms
	Protocol Type.....	Modbus RTU(Modem)
	Modbus ID.....	1
	Modicon Compatible.....	NO
	CRC Enabled.....	YES
Serial I/O #3	Baud Rate.....	9600
	Stop Bits.....	1 Bit
	Data Bits.....	8
	Parity.....	None
	Xmit Key Delay.....	0ms

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 13
=====

----- CONFIG SERIAL I/O (Cont'd)

Protocol Type.....	Modbus ASCII
Modbus ID.....	1
Modicon Compatible.....	YES
CRC Enabled.....	YES
Serial I/O #4 Baud Rate.....	9600
Stop Bits.....	1 Bit
Data Bits.....	8
Parity.....	None
Xmit Key Delay.....	0ms
Protocol Type.....	Modbus RTU
Modbus ID.....	0
Modicon Compatible.....	YES
CRC Enabled.....	YES

----- MODBUS PEER/PEER COMMUNICATIONS

Activate Redundancy Mode.....	NO
Next Master in Sequence.....	0
Last Master in Sequence.....	0
Retry Timer (50 mS Ticks).....	0
Transaction #1 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #2 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #3 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #4 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #5 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #6 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #7 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 14
=====

----- MODBUS PEER/PEER COMMUNICATIONS (Cont'd)

Dest. Point #.....	0
Transaction #8 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #9 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #10 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #11 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #12 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #13 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #14 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #15 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0
Transaction #16 Target Slave ID.....	0
Read/Write ?.....	Read
Source Index #.....	0
# of Points.....	0
Dest. Point #.....	0

----- CUSTOM MODBUS PACKET(ADDR:001)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 15
=====

----- CUSTOM MODBUS PACKET(ADDR:001) (Cont'd)

Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0
Packet #09	Pnt.#.....	0
	# of Points.....	0
Packet #10	Pnt.#.....	0
	# of Points.....	0
Packet #11	Pnt.#.....	0
	# of Points.....	0
Packet #12	Pnt.#.....	0
	# of Points.....	0
Packet #13	Pnt.#.....	0
	# of Points.....	0
Packet #14	Pnt.#.....	0
	# of Points.....	0
Packet #15	Pnt.#.....	0
	# of Points.....	0
Packet #16	Pnt.#.....	0
	# of Points.....	0
Packet #17	Pnt.#.....	0
	# of Points.....	0
Packet #18	Pnt.#.....	0
	# of Points.....	0
Packet #19	Pnt.#.....	0
	# of Points.....	0
Packet #20	Pnt.#.....	0
	# of Points.....	0

----- CUSTOM MODBUS PACKET(ADDR:201)

Packet #01	Pnt.#.....	0
	# of Points.....	0
Packet #02	Pnt.#.....	0
	# of Points.....	0
Packet #03	Pnt.#.....	0
	# of Points.....	0
Packet #04	Pnt.#.....	0
	# of Points.....	0
Packet #05	Pnt.#.....	0
	# of Points.....	0
Packet #06	Pnt.#.....	0
	# of Points.....	0
Packet #07	Pnt.#.....	0
	# of Points.....	0
Packet #08	Pnt.#.....	0
	# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 16
=====

----- CUSTOM MODBUS PACKET(ADDR:401)

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Packet #17 Pnt.#.....	0
# of Points.....	0
Packet #18 Pnt.#.....	0
# of Points.....	0
Packet #19 Pnt.#.....	0
# of Points.....	0
Packet #20 Pnt.#.....	0
# of Points.....	0

----- ARCHIVE 701 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 17
=====

----- ARCHIVE 701 - RECORD DEFINITION (Cont'd)

Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 702 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 18
=====

----- ARCHIVE 702 - RECORD DEFINITION (Cont'd)
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 703 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 704 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 19
=====

----- ARCHIVE 704 - RECORD DEFINITION (Cont'd)

# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 705 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 20
=====

----- ARCHIVE 705 - RECORD DEFINITION (Cont'd)
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 706 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0
Packet #03 Pnt.#..... 0
of Points..... 0
Packet #04 Pnt.#..... 0
of Points..... 0
Packet #05 Pnt.#..... 0
of Points..... 0
Packet #06 Pnt.#..... 0
of Points..... 0
Packet #07 Pnt.#..... 0
of Points..... 0
Packet #08 Pnt.#..... 0
of Points..... 0
Packet #09 Pnt.#..... 0
of Points..... 0
Packet #10 Pnt.#..... 0
of Points..... 0
Packet #11 Pnt.#..... 0
of Points..... 0
Packet #12 Pnt.#..... 0
of Points..... 0
Packet #13 Pnt.#..... 0
of Points..... 0
Packet #14 Pnt.#..... 0
of Points..... 0
Packet #15 Pnt.#..... 0
of Points..... 0
Packet #16 Pnt.#..... 0
of Points..... 0
Max Records..... 0
Archive Boolean Trigger..... 0

----- ARCHIVE 707 - RECORD DEFINITION
Packet #01 Pnt.#..... 0
of Points..... 0
Packet #02 Pnt.#..... 0
of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 21
=====

----- ARCHIVE 707 - RECORD DEFINITION (Cont'd)

Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- ARCHIVE 708 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 22
=====

----- ARCHIVE 708 - RECORD DEFINITION (Cont'd)
 # of Points..... 0
 Packet #12 Pnt.#..... 0
 # of Points..... 0
 Packet #13 Pnt.#..... 0
 # of Points..... 0
 Packet #14 Pnt.#..... 0
 # of Points..... 0
 Packet #15 Pnt.#..... 0
 # of Points..... 0
 Packet #16 Pnt.#..... 0
 # of Points..... 0
 Max Records..... 0
 Archive Boolean Trigger..... 0

----- ARCHIVE 709 - RECORD DEFINITION
 Packet #01 Pnt.#..... 0
 # of Points..... 0
 Packet #02 Pnt.#..... 0
 # of Points..... 0
 Packet #03 Pnt.#..... 0
 # of Points..... 0
 Packet #04 Pnt.#..... 0
 # of Points..... 0
 Packet #05 Pnt.#..... 0
 # of Points..... 0
 Packet #06 Pnt.#..... 0
 # of Points..... 0
 Packet #07 Pnt.#..... 0
 # of Points..... 0
 Packet #08 Pnt.#..... 0
 # of Points..... 0
 Packet #09 Pnt.#..... 0
 # of Points..... 0
 Packet #10 Pnt.#..... 0
 # of Points..... 0
 Packet #11 Pnt.#..... 0
 # of Points..... 0
 Packet #12 Pnt.#..... 0
 # of Points..... 0
 Packet #13 Pnt.#..... 0
 # of Points..... 0
 Packet #14 Pnt.#..... 0
 # of Points..... 0
 Packet #15 Pnt.#..... 0
 # of Points..... 0
 Packet #16 Pnt.#..... 0
 # of Points..... 0
 Max Records..... 0
 Archive Boolean Trigger..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 23
=====

----- ARCHIVE 710 - RECORD DEFINITION

Packet #01 Pnt.#.....	0
# of Points.....	0
Packet #02 Pnt.#.....	0
# of Points.....	0
Packet #03 Pnt.#.....	0
# of Points.....	0
Packet #04 Pnt.#.....	0
# of Points.....	0
Packet #05 Pnt.#.....	0
# of Points.....	0
Packet #06 Pnt.#.....	0
# of Points.....	0
Packet #07 Pnt.#.....	0
# of Points.....	0
Packet #08 Pnt.#.....	0
# of Points.....	0
Packet #09 Pnt.#.....	0
# of Points.....	0
Packet #10 Pnt.#.....	0
# of Points.....	0
Packet #11 Pnt.#.....	0
# of Points.....	0
Packet #12 Pnt.#.....	0
# of Points.....	0
Packet #13 Pnt.#.....	0
# of Points.....	0
Packet #14 Pnt.#.....	0
# of Points.....	0
Packet #15 Pnt.#.....	0
# of Points.....	0
Packet #16 Pnt.#.....	0
# of Points.....	0
Max Records.....	0
Archive Boolean Trigger.....	0

----- CONFIG AB PLC BLOCK#1 READ

Start Address of Data Block #1.....	9
Item #1 Source Point #.....	8
# of Points.....	10
Item #2 Source Point #.....	11
# of Points.....	2
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	3
Item #6 Source Point #.....	4
# of Points.....	6
Item #7 Source Point #.....	7
# of Points.....	1
Item #8 Source Point #.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 24
=====

----- CONFIG AB PLC BLOCK#1 READ (Cont'd)

# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	17
# of Points.....	18
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC BLOCK#2 READ

Start Address of Data Block #2.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 25
=====

----- CONFIG AB PLC BLOCK#3 READ

Start Address of Data Block #3.....	0
Item #1 Source Point #.....	0
# of Points.....	0
Item #2 Source Point #.....	0
# of Points.....	0
Item #3 Source Point #.....	0
# of Points.....	0
Item #4 Source Point #.....	0
# of Points.....	0
Item #5 Source Point #.....	0
# of Points.....	0
Item #6 Source Point #.....	0
# of Points.....	0
Item #7 Source Point #.....	0
# of Points.....	0
Item #8 Source Point #.....	0
# of Points.....	0
Item #9 Source Point #.....	0
# of Points.....	0
Item #10 Source Point #.....	0
# of Points.....	0
Item #11 Source Point #.....	0
# of Points.....	0
Item #12 Source Point #.....	0
# of Points.....	0
Item #13 Source Point #.....	0
# of Points.....	0
Item #14 Source Point #.....	0
# of Points.....	0
Item #15 Source Point #.....	0
# of Points.....	0
Item #16 Source Point #.....	0
# of Points.....	0

----- CONFIG AB PLC COMMAND BLOCK

Start Address of Command Block	0
Item #1 Dest. Point #.....	0
# of Points.....	0
Item #2 Dest. Point #.....	0
# of Points.....	0
Item #3 Dest. Point #.....	0
# of Points.....	0
Item #4 Dest. Point #.....	0
# of Points.....	0
Item #5 Dest. Point #.....	0
# of Points.....	0
Item #6 Dest. Point #.....	0
# of Points.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 26
=====

----- CONFIG AB PLC SETPOINT BLOCK
Start Address of Command Block..... 0
 Item #1 Dest. Point #..... 0
 # of Points..... 0
 Item #2 Dest. Point #..... 0
 # of Points..... 0
 Item #3 Dest. Point #..... 0
 # of Points..... 0
 Item #4 Dest. Point #..... 0
 # of Points..... 0
 Item #5 Dest. Point #..... 0
 # of Points..... 0
 Item #6 Dest. Point #..... 0
 # of Points..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 27
=====

----- PRINTER SETUP

Computer ID.....	62823
Print Interval in Minutes.....	0
Print Interval Start Time.....	18:00:00
Daily Report Time.....	06:00:00
Disable Daily Report.....	YES
Day Light Savings Start.....	00/00/00
Day Light Savings End.....	00/00/00
Clear Daily Totals at Batch End.....	YES
Auto Hourly Batch Select.....	NO
Auto Weekly Batch Select.....	No Batch End
Auto Monthly Batch Select.....	0
Print Priority.....	0
Number of Nulls.....	0
Use Default Report Template.....	NO
Printer Condensed Mode String.....	
Printer Normal Mode String.....	
Company Name	TRANSCO part of Lattice Group plc
Location	Sunny Blackrod

----- ANALYSER SETUP

Analyser ID Number.....	1
Analyser Type.....	DANALYZER
Results Interval (Minutes).....	4
Listen Only Mode (Y or N).....	NO
GC Fail Code.....	Always use
GC Comp. # for Methane (CH4).....	0
GC Comp. # for Nitrogen (N2).....	0
GC Comp. # for Carbon Dioxide (CO2).....	0
GC Comp. # for Ethane (C2H6).....	0
GC Comp. # for Propane (C3H8).....	0
GC Comp. # for Water (H2O).....	0
GC Comp. # for Hydrogen Sulfide (H2S).....	0
GC Comp. # for Hydrogen (H2).....	0
GC Comp. # for Carbon Monoxide (CO).....	0
GC Comp. # for Oxygen (O2).....	0
GC Comp. # for i-Butane (iC4H10).....	0
GC Comp. # for n-Butane (nC4H10).....	0
GC Comp. # for i-Pentane (iC5H12).....	0
GC Comp. # for n-Pentane (nC5H12).....	0
GC Comp. # for n-Hexane (C6H14).....	0
GC Comp. # for n-Heptane (C7H16).....	0
GC Comp. # for n-Octane (C8H16).....	0
GC Comp. # for n-Nonane.....	0
GC Comp. # for n-Decane.....	0
GC Comp. # for Helium (He).....	0
GC Comp. # for Argon (Ar).....	0
GC Comp. # for Heating Value.....	0
GC Comp. # for Specific Gravity.....	0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 28
=====

----- PID CONTROL SETUP
Loop #1 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #2 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #3 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0
 Minimum Ramp To %..... 0
 Primary Setpoint Low Limit..... 0
 High Limit..... 0
 Zero Value..... 0
 Full Scale Value..... 0
 Secondary Var Zero Value..... 0
 Full Scale Value..... 0
Loop #4 Secondary Setpoint Value..... 0
 Primary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Secondary Gain Factor..... 0.00
 Rpts/Min..... 0.00
 Deadband %..... 0
 Startup Ramp %..... 0
 Shutdown Ramp %..... 0

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 29
=====

----- PID CONTROL SETUP (Cont'd)

Minimum Ramp To %.....	0
Primary Setpoint Low Limit.....	0
High Limit.....	0
Zero Value.....	0
Full Scale Value.....	0
Secondary Var Zero Value.....	0
Full Scale Value.....	0

----- GRAV/DENSITY SETUP

----- TEMP/PRESS SETUP

Temp #1 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Temp #2 Low Alarm Limit.....	-10
Hi Alarm Limit.....	40
Override Value.....	15
Override Code.....	Avg on fail
Press #1 Low Alarm Limit.....	35
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds
Press #2 Low Alarm Limit.....	30
Hi Alarm Limit.....	80
Override Value.....	50
Override Code.....	Avg on fail
at 4mA.....	0
at 20mA.....	80
Damping Code.....	0.0 Seconds

----- DIFF. PRESSURE SETUP

Diff Pressure #1 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail
Low DP at 4mA.....	0
Low DP at 20mA.....	50
Damping Code.....	0.0 Seconds
High DP at 4mA.....	0
High DP at 20mA.....	500
Damping Code.....	0.0 Seconds
High DP Select %.....	95
Low DP Select %.....	9
Diff Pressure #2 Low Alarm Limit.....	-2.5
Hi Alarm Limit.....	502.5
Override Value.....	0
Override Code.....	Avg on fail

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 30
=====

----- DIFF. PRESSURE SETUP (Cont'd)
Low DP at 4mA..... 0
Low DP at 20mA..... 50
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 95
Low DP Select %..... 9
Diff Pressure #3 Low Alarm Limit..... -2.5
Hi Alarm Limit..... 502.5
Override Value..... 0
Override Code..... Avg on fail
Low DP at 4mA..... 0
Low DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP at 4mA..... 0
High DP at 20mA..... 500
Damping Code..... 0.0 Seconds
High DP Select %..... 0
Low DP Select %..... 0

----- STATION SG/N2 ETC SETUP
Station ID..... Blackrod
Flow Low Limit (Tons/Hr)..... 0
Flow High Limit (Tons/Hr)..... 867.4584
Gross Flowrate Full Scale..... 0
Mass Flowrate Full Scale..... 0
Run Switch Mode..... Manual
Run Switch Time..... 0
Run Switch Threshold Low %DP..... 0
Run Switch Threshold High %DP..... 0

----- METER RUN SETUP
Meter #1 Meter ID..... 9741/MTA
Analysis Selected..... Product #1
Analyzer Stream Number..... 3
Flow Low Limit..... 0
Flow High Limit..... 433.7292
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 367.0034
Orifice Reference Temp..... 20.2
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.1738
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO
Meter #2 Meter ID..... 8171/MTB

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 31
=====

----- METER RUN SETUP (Cont'd)
Analysis Selected..... Product #1
Analyzer Stream Number..... 1
Flow Low Limit..... 0
Flow High Limit..... 433.7292
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... .45
Orifice Measured Dia..... 366.4895
Orifice Reference Temp..... 20.3
Orifice Expansion Coef..... 1.600000E-005
Pipe Measured Dia..... 730.2849
Pipe Reference Temp..... 20
Pipe Expansion Coef..... 1.100000E-005
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... NO
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

Meter #3 Meter ID.....
Analysis Selected..... Product #1
Analyzer Stream Number..... 0
Flow Low Limit..... 0
Flow High Limit..... 0
Gross Flow Full Scale..... 0
Mass Flow Full Scale..... 0
Low Flow Cutoff..... 0
Orifice Measured Dia..... 0
Orifice Reference Temp..... 0
Orifice Expansion Coef..... 0.000000E+000
Pipe Measured Dia..... 0
Pipe Reference Temp..... 0
Pipe Expansion Coef..... 0.000000E+000
Use Downstream Pressure?..... NO
Use Upstream Temperature?..... YES
Orifice Plate Taps..... Flange Taps
Transducer Density (Y/N)..... NO

----- FACTOR SETUP & SYS CONSTANTS
Atmospheric Pressure (absolute)..... 1.01325
Base Pressure (absolute)..... 1.01325
Base Temperature..... 15
Density of Air..... 1.225410
Flow Average Factor..... 0
Alarm Deadband %..... 2.00
Roll All Totalizers..... 9 Digits
Gross Totalizer Decimal Places..... 0
Net Totalizer Decimal Places..... 0
Mass Totalizer Decimal Places..... 0
Energy Totalizer Decimal Places..... 0
Select Averaging Method..... Flow Weighted
Select Pressure Units..... Bar
Select DP Units..... Milli Bar

=====
CONFIGURATION DATA REPORT COMPUTER ID : 62823 PAGE : 32
=====

----- FLUID DATA & ANALYSIS

Prod #1 Fluid Name.....
 Fluid Type Select (F1=Help)..... Natural Gas
 Viscosity in pa.s..... .0000117
 Isentropic Exponent..... 1.328626
 AGA-8 Method (F1=Help)..... 94 Detailed
 Heating Value Method (F1=Help)..... ISO 6976
 Heating Value MJ/NM3..... 39.15599
 Specific Gravity..... 0.6381
 1994-01 % Methane (CH4)..... 87.1718
 1994-02 % Nitrogen (N2)..... 3.2063
 1994-03 % Carbon Dioxide (CO2)..... 1.5881
 1994-04 % Ethane (C2H6)..... 5.7779
 1994-05 % Propane (C3H8)..... 1.5528
 1994-06 % Water (H2O)..... 0.0000
 1994-07 % Hydrogen Sulfide (H2S)..... 0.0000
 1994-08 % Hydrogen (H2)..... 0.0000
 1994-09 % Carbon Monoxide (CO)..... 0.0000
 1994-10 % Oxygen (O2)..... 0.0000
 1994-11 % i-Butane (iC4H10)..... 0.2048
 1994-12 % n-Butane (nC4H10)..... 0.3254
 1994-13 % i-Pentane (iC5H12)..... 0.0721
 1994-14 % n-Pentane (nC5H12)..... 0.0590
 1994-15 % n-Hexane (C6H14)..... 0.0417
 1994-16 % n-Heptane (C7H16)..... 0.0000
 1994-17 % n-Octane (C8H16)..... 0.0000
 1994-18 % n-Nonane..... 0.0000
 1994-19 % n-Decane..... 0.0000
 1994-20 % Helium (He)..... 0.0000
 1994-21 % Argon (Ar)..... 0.0000

Prod #2 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 39.15599

Prod #3 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density KG/M3..... 0
 Viscosity in pa.s..... 0
 Isentropic Exponent..... 0
 Heating Value MJ/NM3..... 0

Prod #4 Fluid Name.....
 Fluid Type Select (F1=Help)..... None Selected
 Reference Density Lb/Ft3..... 0
 Viscosity in Centipoise..... 0
 Isentropic Exponent..... 0
 Heating Value Btu/Scf..... 0

APPENDIX C CORRECTED DAILY VOLUME FLOWS

TABLE C.1 FLOWS AT BLACKROD DURING THE PERIOD OF THE MIS-MEASUREMENT

	Original Values (total)	Corrected values (total)	% increase
Date	Volume (mscm)	Volume (mscm)	Volume (mscm)
16/07/2007	4.42297	4.42329	0.0073
17/07/2007	4.64599	4.64615	0.0035
18/07/2007	0.67304	0.67317	0.0192
19/07/2007	0.14594	0.14622	0.1933
20/07/2007	0.28699	0.28755	0.1936
21/07/2007	5.76404	5.77520	0.1936
22/07/2007	4.35999	4.36843	0.1936
23/07/2007	4.06097	4.06883	0.1936
24/07/2007	3.60004	3.60701	0.1936
25/07/2007	4.21295	4.22111	0.1936
26/07/2007	0.66205	0.66333	0.1936
27/07/2007	0.00000	0.00000	
28/07/2007	0.00000	0.00000	
29/07/2007	0.00000	0.00000	
30/07/2007	0.00000	0.00000	
31/07/2007	0.66498	0.66627	0.1936
01/08/2007	0.00000	0.00000	
02/08/2007	0.00000	0.00000	
03/08/2007	0.00000	0.00000	
04/08/2007	0.00000	0.00000	
05/08/2007	0.00000	0.00000	
06/08/2007	0.00702	0.00703	0.1936
07/08/2007	0.00000	0.00000	
08/08/2007	0.00000	0.00000	
09/08/2007	0.00000	0.00000	
10/08/2007	0.00000	0.00000	
11/08/2007	0.00000	0.00000	
12/08/2007	0.00000	0.00000	
13/08/2007	0.00000	0.00000	
14/08/2007	0.00000	0.00000	
15/08/2007	0.00000	0.00000	
16/08/2007	0.04297	0.04305	0.1936
17/08/2007	0.00000	0.00000	
18/08/2007	0.00000	0.00000	
19/08/2007	0.55603	0.55711	0.1936
20/08/2007	4.73297	4.74213	0.1936
21/08/2007	4.39899	4.40751	0.1936
22/08/2007	3.71704	3.72424	0.1936
23/08/2007	3.52301	3.52983	0.1936
24/08/2007	3.02399	3.02984	0.1936
25/08/2007	3.05200	3.05791	0.1936
26/08/2007	3.34601	3.35249	0.1936
27/08/2007	0.02899	0.02905	0.1936
28/08/2007	0.00000	0.00000	
29/08/2007	0.00000	0.00000	
30/08/2007	0.00000	0.00000	
31/08/2007	0.00000	0.00000	
01/09/2007	4.16998	4.17805	0.1936
02/09/2007	4.89502	4.90450	0.1936
03/09/2007	4.74097	4.75015	0.1936
04/09/2007	4.58600	4.59488	0.1936

05/09/2007	4.23700	4.24520	0.1936
06/09/2007	3.56799	3.57490	0.1936
07/09/2007	3.50500	3.51179	0.1936
08/09/2007	0.41901	0.41982	0.1936
09/09/2007	3.80701	3.81438	0.1936
10/09/2007	1.06903	1.07110	0.1936
11/09/2007	4.05499	4.06284	0.1936
12/09/2007	3.90399	3.91155	0.1936
13/09/2007	3.96100	3.96867	0.1936
14/09/2007	4.62097	4.62992	0.1936
15/09/2007	3.88702	3.89455	0.1936
16/09/2007	3.38300	3.38955	0.1936
17/09/2007	4.18604	4.19414	0.1936
18/09/2007	6.62097	6.63379	0.1936
19/09/2007	4.28497	4.29327	0.1936
20/09/2007	6.22705	6.23911	0.1936
21/09/2007	6.79700	6.81016	0.1936
22/09/2007	5.00000	5.00968	0.1936
23/09/2007	5.30798	5.31826	0.1936
24/09/2007	8.00800	8.02350	0.1936
25/09/2007	6.31201	6.32423	0.1936
26/09/2007	7.66602	7.68086	0.1936
27/09/2007	6.79095	6.80410	0.1936
28/09/2007	5.55701	5.56777	0.1936
29/09/2007	4.08502	4.09293	0.1936
30/09/2007	4.95300	4.96259	0.1936
01/10/2007	6.06000	6.07173	0.1936
02/10/2007	8.05701	8.07261	0.1936
03/10/2007	8.24500	8.26096	0.1936
04/10/2007	8.33496	8.35110	0.1936
05/10/2007	7.40503	7.41937	0.1936
06/10/2007	7.26300	7.27706	0.1936
07/10/2007	7.68500	7.69988	0.1936
08/10/2007	8.91300	8.93026	0.1936
09/10/2007	8.91100	8.92825	0.1936
10/10/2007	8.90900	8.92625	0.1936
11/10/2007	0.87200	0.87369	0.1936
12/10/2007	6.87800	6.89132	0.1936
13/10/2007	4.49200	4.50070	0.1936
14/10/2007	3.23700	3.24327	0.1936
15/10/2007	5.40700	5.41747	0.1936
16/10/2007	4.44600	4.45461	0.1936
17/10/2007	6.82900	6.84222	0.1936
18/10/2007	7.49600	7.51051	0.1936
19/10/2007	6.92300	6.93640	0.1936
20/10/2007	5.61700	5.62787	0.1936
21/10/2007	4.48800	4.49669	0.1936
22/10/2007	5.20800	5.21808	0.1936
23/10/2007	4.54600	4.55480	0.1936
24/10/2007	3.91200	3.91957	0.1936
25/10/2007	3.71500	3.72219	0.1936
26/10/2007	5.82000	5.83127	0.1936
27/10/2007	3.73100	3.73822	0.1936
28/10/2007	4.67700	4.68605	0.1936
29/10/2007	7.87800	7.89325	0.1936
30/10/2007	7.34000	7.35421	0.1936
31/10/2007	5.53799	5.54871	0.1936
01/11/2007	5.44301	5.45355	0.1936
02/11/2007	1.01100	1.01296	0.1936
03/11/2007	1.58899	1.59207	0.1936
04/11/2007	5.50500	5.51566	0.1936

05/11/2007	7.80800	7.82312	0.1936
06/11/2007	8.08301	8.09866	0.1936
07/11/2007	7.23999	7.25401	0.1936
08/11/2007	8.97800	8.99538	0.1936
09/11/2007	8.80101	8.81805	0.1936
10/11/2007	6.55699	6.56968	0.1936
11/11/2007	7.53300	7.54758	0.1936
12/11/2007	8.21201	8.22791	0.1936
13/11/2007	4.75400	4.76320	0.1936
14/11/2007	7.85699	7.87220	0.1936
15/11/2007	6.91701	6.93040	0.1936
16/11/2007	0.00000	0.00000	
17/11/2007	5.05800	5.06779	0.1936
18/11/2007	6.20100	6.21301	0.1936
19/11/2007	6.86800	6.88130	0.1936
20/11/2007	8.07901	8.09465	0.1936
21/11/2007	4.54800	4.55680	0.1936
22/11/2007	5.29099	5.30123	0.1936
23/11/2007	8.07101	8.08664	0.1936
24/11/2007	8.00497	8.02047	0.1936
25/11/2007	5.98102	5.99260	0.1936
26/11/2007	4.79700	4.80629	0.1936
27/11/2007	4.45001	4.45863	0.1936
28/11/2007	5.90500	5.91643	0.1936
29/11/2007	6.50299	6.51558	0.1936
30/11/2007	5.05600	5.06579	0.1936
01/12/2007	5.32599	5.33630	0.1936
02/12/2007	8.07202	8.08765	0.1936
03/12/2007	8.32898	8.34510	0.1936
04/12/2007	6.76901	6.78211	0.1936
05/12/2007	5.47198	5.48257	0.1936
06/12/2007	7.22000	7.23398	0.1936
07/12/2007	8.25803	8.27402	0.1936
08/12/2007	9.00897	9.02641	0.1936
09/12/2007	7.11902	7.13280	0.1936
10/12/2007	8.87601	8.89319	0.1936
11/12/2007	8.09500	8.11067	0.1936
12/12/2007	8.16299	8.17879	0.1936
13/12/2007	8.87000	8.88717	0.1936
14/12/2007	8.08200	8.09765	0.1936
15/12/2007	5.73300	5.74410	0.1936
16/12/2007	7.01401	7.02759	0.1936
17/12/2007	7.82401	7.83906	0.1924
18/12/2007	9.06097	9.07833	0.1915
19/12/2007	8.45901	8.47521	0.1915
20/12/2007	8.53500	8.55135	0.1915
21/12/2007	8.31198	8.32790	0.1915
22/12/2007	7.54901	7.56347	0.1915
23/12/2007	6.64301	6.65573	0.1915
24/12/2007	7.62100	7.63560	0.1915
25/12/2007	8.15399	8.16961	0.1915
26/12/2007	7.68298	7.69770	0.1915
27/12/2007	6.49304	6.50548	0.1915
28/12/2007	6.92297	6.93623	0.1915
29/12/2007	9.72504	9.74367	0.1915
30/12/2007	7.21698	7.23080	0.1915
31/12/2007	9.60602	9.62442	0.1915
01/01/2008	7.11700	7.13063	0.1915
02/01/2008	10.41090	10.43084	0.1915
03/01/2008	8.33301	8.34897	0.1915
04/01/2008	6.61304	6.62571	0.1915

05/01/2008	8.28595	8.30182	0.1915
06/01/2008	4.41504	4.42350	0.1915
07/01/2008	8.25299	8.26880	0.1915
08/01/2008	8.33197	8.34793	0.1915
09/01/2008	9.06104	9.07840	0.1915
10/01/2008	8.19397	8.20967	0.1915
11/01/2008	8.95801	8.97517	0.1915
12/01/2008	3.66003	3.66704	0.1915
13/01/2008	8.65997	8.67656	0.1915
14/01/2008	6.67902	6.69181	0.1915
15/01/2008	7.43298	7.44722	0.1915
16/01/2008	5.80701	5.81813	0.1915
17/01/2008	7.78699	7.80191	0.1915
18/01/2008	8.89203	8.90906	0.1915
19/01/2008	6.30896	6.32104	0.1915
20/01/2008	5.69702	5.70793	0.1915
21/01/2008	7.28400	7.29795	0.1915
22/01/2008	8.55304	8.56942	0.1915
23/01/2008	6.24194	6.25390	0.1915
24/01/2008	8.88000	8.89701	0.1915
25/01/2008	8.10602	8.12155	0.1915
26/01/2008	8.97198	8.98917	0.1915
27/01/2008	9.10303	9.12047	0.1915
28/01/2008	7.69000	7.70473	0.1915
29/01/2008	7.20697	7.22077	0.1915
30/01/2008	9.30505	9.32287	0.1915
31/01/2008	8.34094	8.35692	0.1915
01/02/2008	8.52704	8.54337	0.1915
02/02/2008	8.04401	8.05942	0.1915
03/02/2008	6.57898	6.59158	0.1915
04/02/2008	6.25500	6.26698	0.1915
05/02/2008	8.22498	8.24073	0.1915
06/02/2008	7.88800	7.90311	0.1915
07/02/2008	9.00903	9.02629	0.1915
08/02/2008	6.69000	6.70281	0.1915
09/02/2008	7.37000	7.38412	0.1915
10/02/2008	7.61597	7.63056	0.1915
11/02/2008	7.85706	7.87211	0.1915
12/02/2008	6.98999	7.00338	0.1915
13/02/2008	7.80298	7.81793	0.1915
14/02/2008	8.58203	8.59847	0.1915
15/02/2008	7.61798	7.63257	0.1915
16/02/2008	7.83197	7.84697	0.1915
17/02/2008	8.85303	8.86999	0.1915
18/02/2008	7.65900	7.67367	0.1915
19/02/2008	7.97302	7.98829	0.1915
20/02/2008	8.59796	8.61443	0.1915
21/02/2008	7.94904	7.96427	0.1915
22/02/2008	7.50201	7.51638	0.1915
23/02/2008	6.27899	6.29102	0.1915
24/02/2008	6.93500	6.94828	0.1915
25/02/2008	8.30298	8.31888	0.1915
26/02/2008	7.41400	7.42820	0.1915
27/02/2008	8.54803	8.56440	0.1915
28/02/2008	8.92600	8.94310	0.1915
29/02/2008	10.36400	10.38385	0.1915
01/03/2008	9.25300	9.27072	0.1915
02/03/2008	7.40500	7.41918	0.1915
03/03/2008	9.73400	9.75265	0.1915
04/03/2008	10.52500	10.54516	0.1915
05/03/2008	7.72700	7.74180	0.1915

06/03/2008	7.80200	7.81694	0.1915
07/03/2008	7.94300	7.95821	0.1915
08/03/2008	8.03900	8.05440	0.1915
09/03/2008	7.58100	7.59552	0.1915
10/03/2008	8.64300	8.65956	0.1915
11/03/2008	7.95800	7.97324	0.1915
12/03/2008	9.69500	9.71357	0.1915
13/03/2008	7.88100	7.89610	0.1915
14/03/2008	7.94800	7.96322	0.1915
15/03/2008	7.75101	7.76586	0.1915
16/03/2008	8.23500	8.25077	0.1915
17/03/2008	8.87401	8.89101	0.1915
18/03/2008	9.60899	9.62740	0.1915
19/03/2008	8.59599	8.61246	0.1915
20/03/2008	9.44501	9.46310	0.1915
21/03/2008	8.53101	8.54735	0.1915
22/03/2008	8.89699	8.91403	0.1915
23/03/2008	8.73801	8.75475	0.1915
24/03/2008	8.49901	8.51529	0.1915
25/03/2008	9.84000	9.85885	0.1915
26/03/2008	7.72000	7.73479	0.1915
27/03/2008	6.94099	6.95428	0.1915
28/03/2008	8.88600	8.90302	0.1915
29/03/2008	9.02301	9.04029	0.1915
30/03/2008	6.96201	6.97537	0.1918
31/03/2008	6.85999	6.87327	0.1936
01/04/2008	8.58899	8.60562	0.1936
02/04/2008	7.61002	7.62475	0.1936
03/04/2008	7.50101	7.51553	0.1936
04/04/2008	4.99698	5.00665	0.1936
05/04/2008	6.79800	6.81116	0.1936
06/04/2008	9.85300	9.87208	0.1936
07/04/2008	7.69202	7.70691	0.1936
08/04/2008	8.62000	8.63669	0.1936
09/04/2008	8.98599	9.00339	0.1936
10/04/2008	7.36801	7.38227	0.1936
11/04/2008	8.81601	8.83308	0.1936
12/04/2008	7.67899	7.69386	0.1936
13/04/2008	7.43900	7.45340	0.1936
14/04/2008	7.32202	7.33620	0.1936
15/04/2008	7.52499	7.53956	0.1936
16/04/2008	7.21600	7.22997	0.1936
17/04/2008	8.49200	8.50844	0.1936
18/04/2008	7.92200	7.93734	0.1936
19/04/2008	8.84799	8.86512	0.1936
20/04/2008	8.20001	8.21589	0.1936
21/04/2008	5.09399	5.10385	0.1936
22/04/2008	4.68600	4.69507	0.1936
23/04/2008	5.67599	5.68698	0.1936
24/04/2008	6.93799	6.95142	0.1936
25/04/2008	7.97900	7.99445	0.1936
26/04/2008	6.46600	6.47852	0.1936
27/04/2008	7.32501	7.33919	0.1936
28/04/2008	5.60999	5.62085	0.1936
29/04/2008	5.94501	5.95652	0.1936
30/04/2008	6.07199	6.08375	0.1936
01/05/2008	5.73502	5.74612	0.1936
02/05/2008	4.75201	4.76121	0.1936
03/05/2008	5.39600	5.40645	0.1936
04/05/2008	7.77899	7.79405	0.1936
05/05/2008	5.64996	5.66090	0.1936

06/05/2008	6.94904	6.96249	0.1936
07/05/2008	5.30499	5.31526	0.1936
08/05/2008	7.18201	7.19591	0.1936
09/05/2008	6.48596	6.49852	0.1936
10/05/2008	6.06805	6.07980	0.1936
11/05/2008	6.08295	6.09473	0.1936
12/05/2008	1.94305	1.94681	0.1936
13/05/2008	0.83496	0.83658	0.1936
14/05/2008	0.00000	0.00000	
15/05/2008	0.00000	0.00000	
16/05/2008	1.34601	1.34862	0.1936
17/05/2008	7.54498	7.55959	0.1936
18/05/2008	8.06201	8.07762	0.1936
19/05/2008	7.79004	7.80512	0.1936
20/05/2008	7.43298	7.44737	0.1936
21/05/2008	6.54596	6.55863	0.1936
22/05/2008	1.45404	1.45686	0.1936
23/05/2008	5.83197	5.84326	0.1936
24/05/2008	4.94501	4.95458	0.1936
25/05/2008	5.49304	5.50367	0.1936
26/05/2008	3.74396	3.75121	0.1936
27/05/2008	6.46100	6.47351	0.1936
28/05/2008	6.47504	6.48758	0.1936
29/05/2008	2.77197	2.77734	0.1936
30/05/2008	4.96698	4.97660	0.1936
31/05/2008	0.00000	0.00000	
01/06/2008	0.49304	0.49399	0.1936
02/06/2008	5.02997	5.03971	0.1936
03/06/2008	3.48102	3.48776	0.1936
04/06/2008	4.98499	4.99464	0.1936
05/06/2008	4.88202	4.89147	0.1936
06/06/2008	4.88397	4.89343	0.1936
07/06/2008	0.08301	0.08317	0.1936
08/06/2008	0.00000	0.00000	
09/06/2008	0.00000	0.00000	
10/06/2008	0.00000	0.00000	
11/06/2008	0.09302	0.09320	0.1936
12/06/2008	3.89899	3.90654	0.1936
13/06/2008	3.25500	3.26130	0.1936
14/06/2008	3.81403	3.82141	0.1936
15/06/2008	4.18298	4.19108	0.1936
16/06/2008	5.18799	5.19803	0.1936
17/06/2008	5.48602	5.49664	0.1936
18/06/2008	6.53998	6.55264	0.1936
19/06/2008	3.44403	3.45070	0.1936
20/06/2008	4.83795	4.84732	0.1936
21/06/2008	0.66003	0.66131	0.1936
22/06/2008	5.85797	5.86931	0.1936
23/06/2008	5.01202	5.02172	0.1936
24/06/2008	4.41101	4.41955	0.1936
25/06/2008	4.07001	4.07789	0.1936
26/06/2008	5.22198	5.23209	0.1936
27/06/2008	0.00000	0.00000	
28/06/2008	0.00000	0.00000	
29/06/2008	0.06702	0.06715	0.1936
30/06/2008	3.95898	3.96664	0.1936
01/07/2008	3.31799	3.32441	0.1936
02/07/2008	3.53198	3.53882	0.1936
03/07/2008	3.61005	3.61704	0.1936
04/07/2008	0.01099	0.01101	0.1936
05/07/2008	0.00000	0.00000	

06/07/2008	0.00000	0.00000	
07/07/2008	3.73401	3.74124	0.1936
08/07/2008	0.00696	0.00697	0.1936
09/07/2008	4.27502	4.28330	0.1936
10/07/2008	3.87201	3.87951	0.1936
11/07/2008	4.31500	4.32335	0.1936
12/07/2008	0.73596	0.73738	0.1936
13/07/2008	0.00000	0.00000	
14/07/2008	0.00000	0.00000	
15/07/2008	0.00000	0.00000	
16/07/2008	0.06702	0.06711	0.1361
17/07/2008	0.08899	0.08912	0.1448
18/07/2008	0.00000	0.00000	
19/07/2008	0.00000	0.00000	
20/07/2008	0.00000	0.00000	
21/07/2008	0.00000	0.00000	
22/07/2008	0.00000	0.00000	
23/07/2008	0.00000	0.00000	
24/07/2008	0.00000	0.00000	
25/07/2008	0.00000	0.00000	
26/07/2008	0.00000	0.00000	
27/07/2008	0.00000	0.00000	
28/07/2008	0.00000	0.00000	
29/07/2008	0.00000	0.00000	
30/07/2008	0.00000	0.00000	
31/07/2008	0.00000	0.00000	
01/08/2008	0.62097	0.62206	0.1752
02/08/2008	0.00000	0.00000	
03/08/2008	0.00000	0.00000	
04/08/2008	0.02100	0.02104	0.1752
05/08/2008	0.00000	0.00000	
06/08/2008	0.00000	0.00000	
07/08/2008	0.00000	0.00000	
08/08/2008	0.00000	0.00000	
09/08/2008	0.00000	0.00000	
10/08/2008	0.00000	0.00000	
11/08/2008	0.00000	0.00000	
12/08/2008	0.00000	0.00000	
13/08/2008	0.00000	0.00000	
14/08/2008	0.00000	0.00000	
15/08/2008	0.00000	0.00000	
16/08/2008	0.00000	0.00000	
17/08/2008	0.00000	0.00000	
18/08/2008	0.00000	0.00000	
19/08/2008	0.31903	0.31959	0.1752
20/08/2008	0.12201	0.12222	0.1752
21/08/2008	3.81696	3.82365	0.1752
22/08/2008	3.65802	3.66443	0.1752
23/08/2008	0.00000	0.00000	
24/08/2008	0.00000	0.00000	
25/08/2008	0.00000	0.00000	
26/08/2008	0.00000	0.00000	
27/08/2008	0.00000	0.00000	
28/08/2008	0.00000	0.00000	
29/08/2008	0.00000	0.00000	
30/08/2008	0.00000	0.00000	
31/08/2008	0.00000	0.00000	
01/09/2008	0.00000	0.00000	
02/09/2008	0.20001	0.20036	0.1752
03/09/2008	0.00000	0.00000	
04/09/2008	0.00000	0.00000	

05/09/2008	1.24597	1.24815	0.1752
06/09/2008	3.83002	3.83673	0.1752
07/09/2008	4.20898	4.21635	0.1752
08/09/2008	4.81403	4.82246	0.1752
09/09/2008	5.69800	5.70798	0.1752
10/09/2008	5.30200	5.31129	0.1752
11/09/2008	4.80499	4.81341	0.1752
12/09/2008	4.60602	4.61409	0.1752
13/09/2008	3.41901	3.42500	0.1752
14/09/2008	0.00000	0.00000	
15/09/2008	0.00000	0.00000	
16/09/2008	6.36096	6.37210	0.1752
17/09/2008	6.81604	6.82798	0.1752
18/09/2008	5.94501	5.95543	0.1752
19/09/2008	5.06696	5.07584	0.1752
20/09/2008	4.05701	4.06412	0.1752
21/09/2008	4.46399	4.47181	0.1752
22/09/2008	5.82001	5.83021	0.1752
23/09/2008	6.51202	6.52343	0.1752
24/09/2008	6.50000	6.51139	0.1752
25/09/2008	6.26001	6.27098	0.1752
26/09/2008	6.06396	6.07458	0.1752
27/09/2008	5.33600	5.34535	0.1752
28/09/2008	6.27399	6.28498	0.1752
29/09/2008	8.82703	8.84249	0.1752
30/09/2008	8.34998	8.36461	0.1752
01/10/2008	6.89404	6.90612	0.1752
02/10/2008	6.09796	6.10864	0.1752
03/10/2008	6.91101	6.92312	0.1752
04/10/2008	6.16602	6.17682	0.1752
05/10/2008	5.05298	5.06183	0.1752
06/10/2008	5.26904	5.27827	0.1752
07/10/2008	4.88800	4.89656	0.1752
08/10/2008	4.52698	4.53491	0.1752
09/10/2008	5.28198	5.29123	0.1752
10/10/2008	5.79803	5.80819	0.1752
11/10/2008	4.64197	4.65010	0.1752
12/10/2008	5.03101	5.03982	0.1752
13/10/2008	5.07404	5.08293	0.1752
14/10/2008	6.33997	6.35108	0.1752
15/10/2008	7.44800	7.46105	0.1752
16/10/2008	8.62700	8.64211	0.1752
17/10/2008	7.61500	7.62834	0.1752
18/10/2008	7.43500	7.44803	0.1752
19/10/2008	7.42300	7.43601	0.1752
20/10/2008	9.60700	9.61711	0.1052
21/10/2008	9.42400	9.43655	0.1332
22/10/2008	10.00700	10.01592	0.0891
23/10/2008	10.99700	11.00663	0.0876
24/10/2008	9.58100	9.58939	0.0876
25/10/2008	9.69100	9.69948	0.0875
26/10/2008	9.68600	9.69448	0.0875
27/10/2008	12.07600	12.08657	0.0875
28/10/2008	11.95700	11.96747	0.0875
29/10/2008	12.43000	12.44088	0.0875
30/10/2008	11.55900	11.56912	0.0875
31/10/2008	10.91800	10.92755	0.0875
01/11/2008	9.79300	9.80157	0.0875
02/11/2008	10.59300	10.60228	0.0876
03/11/2008	9.58200	9.59039	0.0876
04/11/2008	8.22000	8.22720	0.0876

05/11/2008	9.55301	9.56138	0.0876
06/11/2008	9.10199	9.10996	0.0876
07/11/2008	9.53700	9.54535	0.0876
08/11/2008	8.54401	8.55149	0.0876
09/11/2008	10.62400	10.63331	0.0876
10/11/2008	12.06200	12.07257	0.0876
11/11/2008	11.83500	11.84537	0.0876
12/11/2008	10.03700	10.04579	0.0876
13/11/2008	9.03900	9.04691	0.0875
14/11/2008	7.03802	7.04415	0.0870
15/11/2008	6.88998	6.89598	0.0870
16/11/2008	9.60300	9.61141	0.0875
17/11/2008	8.19302	8.20019	0.0875
18/11/2008	6.99197	6.99809	0.0876
19/11/2008	8.73102	8.73866	0.0875
20/11/2008	8.66098	8.66856	0.0875
21/11/2008	8.75000	8.75766	0.0875
22/11/2008	8.08502	8.09210	0.0875
23/11/2008	8.91901	8.92682	0.0875
24/11/2008	8.82098	8.82870	0.0875
25/11/2008	8.85400	8.86175	0.0875
26/11/2008	6.46799	6.47365	0.0876
27/11/2008	7.39301	7.39948	0.0875
28/11/2008	10.28800	10.29700	0.0875
29/11/2008	13.62900	13.64093	0.0876
30/11/2008	13.38400	13.39572	0.0875
01/12/2008	13.55700	13.56887	0.0875
02/12/2008	13.49700	13.50882	0.0875
03/12/2008	13.73900	13.75103	0.0875
04/12/2008	11.54400	11.55410	0.0875
05/12/2008	10.24600	10.25497	0.0875
06/12/2008	8.47299	8.48040	0.0875
07/12/2008	10.77800	10.78743	0.0875
08/12/2008	8.29803	8.30529	0.0875
09/12/2008	11.17600	11.18578	0.0875
10/12/2008	10.60400	10.61328	0.0875
11/12/2008	11.59800	11.60815	0.0875
12/12/2008	10.57996	10.58922	0.0875
13/12/2008	8.51105	8.51850	0.0875
14/12/2008	8.62598	8.63353	0.0875
15/12/2008	11.30300	11.31289	0.0875
16/12/2008	7.82501	7.83186	0.0875
17/12/2008	7.91400	7.92093	0.0875
18/12/2008	6.62000	6.62580	0.0876
19/12/2008	8.84601	8.85375	0.0875
20/12/2008	8.23102	8.23823	0.0876
21/12/2008	7.46698	7.47352	0.0876
22/12/2008	6.73700	6.74290	0.0876
23/12/2008	8.10400	8.11109	0.0875
24/12/2008	7.01202	7.01816	0.0875
25/12/2008	6.64197	6.64779	0.0876
26/12/2008	8.36700	8.37432	0.0875
27/12/2008	9.44000	9.44826	0.0875
28/12/2008	10.36600	10.37507	0.0875
29/12/2008	11.02500	11.03465	0.0875
30/12/2008	13.19500	13.20655	0.0875
31/12/2008	14.84500	14.85799	0.0875
01/01/2009	11.54700	11.55710	0.0875
02/01/2009	9.73499	9.74351	0.0875
03/01/2009	9.48999	9.49829	0.0875
04/01/2009	9.49103	9.49934	0.0875

05/01/2009	11.99200	12.00249	0.0875
06/01/2009	10.09700	10.10584	0.0875
07/01/2009	9.06500	9.07293	0.0875
08/01/2009	9.64600	9.65444	0.0875
09/01/2009	11.14300	11.15275	0.0875
10/01/2009	12.54100	12.55198	0.0875
11/01/2009	9.92297	9.93165	0.0875
12/01/2009	7.77399	7.78080	0.0875
13/01/2009	10.01500	10.02376	0.0875
14/01/2009	9.68903	9.69751	0.0875
15/01/2009	8.77197	8.77965	0.0875
16/01/2009	8.61102	8.61855	0.0875
17/01/2009	7.82898	7.83583	0.0875
18/01/2009	8.88098	8.88875	0.0875
19/01/2009	11.00400	11.01363	0.0875
20/01/2009	9.31500	9.32315	0.0875
21/01/2009	9.30200	9.31014	0.0875
22/01/2009	8.89301	8.90079	0.0875
23/01/2009	9.96301	9.97173	0.0875
24/01/2009	8.87897	8.88674	0.0875
25/01/2009	7.39398	7.40045	0.0875
26/01/2009	9.31702	9.32517	0.0875
27/01/2009	9.03100	9.03890	0.0875
28/01/2009	7.87600	7.88289	0.0875
29/01/2009	8.97100	8.97885	0.0875
30/01/2009	10.94300	10.95257	0.0875
31/01/2009	10.13300	10.14186	0.0875
01/02/2009	12.15200	12.16263	0.0875
02/02/2009	11.49000	11.50005	0.0875
03/02/2009	10.16400	10.17289	0.0875
04/02/2009	11.01500	11.02464	0.0875
05/02/2009	11.88300	11.89340	0.0875
06/02/2009	10.15100	10.15988	0.0875
07/02/2009	9.85600	9.86462	0.0875
08/02/2009	11.63800	11.64818	0.0875
09/02/2009	11.36199	11.37193	0.0875
10/02/2009	10.02400	10.03277	0.0875
11/02/2009	10.41200	10.42110	0.0874
12/02/2009	12.22300	12.23370	0.0875
13/02/2009	8.60500	8.61253	0.0875
14/02/2009	7.91000	7.91692	0.0875
15/02/2009	6.50099	6.50668	0.0875
16/02/2009	7.65601	7.66271	0.0875
17/02/2009	6.60600	6.61178	0.0876
18/02/2009	6.52000	6.52571	0.0875
19/02/2009	7.79100	7.79782	0.0875
20/02/2009	8.35799	8.36531	0.0875
21/02/2009	7.39001	7.39648	0.0875
22/02/2009	7.94598	7.95293	0.0875
23/02/2009	8.11301	8.12011	0.0875
24/02/2009	8.52100	8.52846	0.0875
25/02/2009	8.62701	8.63456	0.0875
26/02/2009	7.73999	7.74676	0.0875
27/02/2009	6.57800	6.58376	0.0875
28/02/2009	8.42499	8.43236	0.0875
01/03/2009	8.75803	8.76570	0.0875
02/03/2009	8.25400	8.26122	0.0875
03/03/2009	8.08499	8.09207	0.0875
04/03/2009	8.77899	8.78667	0.0875
05/03/2009	8.08502	8.09210	0.0875
06/03/2009	7.47299	7.47953	0.0875

07/03/2009	6.54402	6.54975	0.0876
08/03/2009	7.79898	7.80581	0.0875
09/03/2009	8.07800	8.08507	0.0875
10/03/2009	8.15302	8.16016	0.0875
11/03/2009	6.61499	6.62078	0.0876
12/03/2009	6.00201	6.00727	0.0876
13/03/2009	7.17099	7.17727	0.0875
14/03/2009	7.53900	7.54560	0.0875
15/03/2009	6.13800	6.14337	0.0875
16/03/2009	6.52301	6.52872	0.0875
17/03/2009	6.63199	6.64106	0.1368
18/03/2009	6.09799	6.10867	0.1752
19/03/2009	5.78201	5.79214	0.1752
20/03/2009	6.27301	6.28400	0.1752
21/03/2009	8.71799	8.73326	0.1752
22/03/2009	7.60800	7.62133	0.1752
23/03/2009	10.03800	10.05559	0.1752
24/03/2009	8.22302	8.23743	0.1752
25/03/2009	9.87598	9.89328	0.1752
26/03/2009	6.82800	6.83996	0.1752
27/03/2009	5.16000	5.16904	0.1752
28/03/2009	6.12402	6.13475	0.1752
29/03/2009	5.03699	5.04581	0.1752
30/03/2009	6.21100	6.22188	0.1752
31/03/2009	4.84003	4.84851	0.1752
01/04/2009	6.02997	6.04053	0.1752
02/04/2009	6.40002	6.41123	0.1752
03/04/2009	7.57098	7.58424	0.1752
04/04/2009	7.82898	7.84270	0.1752
05/04/2009	7.67303	7.68647	0.1752
06/04/2009	7.91296	7.92682	0.1752
07/04/2009	7.05304	7.06540	0.1752
08/04/2009	7.61298	7.62632	0.1752
09/04/2009	6.69403	6.70576	0.1752
10/04/2009	6.72998	6.74177	0.1752
11/04/2009	5.87396	5.88425	0.1752
12/04/2009	3.08606	3.09147	0.1752
13/04/2009	2.75397	2.75879	0.1752
14/04/2009	4.32898	4.33656	0.1752
15/04/2009	4.34399	4.35160	0.1752
16/04/2009	5.81500	5.82519	0.1752
17/04/2009	6.40405	6.41527	0.1752
18/04/2009	4.84100	4.84948	0.1752
19/04/2009	4.08795	4.09511	0.1752
20/04/2009	4.10205	4.10924	0.1752
21/04/2009	4.88696	4.89552	0.1752
22/04/2009	4.57300	4.58101	0.1752
23/04/2009	3.79004	3.79668	0.1752
24/04/2009	4.51996	4.52788	0.1752
25/04/2009	3.99103	3.99802	0.1752
26/04/2009	5.25897	5.26818	0.1752
27/04/2009	7.67603	7.68948	0.1752
28/04/2009	7.73901	7.75257	0.1752
29/04/2009	6.29498	6.30601	0.1752
30/04/2009	7.20801	7.22064	0.1752
01/05/2009	5.62799	5.63785	0.1752
02/05/2009	5.14099	5.15000	0.1752
03/05/2009	5.73102	5.74106	0.1752
04/05/2009	8.45300	8.46781	0.1752
05/05/2009	8.55298	8.56796	0.1752
06/05/2009	6.24103	6.25196	0.1752

07/05/2009	5.75897	5.76906	0.1752
08/05/2009	3.64703	3.65342	0.1752
09/05/2009	0.00000	0.00000	
10/05/2009	0.00000	0.00000	
11/05/2009	0.00000	0.00000	
12/05/2009	0.00000	0.00000	
13/05/2009	0.00000	0.00000	
14/05/2009	0.00000	0.00000	
15/05/2009	0.00000	0.00000	
16/05/2009	0.00098	0.00098	0.0000
17/05/2009	0.00000	0.00000	
18/05/2009	0.00000	0.00000	
19/05/2009	0.00000	0.00000	
20/05/2009	0.00000	0.00000	
21/05/2009	0.00000	0.00000	
22/05/2009	0.00104	0.00104	0.0000
23/05/2009	0.00000	0.00000	
24/05/2009	0.00000	0.00000	
25/05/2009	0.00000	0.00000	
26/05/2009	0.00000	0.00000	
27/05/2009	0.00000	0.00000	
28/05/2009	0.00000	0.00000	
29/05/2009	1.33801	1.34035	0.1752
30/05/2009	5.30499	5.31428	0.1752
31/05/2009	5.25403	5.26324	0.1752
01/06/2009	5.57300	5.58276	0.1752
02/06/2009	5.58398	5.59376	0.1752
03/06/2009	0.11401	0.11421	0.1752
04/06/2009	0.00000	0.00000	
05/06/2009	0.00000	0.00000	
06/06/2009	0.00000	0.00000	
07/06/2009	5.61096	5.62079	0.1752
08/06/2009	5.04700	5.05584	0.1752
09/06/2009	5.04199	5.05082	0.1752
10/06/2009	4.18402	4.19135	0.1752
11/06/2009	4.01501	4.02204	0.1752
12/06/2009	3.48102	3.48712	0.1752
13/06/2009	5.23999	5.24917	0.1752
14/06/2009	5.44501	5.45455	0.1752
15/06/2009	5.92896	5.93935	0.1752
16/06/2009	5.95300	5.96343	0.1752
17/06/2009	7.27802	7.29077	0.1752
18/06/2009	7.68103	7.69449	0.1752
19/06/2009	7.93799	7.95190	0.1752
20/06/2009	6.88397	6.89603	0.1752
21/06/2009	7.13104	7.14353	0.1752
22/06/2009	6.77197	6.78383	0.1752
23/06/2009	5.91901	5.92938	0.1752
24/06/2009	5.96899	5.97945	0.1752
25/06/2009	5.87000	5.88028	0.1752
26/06/2009	1.82300	1.82619	0.1752
27/06/2009	0.00000	0.00000	
28/06/2009	0.00000	0.00000	
29/06/2009	0.11896	0.11917	0.1752
30/06/2009	0.08203	0.08214	0.1375
01/07/2009	0.05505	0.05515	0.1752
02/07/2009	0.10497	0.10502	0.0448