Measurement Error Register

Unique Reference Number	DN Reference	Description	Offtake	LDZ	Downstream Transporter	Significance Low <30GWH Medium >=30<50GWh High >=50GWh			Discovered		First Gas Day Where Error Present or;	Last Known Good Gas Day	Last Gas Day Where Error Present		Latest Error Status	Live/ Closed	Invoice issued by Xoserve
EA017	MER/CAD/215/22	Intermittent flow on USM	Westry	EA	Cadent Gas Limited - DN	Low	0.01	0.5	28/04/2022	28/04/2022	17/04/2022	N/A	28/04/2022	29/09/2022	MER Published	Live	1
EM011		Orifice Plate error caused by incorrect seating within carrier	Thornton Curtis MTA	EM	Cadent Gas Limited - DN	High	75.93	839	04/07/2022	07/07/2022	21/04/2022	0	04/07/2022	22/06/2023	SMER Published	Live	
EM013	MER/CAD/217/22	Intermittent flow on USM	Stoke Bardolph 2	EM	Cadent Gas Limited – DN (EM)	Low	0.001	0.002	31/03/2022	01/04/2022	30/03/2022	N/A	05/04/2022	29/09/2022	MER Published	Live	1
SW038		Human error led to entering K-Factors and frequencies for both streams into the Omni flow computer incorrectly	Easton Grey MTA	SW	Wales & West Utilities - DN	Low	0.52	5.49	02/03/2023	21/04/2023	15/06/2020		18/04/2023	21/04/2023	MER Published	Live	
SW039		Data entry correction following meter flow signal failure.	Cirencester MRA	SW	Wales & West Utilities - DN	Low	0.19946	2.17	09/01/2023	28/04/2023	09/01/2023		09/03/2023	28/04/2023	MER Published	Live	
WM026	MER/CAD/214/22	Intermittent flow on USM	Lower Drayton Farm	WM	Cadent Gas Limited - DN (WM)	Low	0.000022	0.0002	31/03/2022	01/04/2022	08/03/2022	N/A	08/03/2022	29/09/2022	MER Published	Live	Biomethane
WM027		Disrepency found between metering system and RTU.	Atherstone MRA MRB Combined	WM	Cadent Gas Limited – DN (WM)	not provided	TBC	TBC	08/06/2023	08/06/2023	TBC		TBC	14/06/2023	Error Notified	Live	l
																	1
																	1
																	ı