

Stage 01: Proposal

0389: Simplification of points of telemetry

What stage is this document in the process?

- 01 Proposal
- 02 Workgroup Report
- 03 Draft Modification Report
- 04 Final Modification Report

Simplification of the points of telemetry described within Annex E-1 of the Offtake Arrangements Document.



The Proposer recommends that this self-governance modification should be considered by the Panel in September 2011



High Impact:
N/A



Medium Impact:
N/A



Low Impact:
National Grid Transmission and the Distribution Transporters

Contents

- 1 Summary
- 2 Why Change?
- 3 Solution
- 4 Relevant Objectives
- 5 Impacts and Costs
- 6 Implementation
- 7 The Case for Change
- 8 Legal Text
- 9 Recommendation

About this document:

This document is an amended Modification Proposal. The changes reflect industry feedback received on the original published version 1 which was presented by the Proposer to the Modification Panel on 21 July 2011 and subsequently discussed at the Offtake Arrangements Workgroup.



3 **Any questions?**

5 Contact:

6 **Dave Corby**



11 **David.Corby@uk.ngri**
12 **d.com**



14 **01926 654912**

15 Proposer:

16 **Dave Corby**



19 **David.Corby@uk.**
ngrid.com



01926 654912

Transporter:

National Grid
Transmission



...@...



0000 000 000

Xoserve:

Insert name



commercial.enquiries
@xoserve.com



0000 000 000

0389

Simplification of Points of
Telemetry

17 August 2011

Version 2

Page 2 of 19

© 2011 all rights reserved

1 Summary

Is this a Self Governance Modification

The proposer believes this is a Self Governance Modification as it concerns arrangements for the ongoing efficient and economic provision of point of telemetry items between

Transporters. As such, the modification:

- (i) is unlikely to have a material effect on:
 - (aa) existing or future gas consumers; and
 - (bb) competition in the shipping, transportation or supply of gas conveyed through pipes or any commercial activities connected with the shipping, transportation or supply of gas conveyed through pipes; and
 - (cc) the operation of one or more pipe-line system(s); and
 - (dd) matters relating to sustainable development, safety or security of supply, or the management of market or network emergencies; and
 - (ee) the uniform network code governance procedures or the network code modification procedures; and
- (ii) is unlikely to discriminate between different classes of parties to the uniform network code/relevant gas transporters, gas shippers or DN operators.



What is a point of telemetry

A point of telemetry is a data item relating to connection facilities or gas flowing at an NTS / LDZ Offtake.

See OAD Section E 1.2.1(d)

In July 2011 the Modification Panel agreed that this proposal meets the self governance criteria.

Why Change?

The Enduring Distribution Networks Arrangements (EDNA) Project Team was established by UNC Transporters to discuss what arrangements were required to manage the interface between the Transmission and the Distribution Network Operator systems post System Operator Managed Service Agreement (SOMSA).

One of the recommendations of the EDNA Project Team was that the points of telemetry as defined within the Offtake Arrangements Document (OAD), Section E Annex E-1, should be revised to reflect the operational requirements, as identified in the development of the Distribution Networks Control System (DNCS). It was identified at that time that the current list of points of telemetry in Annex E-1 are not all operationally required, and therefore the UNC does not reflect the proposed operational practice and the subsequent design of the interface between the DNCS and National Grid Transmission (NGT) systems.

Solution

This modification proposes to replace the tables in Annex E-1 (Parts 1 through to 5) with a simpler structure and split into 4 Parts. It is also proposed to rationalise the list of points of telemetry contained in these tables.

Impacts & Costs

This Modification aims to bring the UNC in line with the new systems and operational processes employed. No systems changes have been identified as required to support the implementation of this Modification Proposal. No costs are anticipated to implement this Modification Proposal.

0389

Simplification of Points of Telemetry

17 August 2011

Version 2

Page 3 of 19

© 2011 all rights reserved

Implementation

In July 2011 the Modification panel agreed this proposal as a self-governance modification. Accordingly implementation will be 16 business days after a Modification Panel decision to implement is received.

The Case for Change

The rationalisation of the data items required to be transferred across the interface between DNCS and National Grid Transmission's systems increases the efficiency of the coordination between the DNS' systems and the National Transmission System. Therefore, this modification supports Relevant Objective C: Coordinated, efficient and economic operation of the combined pipe-line system.

Recommendations

The proposer asks that the Modification Panel consider this Modification Proposal as a Self-Governance Modification and consider that it move directly to Consultation.

2 Why Change?

To align UNC with operational requirements

The EDNA Project Team was established by Transporters to discuss what arrangements were required to manage the interface arrangements between the Transmission and the Distribution Network Operator Systems post System Operator Managed Service Agreement (SOMSA). The EDNA Project Team identified a number of improvements that should be made for the enduring regime, one of which is being addressed through this Modification.

The points of telemetry to be provided by DNOs to NGT are described in the Offtake Arrangements Document (OAD), Section E Annex E-1. During the development of DNCS it was identified that the current list of points of telemetry in Annex E-1 does not match the operational requirements and the subsequent design of the new interface between DNCS and NGT systems. A number of the existing points of telemetry currently listed in UNC are no longer required, and the existing definitions of the individual points of telemetry can be updated to provide increased clarity.

This Modification proposes to bring the UNC, OAD Section E Annex E-1 in line with current operational requirements.

3 Solution

3.1 Background

Currently Annex E-1 shows 5 tables (table 2 has 2 parts):

- 1 "General Analogues"
- 2a "FWACV Analogues – CV-Directed Offtakes"
- 2b "FWACV Analogues NTS/LDZ Offtakes which are not CV-Directed Offtakes"
- 3 "States (All Sites)"
- 4 "Controls"
- 5 "Counters"

These tables contain columns showing the point of telemetry, whether the requirement is relevant to any offtake, or if the requirement is relevant only for a specific site, and an associated comment.

3.2 Proposal

This modification proposes that the tables currently detailed in Annex E-1 are replaced by the following revised tables (see below). The revised tables shall be split into the following 4 parts:

- "Analogues"
- "Digitals"
- "Valve Monitoring / Control"
- "Integrators"

Note that the change in names to the parts of the tables, as well as the change in names to the points of telemetry themselves, more accurately describe the data and therefore enhance clarity.

The existing tables in Annex E1 include points of telemetry that are no longer required. The points of telemetry detailed in the proposed revised tables, below, represent a reduced list of points of telemetry that exclude the items no longer required.

For the avoidance of doubt, the revised list of points of telemetry, below, include only four new points of telemetry (detailed in 3.2.1 below) that are not already provided in the current Code. These four new points of telemetry do not represent any data beyond that currently being provided to IGMS via the SCADA link from DNCS.

3.2.1 Revised points of telemetry

The tables presented below detail the points of telemetry currently shown in OAD Section E Annex E1 (in the "Current OAD Annex Ref" column) versus the proposed revised points of telemetry (in the "Proposed OAD Annex Ref" column). The third column details the proposed revised table that the point of telemetry shall be categorised under.

Where the "Proposed OAD Annex Ref" column is blank this represents a point of telemetry that the modification proposes to eliminate, reducing the obligation on the DNOs.

Current OAD Annex Table 1:

Current OAD Annex Ref	Proposed OAD Annex Ref	Proposed OAD Annex Table
Pressures(s)	Feeder/Inlet pressure	Analogues
Outlet Pressure(s)	Outlet Pressure	Analogues
Interstage Pressure(s)		
Temperature(s)	Outlet Gas Temperature	Analogues
Orifice DP(s)	Orifice Standby Differential Pressure	Analogues
Orifice DP(s)	Orifice 'In Use' Differential Pressure	Analogues
Filter DP	Filter Differential Pressure	Analogues
FCV position(s)		
Flow Setpoint(s)		
Low Pressure Override Setpoints		
High Pressure Override Setpoints		
Outlet Pressure set point		
Compressibility	Compressibility	Analogues
Flow meter temperature	Flow Meter Temperature	Analogues

Current OAD Annex Table 2 (A and B):

Current OAD Annex Ref	Proposed OAD Annex Ref	Proposed OAD Annex Table
Calorific Value	Calorific Value	Analogues
Relative Density	Relative Density	Analogues
Nitrogen	Nitrogen	Analogues
Carbon Dioxide	Carbon Dioxide	Analogues
Wobbe	Wobbe	Analogues
24 Hour Average CV	24 Hour Average CV	Analogues
24 Hour Average RD	24 Hour Relative RD	Analogues
Inst. Volume Flow(s)	Instantaneous Flow	Analogues
Inst. Energy Flow(s)	Instantaneous Energy Flow	Analogues
CV Tracker	24 Hour Average CV	Analogues
RD Tracker	24 Hour Relative RD	Analogues

Current OAD Annex Table 3:

In this table there are a number of proposed points of telemetry not corresponding to the Current OAD Annex. With the exception of the bottom three these do not represent new points of telemetry, but instead are redefined expansions of the existing OAD.

For example, the current "Instrument Fault" point of telemetry has a comment in the OAD Annex which reads "If fitted (may include RTU communications faults, barrier faults etc)". The proposed revision splits this point of telemetry into "Barrier", "Local Comms Link Status", "RTU Fault" and "Watchdog". This removes the ambiguity in the current OAD and provides clarity as to the exact Instrument Fault points of telemetry to be provided.

The same principle follows for the current "Site Charger Alarm", "Generator Running / Locked Out" and "Metering Alarm" points of telemetry.

The last three proposed points of telemetry (Valve Position, Comms Routing and Outstation) are not detailed in the current OAD column as they represent data items currently being provided via the SCADA link, but not detailed in the current OAD.

Current OAD Annex Ref	Proposed OAD Annex Ref	Proposed OAD Annex Table
Filter	Filter	Digitals
Slam Shut		
Maintenance Key	Maintenance Key	Digitals
Inlet pressure alarm		
Outlet pressure alarm		
Heater/boiler status alarms		
Instrument fault	Barrier	Digitals
	Local Comms Link Status	Digitals
	RTU Fault	Digitals
	Watchdog	Digitals
Intruder	Intruder	Digitals
System Alarm(s)	Gas Quality System Alarm	Digitals
Instrument Gas Fail		
Override	Pressure Override Alarm	Digitals
Site Mains Supply	Power	Digitals
Site Charger Alarm	Charger	Digitals
	Site UPS	Digitals
Generator running/locked out	Generator Alarm	Digitals
	Generator Available	Digitals
	Generator Bypass	Digitals
	Generator Trip	Digitals
	Generator Running	Digitals
	Generator Status	Digitals
Metering alarm	Metering Alarm	Digitals
	Meter Stream Change	Digitals

Remotely Operable Meter Valves	Meter Valve Position	Digitals
CV or tracker UPS alarm	Gas Quality System UPS	Digitals
CV Not Valid	CV Not Valid	Digitals
CV Not Attributable	CV Not Attributable	Digitals
FWACV Remote Access alarm		
Status Local/Remote	Status Local/Remote	Digitals
FCV Selected		
FCV Parallel		
Mode SPC/DVC		
Override in DVC		
Local Valve Indications		
Pump A common alarm		
Pump B common alarm		
Tank low level		
Power Supply		
	Valve Position of Feeder / Inlet isolation Valves	Digitals
	Comms Routing Status	Digitals
	Outstation Comms Status	Digitals

Current OAD Annex Table 4:

Current OAD Annex Ref	Proposed OAD Annex Ref	Proposed OAD Annex Table
Remote Flow Control Valves		
Remotely Operable Meter Valves		
FCV Select		
SPC/DVC Select		
Override in DVC		
FCV Parallel		
Flow Setpoint		
DVC Control		
Low Pressure Override		
High Pressure Override		
	Control function for Remotely Operable Valves operated by National Grid NTS	Controls

The last proposed point of telemetry (Control Function for Remotely Operable Valves...) represents a data item currently being provided via the SCADA link, but not detailed in the current OAD.

Current OAD Annex Table 5:

Current OAD Annex Ref	Proposed OAD Annex Ref	Proposed OAD Annex Table
Volume integrators	Offtake Flow Integrator	Integrators
Boiler Volume Integrators	Fuel Gas for Pre-Heater Volume Integrator	Integrators
Boiler Energy Integrators	Fuel Gas for Pre-Heater Energy Integrator	Integrators
Energy integrators	Offtake Energy Integrator	Integrators
Pump A flow integrator		
Pump B flow integrator		

4 Relevant Objectives

Implementation is expected to better facilitate the achievement of **Relevant Objective F: Promotion of efficiency in the implementation and administration of the Code.**

Proposer's view of the benefits against the Code Relevant Objectives

Description of Relevant Objective	Identified impact
a) Efficient and economic operation of the pipe-line system.	
b) Coordinated, efficient and economic operation of (i) the combined pipe-line system, and/ or (ii) the pipe-line system of one or more other relevant gas transporters.	Rationalisation of code to reflect the operational requirement for point of telemetry data between DNCS and NGT systems.
c) Efficient discharge of the licensee's obligations.	
d) Securing of effective competition: (i) between relevant shippers; (ii) between relevant suppliers; and/or (iii) between DN operators (who have entered into transportation arrangements with other relevant gas transporters) and relevant shippers.	
e) Provision of reasonable economic incentives for relevant suppliers to secure that the domestic customer supply security standards... are satisfied as respects the availability of gas to their domestic customers.	
f) Promotion of efficiency in the implementation and administration of the Code	

Coordinated, efficient and economic operation of the combined pipe-line system

The proposer considers that this change rationalises the UNC to reflect the operational requirement for point of telemetry data transfer between DNCS and NGT systems thereby enhancing the coordinated, efficient and economic operation of the combined pipe-line system.

5 Impacts and Costs

This Modification proposes to change the OAD such that it is in-line with the revised point of telemetry data items specified as part of the requirements for DNCS development.

Consideration of Wider Industry Impacts

No wider industry impacts identified.

Costs

Indicative industry costs – User Pays
No costs identified.

Impacts

Impact on Transporters' Systems and Process	
Transporters' System/Process	Potential impact
UK Link	None
Operational Processes	Improvement in the efficiency of passage of data between transporters.
User Pays implications	None

Impact on Users	
Area of Users' business	Potential impact
Administrative and operational	None
Development, capital and operating costs	None
Contractual risks	None
Legislative, regulatory and contractual obligations and relationships	None

Impact on Transporters	
Area of Transporters' business	Potential impact
System operation	None
Development, capital and operating costs	None
Recovery of costs	None

Impact on Transporters	
Price regulation	None
Contractual risks	None
Legislative, regulatory and contractual obligations and relationships	None
Standards of service	None

Impact on Code Administration	
Area of Code Administration	Potential impact
Modification Rules	None
UNC Committees	None
General administration	None

Impact on Code	
Code section	Potential impact
Offtakes Arrangements Document, Section E, Annex E-1	As described in Section 3 of this document.

Impact on UNC Related Documents and Other Referenced Documents	
Related Document	Potential impact
Network Entry Agreement (TPD I1.3)	None
Network Exit Agreement (Including Connected System Exit Points) (TPD J1.5.4)	None
Storage Connection Agreement (TPD R1.3.1)	None
UK Link Manual (TPD U1.4)	None
Network Code Operations Reporting Manual (TPD V12)	None
Network Code Validation Rules (TPD V12)	None
ECQ Methodology (TPD V12)	None
Measurement Error Notification Guidelines (TPD V12)	None
Energy Balancing Credit Rules (TPD X2.1)	None
Uniform Network Code Standards of Service (Various)	None

Impact on Core Industry Documents and other documents	
Document	Potential impact
Safety Case or other document under Gas Safety (Management) Regulations	None
Gas Transporter Licence	None

Other Impacts	
Item impacted	Potential impact
Security of Supply	None
Operation of the Total System	Enables continued efficient operation of Transmission and Distribution systems
Industry fragmentation	None
Terminal operators, consumers, connected system operators, suppliers, producers and other non code parties	None

6 Implementation

Proposed Implementation Timetable	
Activity	Date
Development Workstream	August 2011
Modification proposed to Panel for Consultation	September 2011
Consultation	September 2011 – October 2011
Panel consideration	October 2011
Ofgem Decision	N/A
Implementation	<p>In July 2011 the Modification panel agreed this proposal as a self-governance modification.</p> <p>Accordingly implementation will be 16 business days after a Modification Panel decision to implement is received.</p>

7 The Case for Change

In addition to that identified the above, the Proposer has identified the following:

Advantages

None identified further to Section 2, above.

Disadvantages

None identified.

8 Legal Text

Suggested legal text

OAD Annex E-1

Delete the table in Annex E-1 and replace as follows:

Analogues

Point Name	Minimum Requirement	Site Specific Option	Comments
Feeder/Inlet pressure	Yes		
Outlet Pressure	Yes		
Instantaneous Volume Flow	Yes		
Instantaneous Energy Flow	Yes		
Outlet Gas Temperature		Yes	
Calorific Value	Yes		
Relative Density	Yes		
Nitrogen	Yes		Except Tracker-only sites
Carbon Dioxide	Yes		Except Tracker-only sites
Wobbe	Yes		Except Tracker-only sites
24 Hour Average CV	Yes		
24 Hour Average RD	Yes		
Orifice Standby Differential Pressure	Yes		ODPn
Orifice Meter 'In Use' Differential Pressure		Yes	METER_DPn
Flow Meter Temperature		Yes	
Compressibility		Yes	
Filter Differential Pressure		Yes	

Digitals

Point Name	Minimum Requirement	Site Specific Option	Comments
Power	Yes		Mains/Phase Fail

0389

Simplification of Points of Telemetry

17 August 2011

Version 2

Page 16 of 19

© 2011 all rights reserved

Charger	Yes		
Site UPS		Yes	
Gas Quality System UPS	Yes		
Gas Quality System Alarm	Yes		SYSTEMn
Generator Alarm		Yes	
Generator Available		Yes	
Generator Bypass		Yes	
Generator Trip		Yes	
Generator Running		Yes	
Generator Status		Yes	
Barrier		Yes	
Local Comms Link Status		Yes	
RTU Fault		Yes	
Watchdog		Yes	Includes Computer alarm
Filter		Yes	
Maintenance Key		Yes	
Intruder		Yes	
Metering Alarm	Yes		MTR_SUSP
Meter Stream Change		Yes	
Meter Valve Position		Yes	
Status Local/Remote		Yes	
Pressure Override Alarm		Yes	
CV Not Valid	Yes		
CV Not Attributable	Yes		Except Tracker-only sites
Outstation Comms Status	Yes		
Comms Routing Status	Yes		

Valve Monitoring/Control

Point Name	Minimum Requirement	Site Specific Option	Comments
Control function for remotely operable valves operated by National Grid NTS	Yes		

Valve position of all Feeder / Inlet isolation valves	Yes		Valves operated by National Grid NTS and Distribution Networks for isolation of Feeder / inlet of site

Integrators

Point Name	Minimum Requirement	Site Specific Option	Comments
Offtake Volume Integrator	Yes		
Offtake Energy Integrator	Yes		
Fuel Gas for Pre-heater Volume Integrator		Yes	
Fuel Gas for Pre-heater Energy Integrator		Yes	

9 Recommendation

The Proposer invites the Panel to:

- Receive the Workgroup report on or before September 2011.
- DETERMINE that Modification Proposal subsequently progress to Consultation or return to Workgroup as necessary.