

Workgroup Terms of Reference

0581S – Amending the Oxygen content limit specified in the Network Entry Agreements at Grain LNG

Date referred from Panel: 19 May 2016

Background – Why Change?

Please refer to www.gasgovernance.co.uk/0581

Solution

It is proposed to increase the limit for oxygen, as defined within each of the 3 Grain LNG NEAs, from the current limit of 0.001 mol% (10 ppm), to 0.02 mol% (200ppm). The proposed value falls well within the Gas Safety (Management) Regulation limit of 0.2 mol% (2000ppm) and is consistent with the oxygen level recently approved for the BBL/NTS Interconnection Agreement under UNC Modification 0561S.

Topics for Discussion

- Exploration of the issues raised in the consultation and provide views on their materiality
- Understanding the objective
- Assessment of alternative means to achieve objective
- Development of Solution (including business rules if appropriate)
- Assessment of potential impacts of the modification
- Assessment of implementation costs
- Assessment of legal text.

Outputs

Produce a Workgroup Report for submission to the Modification Panel, containing the assessment and recommendations of the Workgroup.

Composition of Workgroup

The Workgroup is open to any party that wishes to attend or participate.

A Workgroup meeting will be quorate provided at least two Transporter and two User representatives are present.

Meeting Arrangements

Meetings will be administered by the Joint Office and conducted in accordance with the Code Administration Code of Practice